Altivar Process

Variable Speed Drives ATV630, ATV650

Installation Manual

04/2020





The information provided in this documentation contains general descriptions and/or technical characteristics of the performance of the products contained herein. This documentation is not intended as a substitute for and is not to be used for determining suitability or reliability of these products for specific user applications. It is the duty of any such user or integrator to perform the appropriate and complete risk analysis, evaluation and testing of the products with respect to the relevant specific application or use thereof. Neither Schneider Electric nor any of its affiliates or subsidiaries shall be responsible or liable for misuse of the information contained herein. If you have any suggestions for improvements or amendments or have found errors in this publication, please notify us.

You agree not to reproduce, other than for your own personal, noncommercial use, all or part of this document on any medium whatsoever without permission of Schneider Electric, given in writing. You also agree not to establish any hypertext links to this document or its content. Schneider Electric does not grant any right or license for the personal and noncommercial use of the document or its content, except for a non-exclusive license to consult it on an "as is" basis, at your own risk. All other rights are reserved.

All pertinent state, regional, and local safety regulations must be observed when installing and using this product. For reasons of safety and to help ensure compliance with documented system data, only the manufacturer should perform repairs to components.

When devices are used for applications with technical safety requirements, the relevant instructions must be followed.

Failure to use Schneider Electric software or approved software with our hardware products may result in injury, harm, or improper operating results.

Failure to observe this information can result in injury or equipment damage.

© 2020 Schneider Electric. All rights reserved.



Table of Contents



	Safety Information
	About the Book
Chapter 1	Introduction
	Verifying the Absence of Voltage
	ATV61/ATV71 to ATV600/ATV900 Migration
	Drive Overview
	Accessories and Options
	Green Premium™
	Steps for setting up the drive
	Preliminary Instructions
Chapter 2	Technical Data
2.1	Environment Data
	Temperature Conditions
	Altitude Conditions
	Chemical and Mechanical Conditions
2.2	Mechanical Data
	Dimensions and Weights
2.3	Electrical Data - Drive Ratings
	Drive Ratings In Normal Duty
	Drive Ratings In Heavy Duty
2.4	Electrical Data - Upstream Protective Device
	Introduction
	Prospective Short-Circuit Current
	IEC Type Circuit-Breaker as SCPD90
	IEC Fuses
	UL Circuit-Breakers and Fuses93
Chapter 3	Drive Mounting
•	Mounting Conditions
	Derating Curves
	Mounting Procedures
Chapter 4	Drive wiring
•	Wiring Instructions
	Specific Wiring Instructions For Wall Mounting Drives
	Specific Wiring Instructions For Floor Standing Drives
	Dimensioning Of Power Part Cables For Floor Standing Drives
	Cable Length Instructions
	General Wiring Diagrams
	Output Relay with Inductive AC Loads
	Output Relay with Inductive DC loads
	Digital Inputs Wiring Depending on Sink / Source Switch Configuration
	Characteristics of the Power Part Terminals
	Characteristics of the Power Part Terminals
	Electromagnetic Compatibility
	Operation on an IT or Corner Grounded System
	Disconnecting The Built-in EMC Filter
	Arrangement and Characteristics of Control Block Terminals and Communication and I/O
	Ports
	Control Terminals Electrical Data
	Wiring The Control Part
Chapter 5	Checking Installation
	Check List Before Switching On

Chapter 6	Maintenance
•	Scheduled Servicing
	Long-term Storage
	Decommissioning
	Additional Support
Glossarv	

cottle hinaiail.

4

Safety Information



Important Information

NOTICE

Read these instructions carefully, and look at the equipment to become familiar with the device before trying to install, operate, service, or maintain it. The following special messages may appear throughout this documentation or on the equipment to warn of potential hazards or to call attention to information that clarifies or simplifies a procedure.



The addition of this symbol to a "Danger" or "Warning" safety label indicates that an electrical hazard exists which will result in personal injury if the instructions are not followed.



This is the safety alert symbol. It is used to alert you to potential personal injury hazards. Obey all safety messages that follow this symbol to avoid possible injury or death

A DANGER

DANGER indicates a hazardous situation which, if not avoided, **will result in** death or serious injury.

WARNING

WARNING indicates a hazardous situation which, if not avoided, **could result in** death or serious injury.

▲ CAUTION

CAUTION indicates a hazardous situation which, if not avoided, **could result** in minor or moderate injury.

NOTICE

NOTICE is used to address practices not related to physical injury.

PLEASE NOTE

Electrical equipment should be installed, operated, serviced, and maintained only by qualified personnel. No responsibility is assumed by Schneider Electric for any consequences arising out of the use of this material.

A qualified person is one who has skills and knowledge related to the construction and operation of electrical equipment and its installation, and has received safety training to recognize and avoid the hazards involved.

Qualification Of Personnel

Only appropriately trained persons who are familiar with and understand the contents of this manual and all other pertinent product documentation are authorized to work on and with this product. In addition, these persons must have received safety training to recognize and avoid hazards involved. These persons must have sufficient technical training, knowledge and experience and be able to foresee and detect potential hazards that may be caused by using the product, by changing the settings and by the mechanical, electrical and electronic equipment of the entire system in which the product is used. All persons working on and with the product must be fully familiar with all applicable standards, directives, and accident prevention regulations when performing such work.

Intended Use

This product is a drive for three-phase synchronous, asynchronous motors and intended for industrial use according to this manual.

The product may only be used in compliance with all applicable safety standard and local regulations and directives, the specified requirements and the technical data. The product must be installed outside the hazardous ATEX zone. Prior to using the product, you must perform a risk assessment in view of the planned application. Based on the results, the appropriate safety measures must be implemented. Since the product is used as a component in an entire system, you must ensure the safety of persons by means of the design of this entire system (for example, machine design). Any use other than the use explicitly permitted is prohibited and can result in hazards.

Product Related Information

Read and understand these instructions before performing any procedure with this drive.

A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

- Only appropriately trained persons who are familiar with and understand the contents of this manual
 and all other pertinent product documentation and who have received safety training to recognize and
 avoid hazards involved are authorized to work on and with this drive system. Installation, adjustment,
 repair and maintenance must be performed by qualified personnel.
- The system integrator is responsible for compliance with all local and national electrical code requirements as well as all other applicable regulations with respect to grounding of all equipment.
- Many components of the product, including the printed circuit boards, operate with mains voltage.
- Only use properly rated, electrically insulated tools and measuring equipment.
- Do not touch unshielded components or terminals with voltage present.
- Motors can generate voltage when the shaft is rotated. Prior to performing any type of work on the drive system, block the motor shaft to prevent rotation.
- AC voltage can couple voltage to unused conductors in the motor cable. Insulate both ends of unused conductors of the motor cable.
- Do not short across the DC bus terminals or the DC bus capacitors or the braking resistor terminals.
- Before performing work on the drive system:
 - Disconnect all power, including external control power that may be present. Take into account that
 the circuit breaker or main switch does not de-energize all circuits.
 - O Place a **Do Not Turn On** label on all power switches related to the drive system.
 - O Lock all power switches in the open position.
 - O Wait 15 minutes to allow the DC bus capacitors to discharge.
 - Follow the instructions given in the chapter "Verifying the Absence of Voltage" in the installation manual of the product.
- Before applying voltage to the drive system:
 - Verify that the work has been completed and that the entire installation cannot cause hazards.
 - If the mains input terminals and the motor output terminals have been grounded and short-circuited, remove the ground and the short circuits on the mains input terminals and the motor output terminals.
 - O Verify proper grounding of all equipment.
 - Verify that all protective equipment such as covers, doors, grids is installed and/or closed.

Failure to follow these instructions will result in death or serious injury.

Damaged products or accessories may cause electric shock or unanticipated equipment operation.

⚠ ⚠ DANGER

ELECTRIC SHOCK OR UNANTICIPATED EQUIPMENT OPERATION

Do not use damaged products or accessories.

Failure to follow these instructions will result in death or serious injury.

Contact your local Schneider Electric sales office if you detect any damage whatsoever.

This equipment has been designed to operate outside of any hazardous location. Only install this equipment in zones known to be free of a hazardous atmosphere.

A DANGER

POTENTIAL FOR EXPLOSION

Install and use this equipment in non-hazardous locations only.

Failure to follow these instructions will result in death or serious injury.

Your application consists of a whole range of different interrelated mechanical, electrical, and electronic components, the drive being just one part of the application. The drive by itself is neither intended to nor capable of providing the entire functionality to meet all safety-related requirements that apply to your application. Depending on the application and the corresponding risk assessment to be conducted by you, a whole variety of additional equipment is required such as, but not limited to, external encoders, external brakes, external monitoring devices, guards, etc.

As a designer/manufacturer of machines, you must be familiar with and observe all standards that apply to your machine. You must conduct a risk assessment and determine the appropriate Performance Level (PL) and/or Safety Integrity Level (SIL) and design and build your machine in compliance with all applicable standards. In doing so, you must consider the interrelation of all components of the machine. In addition, you must provide instructions for use that enable the user of your machine to perform any type of work on and with the machine such as operation and maintenance in a safe manner.

The present document assumes that you are fully aware of all normative standards and requirements that apply to your application. Since the drive cannot provide all safety-related functionality for your entire application, you must ensure that the required Performance Level and/or Safety Integrity Level is reached by installing all necessary additional equipment.

A WARNING

INSUFFICIENT PERFORMANCE LEVEL/SAFETY INTEGRITY LEVEL AND/OR UNINTENDED EQUIPMENT OPERATION

- Conduct a risk assessment according to EN ISO 12100 and all other standards that apply to your application.
- Use redundant components and/or control paths for all critical control functions identified in your risk assessment.
- If moving loads can result in hazards, for example, slipping or falling loads, operate the drive in closed loop mode.
- Verify that the service life of all individual components used in your application is sufficient for the intended service life of your overall application.
- Perform extensive commissioning tests for all potential error situations to verify the effectiveness of the safety-related functions and monitoring functions implemented, for example, but not limited to, speed monitoring by means of encoders, short circuit monitoring for all connected equipment, correct operation of brakes and guards.
- Perform extensive commissioning tests for all potential error situations to verify that the load can be brought to a safe stop under all conditions.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Drive systems may perform unexpected movements because of incorrect wiring, incorrect settings, incorrect data or other errors.

A WARNING

UNANTICIPATED EQUIPMENT OPERATION

- Carefully install the wiring in accordance with the EMC requirements.
- Do not operate the product with unknown or unsuitable settings or data.
- Perform a comprehensive commissioning test.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

WARNING

LOSS OF CONTROL

- The designer of any control scheme must consider the potential failure modes of control paths and, for critical control functions, provide a means to achieve a safe state during and after a path failure. Examples of critical control functions are emergency stop, overtravel stop, power outage and restart.
- Separate or redundant control paths must be provided for critical control functions.
- System control paths may include communication links. Consideration must be given to the implications of unanticipated transmission delays or failures of the link.
- Observe all accident prevention regulations and local safety guidelines (1).
- Each implementation of the product must be individually and thoroughly tested for proper operation before being placed into service.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

(1) For USA: Additional information, refer to NEMA ICS 1.1 (latest edition), Safety Guidelines for the Application, Installation, and Maintenance of Solid State Control and to NEMA ICS 7.1 (latest edition), Safety Standards for Construction and Guide for Selection, Installation and Operation of Adjustable-Speed Drive Systems.

The temperature of the products described in this manual may exceed 80 °C (176 °F) during operation.



HOT SURFACES

- Ensure that any contact with hot surfaces is avoided.
- Do not allow flammable or heat-sensitive parts in the immediate vicinity of hot surfaces.
- Verify that the product has sufficiently cooled down before handling it.
- Verify that the heat dissipation is sufficient by performing a test run under maximum load conditions.


Failure to follow these instructions can result in death, serious injury, or equipment damage.

NOTICE

DESTRUCTION DUE TO INCORRECT MAINS VOLTAGE

Before switching on and configuring the product, verify that it is approved for the mains voltage.

Failure to follow these instructions can result in equipment damage.



About the Book



At a Glance

Document Scope

The purpose of this document is:

- to give you mechanical and electrical information related to the Altivar Process drive,
- to show you how to install and wire this drive.

Validity Note

Original instructions and information given in the present document have been written in English (before optional translation).

NOTE: The products listed in the document are not all available at the time of publication of this document online. The data, illustrations and product specifications listed in the guide will be completed and updated as the product availabilities evolve. Updates to the guide will be available for download once products are released on the market.

This documentation is valid for the Altivar Process drive.

The technical characteristics of the devices described in the present document also appear online. To access the information online:

Step	Action
1	Go to the Schneider Electric home page <u>www.schneider-electric.com</u> .
2	In the Search box type the reference of a product or the name of a product range. • Do not include blank spaces in the reference or product range. • To get information on grouping similar modules, use asterisks (*).
3	If you entered a reference, go to the Product Datasheets search results and click on the reference that interests you. If you entered the name of a product range, go to the Product Ranges search results and click on the product range that interests you.
4	If more than one reference appears in the Products search results, click on the reference that interests you.
5	Depending on the size of your screen, you may need to scroll down to see the datasheet.
6	To save or print a datasheet as a .pdf file, click Download XXX product datasheet .

The characteristics that are described in the present document should be the same as those characteristics that appear online. In line with our policy of constant improvement, we may revise content over time to improve clarity and accuracy. If you see a difference between the document and online information, use the online information as your reference.

Related Documents

Use your tablet or your PC to quickly access detailed and comprehensive information on all our products on www.schneider-electric.com.

The internet site provides the information you need for products and solutions:

- The whole catalog for detailed characteristics and selection guides,
- The CAD files to help design your installation, available in over 20 different file formats,
- All software and firmware to maintain your installation up to date,
- A large quantity of White Papers, Environment documents, Application solutions, Specifications... to gain a better understanding of our electrical systems and equipment or automation,

• And finally all the User Guides related to your drive, listed below:

Title of Documentation	Catalog Number
Digital Catalog for Industrial Automation	<u>Digit-Cat</u>
Catalog: Altivar Process ATV600 variable speed drives	<u>DIA2ED2140502EN</u> (English), <u>DIA2ED2140502FR</u> (French)
ATV600 Getting Started	<u>EAV63253</u> (English), <u>EAV63254</u> (French), <u>EAV63255</u> (German), <u>EAV63256</u> (Spanish), <u>EAV63257</u> (Italian), <u>EAV64298</u> (Chinese), <u>EAV63253PT</u> (Portuguese), <u>EAV63253TR</u> (Turkish)
ATV600 Getting Started Annex (SCCR)	<u>EAV64300</u> (English)
ATV630, ATV650 Installation Manual	
ATV600 Programming Manual	<u>EAV64318</u> (English), <u>EAV64320</u> (French), <u>EAV64321</u> (German), <u>EAV64322</u> (Spanish), <u>EAV64323</u> (Italian), <u>EAV64324</u> (Chinese), <u>EAV64318PT</u> (Portuguese), <u>EAV64318TR</u> (Turkish)
ATV600 Modbus Serial Link Manual (Embedded)	<u>EAV64325</u> (English)
ATV600 Ethernet Manual (Embedded)	<u>EAV64327</u> (English)
ATV600 Ethernet IP - Modbus TCP Manual (VW3A3720, 721)	<u>EAV64328</u> (English)
ATV600 BACnet MS/TP Manual (VW3A3725)	<u>QGH66984</u> (English)
ATV600 PROFIBUS DP manual (VW3A3607)	<u>EAV64329</u> (English)
ATV600 DeviceNet manual (VW3A3609)	<u>EAV64330</u> (English)
ATV600 PROFINET manual (VW3A3627)	<u>EAV64331</u> (English)
ATV600 CANopen Manual (VW3A3608, 618, 628)	<u>EAV64333</u> (English)
ATV600 POWERLINK manual (VW3A3619)	<u>PHA99690</u> (English)
ATV600 Communication Parameters	<u>EAV64332</u> (English)
ATV600 Embedded Safety Function manual	<u>EAV64334</u> (English)
Altivar Process Drive Systems Installation manual (ATV660, ATV680, ATV960, ATV980)	<u>NHA37119</u> (English), <u>NHA37121</u> (French), <u>NHA37118</u> (German), <u>NHA37122</u> (Spanish), <u>NHA37123</u> (Italian), <u>NHA37130</u> (Chinese), <u>NHA37124</u> (Dutch), <u>NHA37126</u> (Polish), <u>NHA37127</u> (Portuguese), <u>NHA37129</u> (Turkish)
ATV660 Handbook	<u>NHA37111</u> (English), <u>NHA37110</u> (German)
ATV680 Handbook	<u>NHA37113</u> (English), <u>NHA37112</u> (German)
ATV600F, ATV900F Installation Instruction sheet	<u>NVE57369</u> (English)
ATV600, ATV900 ATEX manual	<u>NVE42416</u> (English)
SoMove: FDT	SoMove FDT (English, French, German, Spanish, Italian, Chinese)
ATV600: DTM	ATV6xx DTM Library EN (English - to be installed first), ATV6xx DTM Lang FR (French), ATV6xx DTM Lang DE (German), ATV6xx DTM Lang SP (Spanish), ATV6xx DTM Lang IT (Italian), ATV6xx DTM Lang CN (Chinese)
ATV61-71 to ATV600-900 Migration Manual	<u>EAV64336</u> (English)
Application Note: ATV600 Multi- Drives Booster Control Optimized	<u>QGH36060</u> (English)
Application Note: ATV600 Multi- Masters Booster Control Pressure Feedback with Service Continuity	<u>QGH36061</u> (English)

Title of Documentation	Catalog Number
Application Note: ATV600 Multi- Drives Standard Level Control	QGH36059 (English)
Application Note: ATV600 Multi- Masters with Optimized Level Control	<u>EAV64367</u> (English)
Recommended Cybersecurity Best Practices	<u>CS-Best-Practices-2019-340</u> (English)

You can download these technical publications and other technical information from our website at www.schneider-electric.com/en/download

Electronic Product Data sheet

Scan the QR code in front of the drive to get the product data sheet.

Terminology

The technical terms, terminology, and the corresponding descriptions in this manual normally use the terms or definitions in the relevant standards.

In the area of drive systems this includes, but is not limited to, terms such as error, error message, failure, fault, fault reset, protection, safe state, safety function, warning, warning message, and so on.

Among others, these standards include:

- IEC 61800 series: Adjustable speed electrical power drive systems
- IEC 61508 Ed.2 series: Functional safety of electrical/electronic/programmable electronic safety-related
- EN 954-1 Safety of machinery safety-related parts of control systems
- ISO 13849-1 & 2 Safety of machinery safety related parts of control systems
- IEC 61158 series: Industrial communication networks Fieldbus specifications
- IEC 61784 series: Industrial communication networks Profiles
- IEC 60204-1: Safety of machinery Electrical equipment of machines Part 1: General requirements

In addition, the term zone of operation is used in conjunction with the description of specific hazards, and is defined as it is for a hazard zone or danger zone in the EC Machinery Directive (2006/42/EC) and in ISO 12100-1.

Also see the glossary at the end of this manual.


Contact Us

Select your country on:

www.schneider-electric.com/contact

Schneider Electric Industries SAS

Head Office 35, rue Joseph Monier 92500 Rueil-Malmaison France



Chapter 1 Introduction

What Is in This Chapter?

This chapter contains the following topics:

Торіс	Page
Verifying the Absence of Voltage	14
ATV61/ATV71 to ATV600/ATV900 Migration	15
Drive Overview	16
Accessories and Options	28
Green Premium™	29
Steps for setting up the drive	30
Preliminary Instructions	31



Verifying the Absence of Voltage

Instructions

The DC bus voltage level is determined by measuring the voltage between the DC bus terminals PA/+ and PC/-.

The location of the DC bus terminals depends on the drive model.

Identify your drive model by referring to the nameplate of the drive. Then, refer to the chapter "Wiring the Power Part" (see page 149) for the location of the DC bus terminals PA/+ and PC/-.

A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

- Only appropriately trained persons who are familiar with and understand the contents of this manual
 and all other pertinent product documentation and who have received safety training to recognize and
 avoid hazards involved are authorized to work on and with this drive system. Installation, adjustment,
 repair and maintenance must be performed by qualified personnel.
- The system integrator is responsible for compliance with all local and national electrical code requirements as well as all other applicable regulations with respect to grounding of all equipment.
- Many components of the product, including the printed circuit boards, operate with mains voltage.
- Only use properly rated, electrically insulated tools and measuring equipment.
- Do not touch unshielded components or terminals with voltage present.
- Motors can generate voltage when the shaft is rotated. Prior to performing any type of work on the drive system, block the motor shaft to prevent rotation.
- AC voltage can couple voltage to unused conductors in the motor cable. Insulate both ends of unused conductors of the motor cable.
- Do not short across the DC bus terminals or the DC bus capacitors or the braking resistor terminals.
- Before performing work on the drive system:
 - Disconnect all power, including external control power that may be present. Take into account that
 the circuit breaker or main switch does not de-energize all circuits.
 - O Place a **Do Not Turn On** label on all power switches related to the drive system.
 - O Lock all power switches in the open position.
 - O Wait 15 minutes to allow the DC bus capacitors to discharge.
 - Follow the instructions given in the chapter "Verifying the Absence of Voltage" in the installation manual of the product.
- Before applying voltage to the drive system:
 - O Verify that the work has been completed and that the entire installation cannot cause hazards.
 - If the mains input terminals and the motor output terminals have been grounded and short-circuited, remove the ground and the short circuits on the mains input terminals and the motor output terminals.
 - O Verify proper grounding of all equipment.
 - O Verify that all protective equipment such as covers, doors, grids is installed and/or closed.

Failure to follow these instructions will result in death or serious injury.

Procedure

Perform the following actions to verify the absence of voltage

Step	Action	
1	Measure the voltage on the DC bus between the DC bus terminals (PA/+ and PC/-) using a properly rated voltmeter to verify that the voltage is less than 42 Vdc	
2	If the DC bus capacitors do not discharge properly, contact your local Schneider Electric representative. Do not repair or operate the product.	
3	Verify that no other voltage is present in the drive system.	

ATV61/ATV71 to ATV600/ATV900 Migration

Download the Manual

The ATV61-71 to ATV600-900 Migration Manual is now available *EAV64336 (English)*. It provides information about:

- migration from ATV61 to ATV630 or ATV650,
- migration from ATV71 to ATV930 or ATV950.

This information ranges from product selection according to the existing installation, technical differences between the product ranges, product frame size, wiring information or available options.

Drive Overview

Frame Sizes for IP20/IP21 Products - Wall Mounting

10 frame sizes for IP21 products.

Frame size 1	Frame size 2
 3-phase 200240 V, 0.754 kW, 15 HP 3-phase 380480 V, 0.755.5 kW, 17 ^{1/2} HP 	 3-phase 200240 V, 5.5 kW, 7 ^{1/2} HP 3-phase 380480 V, 7.511 kW, 1015 HP 3-phase 600 V, 320 HP
Althor Process Stagether Stageth	Advant Reaction Scignedistr
ATV630U07M3U40M3, ATV630U07N4U55N4	ATV630U55M3, ATV630U75N4, ATV630D11N4, ATV630U22S6XATV630D15S6X



Frame size 4	Frame size 5
 3-phase 200240 V 1522 kW, 2030 HP 3-phase 380480 V, 3045 kW, 4060 HP 	 3-phase 200240 V, 3045 kW, 4060 HP 3-phase 380480 V, 5590 kW, 75125 HP
Scignoder Scignoder	Schreider.
ATV630D15M3ATV630D22M3, ATV630D30N4ATV630D45N4	ATV630D30M3D45M3, ATV630D55N4D90N4

Codite Minatali.

	Frame size 6 (*)
9 3-phase 600 V, 40100 HP	• 3-phase 200240 V, 5575 kW, 75100 HP • 3-phase 380480 V, 110160 kW, 150250 HP
	A Marie Control of the Control of th
	(*) The picture shows a product equipped with the VW3A9704 optional metal conduit box.
ATV630D30S6D75S6	ATV630D55M3, ATV630D75M3, ATV630C11N4C16N4



Products intended to Cabinet Integration


3 frame sizes of IP20 products





2 frame sizes IP20 on upper part and IP00 on lower part

Frame size 4	Frame size 5
3-phase 380480 V, 3045 kW, 4060 HP	• 3-phase 380480 V, 5590 kW, 75125 HP



2 frame sizes for IP00 products.



Frame Sizes for IP55 Products - Wall Mounting

3 frame sizes for IP55 products, with or without integrated disconnect switch.



disconnect switch.

Frame size B	Frame size C
3-phase 380480 V, 3045 kW, 4060 HP, with or without Vario disconnect switch	3-phase 380480 V, 5590 kW, 75125 HP, with or without Vario disconnect switch
Without valid disconnect switch	Without Valio disconnect switch
ATV650D30N4(E)D45N4(E)	ATV650D55N4(E)D90N4(E)
(E) The suffix E indicates a product including a Vario disco	

Codite Ministration Collins

Frame Sizes for IP21 Products - Floor Standing

2 frame sizes for IP21 products.




Frame Sizes for IP54 Products - Floor Standing

2 frame sizes for IP54 products.



ATV600 Catalog Number Description




NOTE: see the catalog for possible combinations.

colie dia colie di co

26

Nameplate example

The nameplate contains the following data:



- 1 Product type 2 Catalog number 3 Power rating
- 4 Firmware version 5 Power part supply
- (6) Fuses and overload protection information (7) Power part cable information
- (8) Degree of protection (9) Certifications (10) Serial number

Accessories and Options

Introduction

Altivar Process drives are designed to take numerous accessories and options to increase their functionality. For a detailed description and catalog numbers, refer to the Catalog on schneider-electric.com.

All accessories and options come with an instruction sheet to help installation and commissioning. Therefore you will only find here a short product description.

Accessories

Drive

- Fan replacement kit
- External braking resistors

Graphic display terminal

- Remote mounting kit for mounting on enclosure door
- Multidrop connection accessories for connecting several drives to the RJ45 terminal port

Drive mounting kits

• Flange-mounting kit (see page 99) for separate air flow

EMC Plates for IP20 drives of frame sizes 1...5

• These EMC plates are intended to be mounted on IP20 drives for cabinet integration (see page 19). Refer to the dedicated instruction sheet <u>PHA93871</u>.

IP upgrade

 Metal conduit box for frame sizes 6, 7A, 7B, 3Y and 5Y product for IP21 degree of protection on bottom side



Modbus Communication tools

- Wifi dongle
- Bluetooth dongle
- USB to Modbus adapter

Options

I/O extension modules

- Digital and analog I/O module
- · Relay output module

Communication modules

- EtherNet/IP and Modbus TCP dual port
- CANopen daisy chain
- CANopen SUB-D
- CANopen screw terminal block
- PROFINET
- PROFIBUS DP V1
- DeviceNet
- BACnet MS/TP

Filters

Passive filters

EMC input filters

Output filters

- dv/dt filters
- Sinus filters
- Common mode filters for frame sizes 1...6

Green Premium™

Description

Information on the environmental impact of products, their resource efficiency, and end-of-life instructions.


Easy access to information: "Check Your Product"

Certificates and relevant product information available at the address:

www.schneider-electric.com/green-premium

You can download RoHS and REACh compliance declarations, Product Environmental Profiles (PEP) and End-of-Life instructions (EoLi).





Steps for setting up the drive

Procedure

INSTALLATION



Receive and inspect the drive controller

- □ Check that the catalog number printed on the label is the same as that on the purchase order
- □ Remove the drive from its packaging and check that it has not been damaged



Verify the supply mains

□ Verify that the supply mains is compatible with the power part supply range of the drive.



Mount the drive

- Mount the drive in accordance with the instructions in this document
- ☐ Install the transformer(s), if any
- □ Install any internal and external options



- □ Connect the motor, ensuring that its connections correspond to the voltage
- □ Connect the supply mains, after making sure that the power is off
- □ Connect the control

Wire the drive



Steps 1 to 4 must

be performed with

the power off.

PROGRAMMING

Refer to the Programming

30

Preliminary Instructions

Inspecting the product

Damaged products or accessories may cause electric shock or unanticipated equipment operation.

🛕 🛕 DANGER

ELECTRIC SHOCK OR UNANTICIPATED EQUIPMENT OPERATION

Do not use damaged products or accessories.

Failure to follow these instructions will result in death or serious injury.

Contact your local Schneider Electric sales office if you detect any damage whatsoever.

Step	Action
1	Verify that the catalog number printed on the nameplate (see page 27) corresponds to the purchase order.
2	Before performing any installation work, inspect the product for visible damage.

Handling

▲ WARNING

INCORRECT HANDLING

- Follow all handling instructions provided in this manual and in all associated product documentation.
- Handle and store the product in its original packaging.
- Do not handle and store the product if the packaging is damaged or appears to be damaged.
- Take all measures required to avoid damage to the product and other hazards when handling or opening the packaging.


Failure to follow these instructions can result in death, serious injury, or equipment damage.

To help protect the drive before installation, handle and store the device in its packaging. Ensurethat the ambient conditions are acceptable.

Handling the Wall Mounting Drives Up to Frame Size 6


Altivar Process drives of frame size A, and frame sizes 1 up to 3 can be removed from their packaging and installed without a handling device.

Higher frame size drives require a handling device. All drives have either lifting eyes or lifting lugs for handling.



Unpacking the Frame Size 7A and 7B Drives

The drive and the DC choke(s) are mounted on a pallet with screws.




Removing the DC Chokes of Frame Size 7A and 7B Drives from the Pallet

A CAUTION

SHARP EDGES

Use all necessary personal protective equipment (PPE) such as gloves when removing the components from the pallet.

Failure to follow these instructions can result in injury or equipment damage.



Procedure:

Step	Action	
1	Remove the screws as shown in the illustration	
2	Remove the DC choke(s) by means of a hoist	
3	Remove the fixing screws from the DC choke housing	
4	Remove the DC choke housing from the pallet	

Keep all parts and components for the mounting procedure (see page 122).


Hoisting the Frame Size 7A and 7B Drives

A WARNING

TOPPLING, SWINGING, OR FALLING EQUIPMENT

- Take all measures necessary to keep the equipment from swinging, toppling and falling.
- Follow the instructions provided to remove the equipment from the packaging and to mount it at its final position.

Failure to follow these instructions can result in death, serious injury, or equipment damage.



Procedure:

Step	Action	
1	Remove the screws holding the drive on the pallet	
2	Lift the drive by means of a hoist. Use the handling lugs of the drive to fasten the lifting equipment	
3	Keep the drive suspended by means of appropriate equipment until it is securely fastened in the fin installation position	
4	Move the drive to the final installation position on a wall or the back of the enclosure in accordance with the instructions given in this document (see page 98)	

Handling and Hoisting the Floor Standing Drives

A WARNING

TOPPLING

- Take into account the high center of gravity when handling the equipment.
- Verify that the ambient conditions for storage and transportation specified in this manual are respected.
- Only transport the equipment on the pallet using a suitable forklift.
- Do not remove the straps and the screws on the pallet before the equipment has been transported to the final installation position.

Failure to follow these instructions can result in death, serious injury, or equipment damage.


NOTE: Handling, hoisting and installation of the floor standing drives are described in the dedicated instruction sheet <u>NVE57369</u> delivered with these drives and available on <u>schneider-electric.com</u>.

Chapter 2 Technical Data

What Is in This Chapter?

This chapter contains the following sections:

Section	Topic	Page
2.1	Environment Data	36
2.2	Mechanical Data	39
2.3	Electrical Data - Drive Ratings	69
2.4	Electrical Data - Upstream Protective Device	84



Section 2.1 **Environment Data**

What Is in This Section?

This section contains the following topics:

Topic	Page
Temperature Conditions	
Altitude Conditions	
Chemical and Mechanical Conditions	38



Temperature Conditions

Climatic Environmental Conditions for Transportation and Storage

The environment during transportation and storage must be dry and free from dust.

Storage Temperature	All drives other than frame sizes 7, and floor standing	°C	-4070
	products	°F	-40158
	Frame sizes 7, and floor standing drives	°C	-2570
		°F	-13158
Transportation Temperature	All drives other than frame sizes 7, and floor standing	°C	-4070
	products	°F	-40158
	Frame sizes 7, and Floor standing drives	°C	-2570
		°F	-13158
Relative humidity		%	595

Climatic Environmental Conditions for Operation

The maximum permissible ambient temperature during operation depends on the mounting distances between the devices and on the required power. Observe the pertinent instructions in the chapter Drive Mounting (see page 97).

Frame sizes 13, 3S, 3Y, 4,	Temperature without derating	°C	-1550
5, 5S, 5Y and 6 Wall mounting drives and		°F	5122
Cabinet mounting drives	Temperature with derating of output power (1)	°C	Up to 60
· ·		°F	Up to 140
Frame sizes 7A and 7B	Temperature without derating	°C	-1040
Wall mounting drives		°F	14104
	Temperature with derating of output power (1)	°C	Up to 60
		°F	Up to 140
Frame sizes AC	Temperature without derating	°C	-1540
Wall mounting drives		°F	5104
	Temperature with derating of output power (1)	°C	Up to 50
		°F	Up to 122
All frame sizes	Temperature without derating	°C	040
Floor standing drives		°F	32104
	Temperature with derating of output power (1)	°C	Up to 50
		°F	Up to 122
All products	Relative humidity without condensing	%	595
1) Refer to Derating Curv	es section <i>(see page 107)</i> .		7. CO.
1) Refer to Derating Curv	es section (see page 107).		

Altitude Conditions

Operating Altitude

All frame sizes, except frame size 7

Altitude	Supply voltage (1)	Supply Ele	ectrical Net	work	Derating
		TT/TN	IT	Corner- Grounded	
Up to 1000 m (3300 ft)	200240 V	1	1	1	0
	380480 V (2)	1	1	✓	0
	600 V	1	1	_	0
	500690 V	1	1	_	0
10002000 m (33006600 ft)	200240 V	1	1	1	1
	380480 V (2)	1	1	1	1
	600 V	1	1	_	1
	500690 V	1	1	_	1
20003800 m (660012400 ft)	200240 V	1	1	1	1
	380480 V (2)	1	1	_	1
	600 V	1	1	_	1
	500690 V	-	_	_	-
38004800 m (1240015700 ft)	200240 V	1	1	1	1
	380480 V (2)	1	_	_	1
	600 V	1	-	_	1
	500690 V	_	_	_	_

⁽¹⁾ Tolerance: -15...+10%

Legend:

- ✓: Derate the nominal current of the drive by 1% for each additional 100 m.
- o: Without derating
- -: Not applicable

Frame Size 7

Altitude	Supply voltage (1)	Supply Electi	ical Network		Derating
		TT/TN	IT	Corner- Grounded	
Up to 1000 m (3300 ft)	380480 V	1	1	✓	0
10002000 m (33006600 ft)	380480 V	1	1	✓	1
20003000 m (66009800 ft)	380480 V	✓	✓	-	1

⁽¹⁾ Tolerance: -15...+10%

Legend:

- ✓: Derate the nominal current of the drive by 1% for each additional 100 m.
- o: Without derating
- -: Not applicable

Chemical and Mechanical Conditions

Withstand to harsh environments, conforming to IEC/EN 60721-3-3

Drive	Chemical active substances	Mechanical active substances	Mechanical conditions
All, except frame size 7	class 3C3	class 3S3	class 3M3
Frame size 7	class 3C2	class 3S2	class 3M3

⁽²⁾ The voltage of floor standing drives ATV••0•••N4F is limited to 440 Vac.

Section 2.2 Mechanical Data


Dimensions and Weights

About the drawings


All drawings CAD files can be downloaded from www.schneider-electric.com

Frame Size 1

IP21 / UL Type 1 Drives - Front, Side and Rear View



IP20 Drives - Front, Side And Rear View



EAV64301 04/2020 39


Weights

Catalog Number	Weight in kg (lb)
ATV630U07N4ZU22N4Z	3.7 (8.2)
ATV630U30N4Z, ATV630U40N4Z	3.8 (8.4)
ATV630U55N4Z	3.9 (8.6)
ATV630U07M3, ATV630U15M3	4.3 (9.5)
ATV630U07N4U22N4, U22M3U30M3	4.5 (9.9)
ATV630U30N4, ATV630U40N4, ATV630U40M3	4.6 (10.1)
ATV630U55N4	4.7 (10.4)




Frame size 2

IP21 / UL Type 1 Drives - Front, Side and Rear View



IP20 Drives - Front, Side And Rear View




Weights

Catalog Number	Weight in kg (lb)
ATV630U75N4Z, ATV630D11N4Z	6.9 (15.2)
ATV630U75N4, ATV630D11N4 ATV630U55M3	7.7 (17)
ATV630U22S6XATV630D15S6X	5.5 (12.1)

EAV64301 04/2020 41

Frame size 3


IP21 / UL Type 1 Drives - Front, Side and Rear View



coilennaian.com

42

IP20 Drives - Front, Side And Rear View




Weights


Catalog Number	Weight in kg (lb)
ATV630D15N4Z	13 (28.7)
ATV630D18N4Z	13.6 (30)
ATV630D22N4Z	13.7 (30.2)
ATV630U75M3	13.8 (30.4)
ATV630D11M3	13.8 (30.4)
ATV630D15N4	13.6 (30)
ATV630D18N4	14.2 (31.3)
ATV630D22N4	14.3 (31.5)

Frame size 3S

IP20 / UL Type 1 Drives - Front, Side And Rear View









Weights


Weights	
Catalog Number	Weight in kg (lb)
ATV630D18S6 and ATV630D22S6	23 (50.7)

Frame size 3Y

IP20 on Upper Part and IP00 on Lower Part Drives - Front View With and Whitout EMC Plate, Side And Rear View










Weights

Catalog Number	Weight in kg (lb)	
ATV630U22Y6ATV630D30Y6	22 (48.5)	


EAV64301 04/2020 45

Frame size 4

IP21 / UL Type 1 Drives - Front, Side and Rear View



IP20 Drives, except on Lower Part (IP00) - Front, Side And Rear View




Weights

Catalog Number	Weight in kg (lb)
ATV630D30N4Z	25.8 (56.9)
ATV630D37N4Z	26 (57.3)
ATV630D45N4Z	26.5 (58.4)
ATV630D15M3D22M3	27.3 (60.2)
ATV630D30N4	28 (61.7)
ATV630D37N4	28.2 (62.2)
ATV630D45N4	28.7 (63.3)


Frame size 5

IP21 / UL Type 1 Drives - Front, Side and Rear View



EAV64301 04/2020 47

IP20 Drives, except on Lower Part (IP00) - Front, Side And Rear View




Weights


Catalog Number	Weight in kg (lb)	
ATV630D55N4Z	52.6 (116)	
ATV630D75N4Z	54.1 (119.3)	
ATV630D90N4Z	54.6 (120.4)	
ATV630D30M3D45M3	56.6 (124.8)	
ATV630D55N4	56.5 (124.6)	
ATV630D75N4	58 (127.9)	
ATV630D90N4	58.5 (129)	
		COULT.
	collen	
	codiled	EAV64301 04/2020

48

Frame size 5S

IP20 / UL Type 1 Drives - Front , Side And Rear View







Weights


23.82	
Weights	
Catalog Number	Weight in kg (lb)
ATV630D30S6ATV630D75S6	55 (121.3)

Frame size 5Y

IP20 on Upper Part and IP00 on Lower Part Drives - Front View with and Without EMC Plate, Side and Rear View








Weights

Catalog Number	Weight in kg (lb)	
ATV630D37Y6ATV630D90Y6	53 (116.8)	

Frame size 6

IP20 on Upper Part and IP00 on Lower Part Drives - Rear and Side View With Top Cover




mm in.


IP20 Drives - Front and Rear View With Top Cover and Conduit Box

 $\frac{\text{mm}}{\text{in.}}$ 1158.8 45.62 0 323.5

52

IP21 on Upper Part and IP00 on Lower Part / UL Type 1 Drives - Side and Front View






coinentain.com

 $\underline{\mathsf{mm}}$

IP21 / UL Type 1 Drives - Front, Rear and Side View

in.



NOTE: Lower Conduit Box part sold separately. This part enables wall mounting of the product. It provides IP21 protection degree on the bottom side and UL type 1 protection degree.





Weights


Catalog Number Weight in kg (lb) ATV630C11N4ATV630C16N4 82 (181) ATV630D55M3, ATV630D75M3 80 (176)	7.28 364 14.33 370 14.57 373.93 14.72	
ATV630C11N4ATV630C16N4 82 (181) ATV630D55M3, ATV630D75M3 80 (176)		
ATV630D55M3, ATV630D75M3 80 (176)		
55		55

Frame Size 7A

IP20 on Upper Part and IP00 on Lower Part Drives - Side, Front and rear View







odiennaian.com


NOTE: Lower Conduit Box part sold separately. This part enables wall mounting of the product. It provides IP21 protection degree on the bottom side and UL type 1 protection degree.


Weights


Catalog Number	Weight in kg (lb)		
ATV630C22N4	172 <i>(379)</i>		

Frame Size 7B

IP20 on Upper Part and IP00 on Lower Part Drives - Side, Front and Rear View







NOTE: Lower Conduit Box part sold separately. This part enables wall mounting of the product. It provides IP21 protection degree on the bottom side and UL type 1 protection degree.

Weights


Catalog Number	Weight in kg (lb)		
ATV630C25N4, ATV630C31N4	203 (448)		



58

Frame Size A

IP55 / UL Type 1 Drives Without Load Switch - Front and Side View



ATV650U07N4, U15N4, U22N4, U30N4, U40N4, U55N4: a = 272 mm (10.7 in.) ATV650U75N4, D11N4, D15N4, D18N4, D22N4: a = 299 mm (11.8 in.)

 $\frac{\text{mm}}{\text{in.}}$ $\underline{\mathsf{mm}}$ 15 0.59 233 in. 9.17 205 8.07 2 x Ø6 2 x Ø0.24 298.2 11.7 675.5 26.59 661 26.02 678 26.7 728.4


IP55 / UL Type 1 Drives With Load Switch - Front and Side View

ATV650U07N4E, U15N4E, U22N4E, U30N4E, U40N4E, U55N4E: a = 300 mm (11.8 in.) ATV650U75N4E, D11N4E, D15N4E, D18N4E, D22N4E: a = 330 mm (13 in.) Weights


Catalog Number	Weight in kg (lb)	
ATV650U07N4•ATV650U22N4•	10.5 (23.1)	
ATV650U30N4•, ATV650U40N4•	10.6 (23.4)	
ATV650U55N4•	10.7 (23.6)	
ATV650U75N4•, ATV650D11N4•	13.7 (30.2)	
ATV650D15N4•	19.6 (43.2)	
ATV650D18N4•, ATV650D22N4•	20.6 (45.4)	
	Cogitestr	

Frame Size B

IP55 / UL Type 1 Drives Without Load Switch - Front and Side View



IP55 / UL Type 1 Drives With Load Switch - Front and Side View




Weights

atalog Number	Weight in kg (lb)
TV650D30N4ATV650D45N4	50 (110.2)
TV650D30N4EATV650D45N4E	52 (114.6)
	Codileally


62

Frame Size C

IP55 / UL Type 1 Drives Without Load Switch - Front and Side View



IP55 / UL Type 1 Drives With Load Switch - Front and Side View




Weights

Catalog Number	Weight in kg (lb)	
ATV650D55N4ATV650D75N4	87 (191.8)	
ATV650D55N4EATV650D75N4E	89.3 (196.9)	
ATV650D90N4	87.7 (193.3)	
ATV650D90N4E	90 (198.4)	


Floor Standing - Frame Size FS1 and FSA

IP 21 Drives - Side and Front View



Colitennaian. Com

IP 54 Drives - Side and Front View




Weights


Catalog Number	Weight in kg (lb)
ATV630C11N4FATV630C16N4F	300 (661.4)
ATV650C11N4FATV650C16N4F	310 (683.4)

Floor Standing - Frame Size FS2 and FSB

IP 21 Drives - Side and Front View



IP 54 Drives - Side and Front View



Weights

Catalog Number	Weight in kg (lb)
ATV630C20N4FATV630C31N4F	400 (882)
ATV650C20N4FATV650C31N4F	420 (926)

Section 2.3 **Electrical Data - Drive Ratings**

What Is in This Section?

This section contains the following topics:

Topic	Page
Drive Ratings In Normal Duty	70
Drive Ratings In Heavy Duty	77



Drive Ratings In Normal Duty

Normal Duty

Normal duty values are given for applications requiring a slight overload (up to 110 %).

NOTE:

- For fuse and circuit-breaker ratings refer to the information provided in the Altivar Process 600 Getting Started Annex (SCCR), catalog number <u>NHA64300</u> for UL/CSA compliance and also in the catalog (see page 9) for IEC compliance.
- For motor overload and drive thermal monitoring functions, refer to the ATV600 Programming manual (see page 9).

IP20 on Upper Part, IP00 on Lower Part Products and IP21 / UL Type 1 Products 3-Phase Power Part Supply 200...240 Vac 50/60 Hz

Power and Current Ratings

Catalog Number and		Nominal Power		Power Part Supply				Drive (output)	
Frame Size [•]		(1)		Max. Input Current		Apparent	Max.	Nominal	Max.
				At 200 Vac	At 240 Vac	Power	Inrush Current (2)	Current (1)	Transient current (1) (3)
		kW	HP	Α	Α	kVA	Α	Α	Α
ATV630U07M3	[1]	0.75	1	3	2.6	1.1	4.3	4.6	5.1
ATV630U15M3	[1]	1.5	2	5.9	5	2.1	4.3	8	8.8
ATV630U22M3	[1]	2.2	3	8.4	7.2	3.0	4.3	11.2	12.3
ATV630U30M3	[1]	3	-	11.5	9.9	4.1	17.5	13.7	15.1
ATV630U40M3	[1]	4	5	15.1	12.9	5.4	17.6	18.7	20.6
ATV630U55M3	[2]	5.5	7 1/2	20.2	17.1	7.1	30.9	25.4	27.9
ATV630U75M3	[3]	7.5	10	27.1	22.6	9.4	39.3	32.7	36.0
ATV630D11M3	[3]	11	15	39.3	32.9	13.7	39.3	46.8	51.5
ATV630D15M3	[4]	15	20	52.6	45.5	18.9	64.6	63.4	69.7
ATV630D18M3	[4]	18.5	25	66.7	54.5	22.7	71.3	78.4	86.2
ATV630D22M3	[4]	22	30	76	64.3	26.7	70.9	92.6	101.9
ATV630D30M3	[5]	30	40	104.7	88.6	36.8	133.3	123	135.3
ATV630D37M3	[5]	37	50	128	107.8	44.8	133.3	149	163.9
ATV630D45M3	[5]	45	60	155.1	130.4	54.2	175	176	193.6
ATV630D55M3	[6]	55	75	189	161	61.1	168.2	211	232.1
ATV630D75M3	[6]	75	100	256	215	83.7	168.2	282	310.2

- (1) The switching frequency is adjustable:
 - O From 2...12 kHz for drive frame sizes 1 to 4, rated value: 4 kHz
 - O From 1...8 kHz for drive frame sizes 5 and 6, rated value: 2.5 kHz

For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.

- (2) Peak current when power is switched On, for the maximum supply mains voltage.
- (3) The drive is designed to run up to 60 s at 110% of nominal current.

IP20 on Upper Part, IP00 on Lower Part Products and IP21 / UL Type 1 Products 3-Phase Power Part Supply 380...480 Vac 50/60 Hz

Power And Current Ratings

Catalog Number (4) and Frame Size [•]		Nominal Power (1)		Power Part Supply				Drive (output)	
				Max. Input Current		Apparent	Max.	Nominal	Max.
				At 380 Vac	At 480 Vac	Power	Inrush Current (2)	Current (1)	Transient current (1) (3)
		kW	HP	Α	Α	kVA	Α	Α	Α
ATV630U07N4	[1]	0.75	1	1.5	1.3	1.1	8	2.2	2.4
ATV630U15N4	[1]	1.5	2	3	2.6	2.2	8.3	4	4.4
ATV630U22N4	[1]	2.2	3	4.3	3.8	3.2	8.4	5.6	6.2
ATV630U30N4	[1]	3	-	5.8	5.1	4.2	31.5	7.2	7.9
ATV630U40N4	[1]	4	5	7.6	6.7	5.6	32.2	9.3	10.2
ATV630U55N4	[1]	5.5	7 1/2	10.4	9.1	7.6	33.2	12.7	14
ATV630U75N4	[2]	7.5	10	13.8	11.9	9.9	39.9	16.5	18.2
ATV630D11N4	[2]	11	15	19.8	17	14.1	40.4	23.5	25.9
ATV630D15N4	[3]	15	20	27	23.3	19.4	74.5	31.7	34.9
ATV630D18N4	[3]	18.5	25	33.4	28.9	24	75.5	39.2	43.1
ATV630D22N4	[3]	22	30	39.6	34.4	28.6	76	46.3	50.9
ATV630D30N4	[4]	30	40	53.3	45.9	38.2	83	61.5	67.7
ATV630D37N4	[4]	37	50	66.2	57.3	47.6	92	74.5	82
ATV630D45N4	[4]	45	60	79.8	69.1	57.4	110	88	96.8
ATV630D55N4	[5]	55	75	97.2	84.2	70	176	106	116.6
ATV630D75N4	[5]	75	100	131.3	112.7	93.7	187	145	159.5
ATV630D90N4	[5]	90	125	156.2	135.8	112.9	236	173	190.3
ATV630C11N4	[6]	110	150	201	165	121.8	325	211	232
ATV630C13N4	[6]	132	200	237	213	161.4	325	250	275
ATV630C16N4	[6]	160	250	284	262	201.3	325	302	332
ATV630C22N4	[7A]	220	350	397	324	247	426	427	470
ATV630C25N4	[7B]	250	400	451	366	279	450	481	529
ATV630C31N4	[7B]	315	500	569	461	351	615	616	678

- (1) The switching frequency is adjustable:
 - O From 2...12 kHz for drive frame sizes 1 to 4, rated value: 4 kHz
 - O From 1...8 kHz for drive frame sizes 5 to 7, rated value: 2.5 kHz

For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.

- (2) Peak current when power is switched On, for the maximum supply mains voltage.
- (3) The drive is designed to run up to 60 s at 110% of nominal current.
- (4) Size 1...5 drives: Including catalog numbers ATV630 ••• N4Z...

IP20/IP21 / UL Type 1 Products 3-Phase Power Part Supply 600 Vac 50/60 Hz

NOTICE

OVERLOAD

Install properly rated line chokes upstream of drives ATV•30•••S6X.

Failure to follow these instructions can result in equipment damage.

Power And Current Ratings

Catalog Number and Frame Size [•]		Nominal Power	Power Part S	Supply	Drive (output)			
		(1)	Max. Input Line Current choke (Apparent Power	Max. Inrush Current (2)	Nominal Current (1)	Max. Transient
			At 600 Vac					current(1) (3)
		HP	Α	mH	kVA	Α	Α	Α
ATV630U22S6X	[2]	3	2.9	10	3.0	46	4.2	4.6
ATV630U40S6X	[2]	5	5.3	4	5.5	46	7.2	7.9
ATV630U55S6X	[2]	7 ^{1/2}	7	4	7.3	46	9.5	10.5
ATV630U75S6X	[2]	10	9.9	2	10.3	46	13.5	14.9
ATV630D11S6X	[2]	15	15.3	1	15.9	46	18	19.8
ATV630D15S6X	[2]	20	19.6	1	20.4	46	22	24.2
ATV630D18S6	[3S]	25	23.2	N/A	24.1	35	27	29.7
ATV630D22S6	[3S]	30	26.9	N/A	28.0	35	34	37.4
ATV630D30S6	[5S]	40	40.6	N/A	42.2	115	41.5	45.7
ATV630D37S6	[5S]	50	47.1	N/A	48.9	115	52	57.2
ATV630D45S6	[5S]	60	55.1	N/A	57.3	115	62	68.2
ATV630D55S6	[5S]	75	70.1	N/A	72.9	115	83	91.3
ATV630D75S6	[5S]	100	89.4	N/A	92.9	115	100	110.0

- (1) The switching frequency is adjustable:
 - O From 2...12 kHz for drive frame size 2, rated value: 4 kHz
 - O From 2...6 kHz for drive frame size 3S, rated value: 4 kHz
 - O From 1...4.9 kHz for drive frame size 5S, rated value: 2.5 kHz

For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.

- (2) Peak current when power is switched On, for the maximum supply mains voltage.
- (3) The drive is designed to run up to 60 s at 110% of nominal current.
- (4) ATV630 ••• S6X may only be used with a line choke.

72

IP20 on Upper Part, IP00 on Lower Part Products, 3-Phase Power Part Supply 500...690 Vac 50/60 Hz Power And Current Ratings At Minimum Supply Voltage

Catalog Number ar Size [•]	nd Frame	Nominal	Power (1)	Power Part Supply	Drive (output))
				Max. Input Current	Nominal Current (1)	Max. Transient current (1) (2)
		At 500 Vac		At 500 Vac		
		kW	HP	Α	Α	A
ATV630U22Y6	[3Y]	1.5	2	3.4	3.1	3.4
ATV630U30Y6	[3Y]	2.2	3	4.7	4.2	4.6
ATV630U40Y6	[3Y]	3	-	6.2	5.4	5.9
ATV630U55Y6	[3Y]	4	5	7.9	7.2	7.9
ATV630U75Y6	[3Y]	5.5	7 1/2	10.4	9.5	10.5
ATV630D11Y6	[3Y]	7.5	10	13.6	13.5	14.9
ATV630D15Y6	[3Y]	11	15	18.4	18	19.8
ATV630D18Y6	[3Y]	15	20	23.1	24	26.4
ATV630D22Y6	[3Y]	18.5	25	27.6	29	31.9
ATV630D30Y6	[3Y]	22	30	32.1	34	37.4
ATV630D37Y6	[5Y]	30	40	47.2	45	49.5
ATV630D45Y6	[5Y]	37	50	55.6	55	60.5
ATV630D55Y6	[5Y]	45	60	65.5	66	72.6
ATV630D75Y6	[5Y]	55	75	82.7	83	91.3
ATV630D90Y6	[5Y]	75	100	108.3	108	118.8

(1) The switching frequency is adjustable:

- O From 2...6 kHz for drive frame size 3Y, rated value: 4 kHz
- O From 1...4.9 kHz for drive frame size 5Y, rated value: 2.5 kHz

For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.

(2) The drive is designed to run up to 60 s at 110% of nominal current.



Power And Current Ratings At Maximum Supply Voltage

Catalog Number a	and	Nominal	Power (1)	Power Part S	Supply		Drive (output)	
Frame Size [•]				Max. Input Current	Apparent Power	Max. Inrush Current (2)	Nominal Current (1)	Max. Transient
		At 690 Vac		At 690 Vac	At 690 Vac	At 690 Vac		current (1) (3)
		kW	HP	Α	kVA	Α	Α	Α
ATV630U22Y6	[3Y]	2.2	3	3.6	4.3	35	3.1	3.4
ATV630U30Y6	[3Y]	3	-	4.8	5.7	35	4.2	4.6
ATV630U40Y6	[3Y]	4	5	6.1	7.3	35	5.4	5.9
ATV630U55Y6	[3Y]	5.5	71/2	8	9.6	35	7.2	7.9
ATV630U75Y6	[3Y]	7.5	10	10.5	12.5	35	9.5	10.5
ATV630D11Y6	[3Y]	11	15	14.7	17.6	35	13.5	14.9
ATV630D15Y6	[3Y]	15	20	19.2	22.9	35	18	19.8
ATV630D18Y6	[3Y]	18.5	25	23	27.5	35	24	26.4
ATV630D22Y6	[3Y]	22	30	26	31.1	35	29	31.9
ATV630D30Y6	[3Y]	30	40	32.8	39.2	35	34	37.4
ATV630D37Y6	[5Y]	37	50	46.2	55.2	115	45	49.5
ATV630D45Y6	[5Y]	45	60	54.4	65.0	115	55	60.5
ATV630D55Y6	[5Y]	55	75	62.5	74.7	115	66	72.6
ATV630D75Y6	[5Y]	75	100	87.7	104.8	115	83	91.3
ATV630D90Y6	[5Y]	90	125	99.4	118.8	115	108	118.8

- (1) The switching frequency is adjustable:
 - O From 2...6 kHz for drive frame size 3Y, rated value: 4 kHz
 - O From 1...4.9 kHz for drive frame size 5Y, rated value: 2.5 kHz

For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.

- (2) Peak current when power is switched On, for the maximum supply mains voltage.
- (3) The drive is designed to run up to 60 s at 110% of nominal current.

IP21 Products 3-Phase Power Part Supply 380...440 Vac 50/60 Hz - Floor standing

Power And Current Ratings

Catalog Number	Nominal Power (1)	Power Pa	rt Supply		Drive (output)		
		Max. Input Current		Apparent	Max.	Nominal	Max.
		At 380 Vac	At 440 Vac	Power	Inrush Current (2)	Current (1)	Transient current (1) (3)
	kW	Α	Α	kVA	Α	Α	Α
ATV630C11N4F	110	207	179	136	187	211	232
ATV630C13N4F	132	250	210	160	187	250	275
ATV630C16N4F	160	291	251	191	187	302	332
ATV630C20N4F	200	369	319	243	345	370	407
ATV630C25N4F	250	453	391	298	345	477	524
ATV630C31N4F	315	566	488	372	345	590	649

⁽¹⁾ The switching frequency is adjustable from 2...8 kHz with a rated value of 2.5 kHz For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.

IP55 / UL Type 1 Products 3-Phase Power Part Supply 380...480 Vac 50/60 Hz

Power And Current Ratings

Catalog Number and	Nomir	al Power	Power P	art Supply			Drive (output)	
Frame Size [•]	(1)		Max. Input Current		Apparent	Max.	Nominal	Max.
			At 380 Vac	At 480 Vac	Power	Inrush Current (2)	Current (1)	Transient current (1) (3)
	kW	HP	Α	Α	kVA	Α	Α	Α
ATV650U07N4• [A]	0.75	1	1.5	1.3	1.1	8	2.2	2.4
ATV650U15N4• [A]	1.5	2	3	2.6	2.2	8.3	4	4.4
ATV650U22N4• [A]	2.2	3	4.3	3.8	3.2	8.4	5.6	6.2
ATV650U30N4• [A]	3	-	5.8	5.1	4.2	31.5	7.2	7.9
ATV650U40N4• [A]	4	5	7.6	6.7	5.6	32.2	9.3	10.2
ATV650U55N4• [A]	5.5	7 1/2	10.4	9.1	7.6	33.2	12.7	14
ATV650U75N4• [A]	7.5	10	13.8	11.9	9.9	39.9	16.5	18.2
ATV650D11N4• [A]	11	15	19.8	17	14.1	40.4	23.5	25.9
ATV650D15N4• [A]	15	20	27	23.3	19.4	74.5	31.7	34.9
ATV650D18N4• [A]	18.5	25	33.4	28.9	24	75.5	39.2	43.1
ATV650D22N4• [A]	22	30	39.6	34.4	28.6	76	46.3	50.9
ATV650D30N4• [B]	30	40	53.3	45.9	38.2	83	61.5	6 7.7
ATV650D37N4• [B]	37	50	66.2	57.3	47.6	92	74.5	82
ATV650D45N4• [B]	45	60	79.8	69.1	57.4	110	88	96.8
ATV650D55N4• [C]	55	75	97.2	84.2	70	176	106	116.6
ATV650D75N4• [C]	75	100	131.3	112.7	93.7	187	145	159.5
ATV650D90N4• [C]	90	125	156.2	135.8	112.9	236	173	190.3

⁽¹⁾ The switching frequency is adjustable:

For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.

⁽²⁾ Peak current when power is switched On, for the maximum supply mains voltage.

⁽³⁾ The drive is designed to run up to 60 s at 110% of nominal current.

O From 2...12 kHz for drive frame sizes A and B, rated value: 4 kHz

O From 1...8 kHz for drive frame size C, rated value: 2.5 kHz

⁽²⁾ Peak current when power is switched On, for the maximum supply mains voltage.

⁽³⁾ The drive is designed to run up to 60 s at 110% of nominal current.

IP54 Products 3-Phase Power Part Supply 380...440 Vac 50/60 Hz - Floor standing

Power And Current Ratings

Catalog Number	Nominal	Power Pa	art Supply			Drive (outpu	Drive (output)	
	Power (1)	Max. Input Current		Apparent	Max.	Nominal	Max.	
		At 380 Vac	At 440 Vac	Power	Inrush Current (2)	Current (1)	Transient current (1) (3)	
	kW	Α	Α	kVA	Α	Α	Α	
ATV650C11N4F	110	207	179	136	187	211	232	
ATV650C13N4F	132	244	210	160	187	250	275	
ATV650C16N4F	160	291	251	191	187	302	332	
ATV650C20N4F	200	369	319	243	345	370	407	
ATV650C25N4F	250	453	391	298	345	477	524	
ATV650C31N4F	315	566	488	372	345	590	649	

- (1) The switching frequency is adjustable from 2...8 kHz with a rated value of 2.5 kHz For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.
- (2) Peak current when power is switched On, for the maximum supply mains voltage.
- (3) The drive is designed to run up to 60 s at 110% of nominal current.

Floor Standing Drives - Fuse and Circuit-breaker Ratings

Catalog Number	Nominal	Upstream Cables	Upstream Cables				
	Power	gG Class Pre-fuse	Circuit-breaker I _{therm}	aR fuse			
	kW	Α	Α	Α			
ATV6•0C11N4F	110	250	230	250			
ATV6•0C13N4F	132	300	280	315			
ATV6•0C16N4F	160	315	315	350			
ATV6•0C20N4F	200	400	400	2 x 250			
ATV6•0C25N4F	250	500	500	2 x 315			
ATV6•0C31N4F	315	630	630	2 x 400			

76

Drive Ratings In Heavy Duty

Heavy Duty

Heavy-duty values are given for applications requiring a significant overload (up to 150 %).

NOTE:

- For fuse and circuit-breaker ratings refer to the information provided in the Altivar Process 600 Getting Started Annex (SCCR), catalog number <u>NHA64300</u> for UL/CSA compliance and also in the catalog (see page 9) for IEC compliance.
- For motor overload and drive thermal monitoring functions, refer to the ATV600 Programming manual (see page 9).

IP20 on Upper Part, IP00 on Lower Part Products and IP21 / UL Type 1 Products 3-Phase Power Part Supply 200...240 Vac 50/60 Hz

Power And Current Ratings

Catalog Number	and	Nomir	al Power	Power Pa	rt Supply			Drive (output)	
Frame Size [•]		(1)		Max. Inpu	t Current	Apparent	Max. Inrush	Nominal	Max. Transient
				At 200 Vac	At 240 Vac	Power	Current (2)	Current (1)	current (1) (3)
		kW	HP	Α	Α	kVA	Α	Α	Α
ATV630U07M3	[1]	0.37	1/2	1.7	1.5	0.6	4.3	3.3	5
ATV630U15M3	[1]	0.75	1	3.3	3	1.2	4.3	4.6	6.9
ATV630U22M3	[1]	1.5	2	6	5.3	2.2	4.3	8	12
ATV630U30M3	[1]	2.2	3	8.7	7.6	3.2	17.5	11.2	16.8
ATV630U40M3	[1]	3	_	11.7	10.2	4.2	17.6	13.7	20.6
ATV630U55M3	[2]	4	5	15.1	13	5.4	30.9	18.7	28.1
ATV630U75M3	[3]	5.5	7 1/2	20.1	16.9	7	39.3	25.4	38.1
ATV630D11M3	[3]	7.5	10	27.2	23.1	9.6	39.3	32.7	49.1
ATV630D15M3	[4]	11	15	40.1	34.3	14.3	64.6	46.8	70.2
ATV630D18M3	[4]	15	20	53.1	44.9	18.7	71.3	63.4	95.1
ATV630D22M3	[4]	18.5	25	64.8	54.5	22.7	70.9	78.4	117.6
ATV630D30M3	[5]	22	30	78.3	67.1	27.9	133.3	92.6	138.9
ATV630D37M3	[5]	30	40	104.7	88.6	36.8	133.3	123	184.5
ATV630D45M3	[5]	37	50	128.5	108.5	45.1	175	149	223.5
ATV630D55M3	[6]	45	60	156	134	50	168.2	176	264
ATV630D75M3	[6]	55	75	189	161	61.1	168.2	211	316.5

- (1) The switching frequency is adjustable:
 - O From 2...12 kHz for drive frame sizes 1 to 4, rated value: 4 kHz
 - O From 1...8 kHz for drive frame sizes 5 and 6, rated value: 2.5 kHz

For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.

- (2) Peak current when power is switched On, for the maximum supply mains voltage.
- (3) The drive is designed to run up to 60 s at 150% of nominal current.

IP20 on Upper Part, IP00 on Lower Part Products and IP21 / UL Type 1 Products 3-Phase Power Part Supply 380...480 Vac 50/60 Hz

Power And Current Ratings

Catalog Number	(4) and	Nomin	al Power	Power Pa	rt Supply			Drive (output)		
Frame Size [•]		(1)		Max. Inpu	t Current	Apparent	Max. Inrush	Nominal	Max.	
				At 380 Vac	At 480 Vac	Power	Current (2)	Current (1)	Transient current (1) (3)	
		kW	HP	Α	Α	kVA	Α	Α	Α	
ATV630U07N4	[1]	0.37	1/2	0.9	0.8	0.7	8	1.5	2.3	
ATV630U15N4	[1]	0.75	1	1.7	1.5	1.2	8.3	2.2	3.3	
ATV630U22N4	[1]	1.5	2	3.1	2.9	2.4	8.4	4	6	
ATV630U30N4	[1]	2.2	3	4.5	4.0	3.3	31.5	5.6	8.4	
ATV630U40N4	[1]	3	-	6.0	5.4	4.5	32.2	7.2	10.8	
ATV630U55N4	[1]	4	5	8	7.2	6.0	33.2	9.3	14	
ATV630U75N4	[2]	5.5	7 1/2	10.5	9.2	7.6	39.9	12.7	19.1	
ATV630D11N4	[2]	7.5	10	14.1	12.5	10.4	40.4	16.5	24.8	
ATV630D15N4	[3]	11	15	20.6	18.1	15	74.5	23.5	35.3	
ATV630D18N4	[3]	15	20	27.7	24.4	20.3	75.5	31.7	47.6	
ATV630D22N4	[3]	18.5	25	34.1	29.9	24.9	76	39.2	58.8	
ATV630D30N4	[4]	22	30	40.5	35.8	29.8	83	46.3	69.5	
ATV630D37N4	[4]	30	40	54.8	48.3	40.2	92	61.5	92.3	
ATV630D45N4	[4]	37	50	67.1	59	49.1	110	74.5	111.8	
ATV630D55N4	[5]	45	60	81.4	71.8	59.7	176	88	132	
ATV630D75N4	[5]	55	75	98.9	86.9	72.2	187	106	159	
ATV630D90N4	[5]	75	100	134.3	118.1	98.2	236	145	217.5	
ATV630C11N4	[6]	90	125	170	143	102.6	325	173	259.5	
ATV630C13N4	[6]	110	150	201	165	121.8	325	211	317	
ATV630C16N4	[6]	132	200	237	213	161.4	325	250	375	
ATV630C22N4	[7A]	160	250	296	246	187	426	302	453	
ATV630C25N4	[7B]	200	300	365	301	229	450	387	581	
ATV630C31N4	[7B]	250	400	457	375	286	615	481	722	

- (1) The switching frequency is adjustable:
 - O From 2...12 kHz for drive frame sizes 1 to 4, rated value: 4 kHz
 - O From 1...8 kHz for drive frame sizes 5 to 7, rated value: 2.5 kHz

For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.

- (2) Peak current when power is switched On, for the maximum supply mains voltage.
- (3) The drive is designed to run up to 60 s at 150% of nominal current.
- (4) Size 1...5 drives: Including catalog numbers ATV630 ••• N4Z...

IP20/21 / UL Type 1 Products 3-Phase Power Part Supply 600 Vac 50/60 Hz

NOTICE

OVERLOAD

Install properly rated line chokes upstream of drives ATV•30•••S6X.

Failure to follow these instructions can result in equipment damage.

Power And Current Ratings

Catalog Number a Frame Size [•]	Catalog Number and Nomin Frame Size [•] Power		Power Part S	upply			Drive (output)		
		(1)	Max. Input Current	Line choke	Apparent Power	Max. Inrush Current (2)	Nominal Current	Max. Transient current (1) (3)	
			At 600 Vac	(4)			(1)		
		HP	Α	mH	kVA	Α	Α	Α	
ATV630U22S6X	[2]	2	2.1	10	2.2	46	3.1	4.7	
ATV630U40S6X	[2]	3	3.3	4	3.4	46	4.2	6.3	
ATV630U55S6X	[2]	5	5.3	4	5.5	46	7.2	10.8	
ATV630U75S6X	[2]	7 1/2	7.7	2	8.0	46	9.5	14.3	
ATV630D11S6X	[2]	10	11.1	1	11.5	46	13.5	20.3	
ATV630D15S6X	[2]	15	15.3	1	15.9	46	18	27.0	
ATV630D18S6	[3S]	20	19.6	N/A	20.4	35	22	33.0	
ATV630D22S6	[3S]	25	23.2	N/A	24.1	35	27	40.5	
ATV630D30S6	[5S]	30	32	N/A	33.3	115	34	51.0	
ATV630D37S6	[5S]	40	40.6	N/A	42.2	115	41.5	62.3	
ATV630D45S6	[5S]	50	47.1	N/A	48.9	115	52	78.0	
ATV630D55S6	[5S]	60	60.4	N/A	62.8	115	62	93.0	
ATV630D75S6	[5S]	75	70.1	N/A	72.9	115	83	124.5	

(1) The switching frequency is adjustable:

EAV64301 04/2020

- O From 2...12 kHz for drive frame size 2, rated value: 4 kHz
- O From 2...6 kHz for drive frame size 3S, rated value: 4 kHz
- O From 1...4.9 kHz for drive frame size 5S, rated value: 2.5 kHz

For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.

- (2) Peak current when power is switched On, for the maximum supply mains voltage.
- (3) The drive is designed to run up to 60 s at 150% of nominal current.
- (4) ATV630 ••• S6X may only be used with a line choke.

IP20 on Upper Part, IP00 on Lower Part Products, 3-Phase Power Part Supply 500...690 Vac 50/60 Hz Power And Current Ratings At Minimum Supply Voltage

Catalog Number and Size [•]	I Frame	Nominal Po	wer (1)	Power Part Supply	Drive (output)
				Max. Input Current	Nominal Current (1)	Max. Transient current (1) (3)
		At 500 Vac		At 500 Vac		
		kW	HP	Α	A	A
ATV630U22Y6	[3Y]	1.1	1 1/2	2.6	2.4	3.6
ATV630U30Y6	[3Y]	1.5	2	3.4	3.1	4.7
ATV630U40Y6	[3Y]	2.2	3	4.7	4.2	6.3
ATV630U55Y6	[3Y]	3	-	6.2	5.4	8.1
ATV630U75Y6	[3Y]	4	5	7.9	7.2	10.8
ATV630D11Y6	[3Y]	5.5	7 1/2	10.4	9.5	14.3
ATV630D15Y6	[3Y]	7.5	10	13.6	13.5	20.3
ATV630D18Y6	[3Y]	11	15	18.4	18	27.0
ATV630D22Y6	[3Y]	15	20	23.2	24	36.0
ATV630D30Y6	[3Y]	18.5	25	27.6	29	43.5
ATV630D37Y6	[5Y]	22	30	37.7	34	51.0
ATV630D45Y6	[5Y]	30	40	47.2	45	67.5
ATV630D55Y6	[5Y]	37	50	55.6	55	82.5
ATV630D75Y6	[5Y]	45	60	71	66	99.0
ATV630D90Y6	[5Y]	55	75	82.7	83	124.5

- (1) The switching frequency is adjustable:
 - O From 2...6 kHz for drive frame size 3Y, rated value: 4 kHz
 - O From 1...4.9 kHz for drive frame size 5Y, rated value: 2.5 kHz

For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.

- (2) Peak current when power is switched On, for the maximum supply mains voltage.
- (3) The drive is designed to run up to 60 s at 150% of nominal current.

80

Power And Current Ratings At Maximum Supply Voltage

Catalog Number a	and	Nominal	Power (1)	Power Part S	Supply		Drive (output)	
Frame Size [•]				Max. Input Current	Apparent Power	Max. Inrush Current (2)	Nominal Current (1)	Max. Transient
			At 690 Vac		At 690 Vac	At 690 Vac		current (1) (3)
		kW	HP	Α	kVA	A	Α	Α
ATV630U22Y6	[3Y]	1.5	2	2.6	3.1	35	2.4	3.6
ATV630U30Y6	[3Y]	2.2	3	3.6	4.3	35	3.1	4.7
ATV630U40Y6	[3Y]	3	-	4.8	5.7	35	4.2	6.3
ATV630U55Y6	[3Y]	4	5	6.1	7.3	35	5.4	8.1
ATV630U75Y6	[3Y]	5.5	7 1/2	8	9.6	35	7.2	10.8
ATV630D11Y6	[3Y]	7.5	10	10.5	12.5	35	9.5	14.3
ATV630D15Y6	[3Y]	11	15	14.7	17.6	35	13.5	20.3
ATV630D18Y6	[3Y]	15	20	19.2	22.9	35	18	27.0
ATV630D22Y6	[3Y]	18.5	25	23	27.5	35	24	36.0
ATV630D30Y6	[3Y]	22	30	26	31.1	35	29	43.5
ATV630D37Y6	[5Y]	30	40	38.5	46.0	115	34	51.0
ATV630D45Y6	[5Y]	37	50	46.2	55.2	115	45	67.5
ATV630D55Y6	[5Y]	45	60	54.4	65.0	115	55	82.5
ATV630D75Y6	[5Y]	55	75	68.5	81.9	115	66	99.0
ATV630D90Y6	[5Y]	75	100	87.7	104.8	115	83	124.5

(1) The switching frequency is adjustable:

- O From 2...6 kHz for drive frame size 3Y, rated value: 4 kHz
- O From 1...4.9 kHz for drive frame size 5Y, rated value: 2.5 kHz

For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.

- (2) Peak current when power is switched On, for the maximum supply mains voltage.
- (3) The drive is designed to run up to 60 s at 150% of nominal current.

IP21 Products 3-Phase Power Part Supply 380...440 Vac 50/60 Hz - Floor standing

Power And Current Ratings

Catalog Number	Nominal Power (1)	Power Pa	art Supply	Drive (output)			
		At 380 Vac		Apparent Power	Max. Inrush Current	Nominal Current (1)	Max. Transient current (1)
	kW	Α	Α	kVA	(2) A	A	(3) A
ATV630C11N4F	90	174	151	115	187	173	260
ATV630C13N4F	110	207	179	136	187	211	317
ATV630C16N4F	132	244	210	160	187	250	375
ATV630C20N4F	160	302	262	200	345	302	453
ATV630C25N4F	200	369	319	243	345	370	555
ATV630C31N4F	250	453	391	298	345	477	716

- (1) The switching frequency is adjustable from 2...8 kHz with a rated value of 2.5 kHz For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.
- (2) Peak current when power is switched On, for the maximum supply mains voltage.
- (3) The drive is designed to run up to 60 s at 150% of nominal current.

IP55 / UL Type 1 Products 3-Phase Power Part Supply 380...480 Vac 50/60 Hz

Power And Current Ratings

Catalog Number and		Nomir	al	Power Pa	art Supply	Drive (output)			
Frame Size [•]		Power (1)		Max. Inpu	ut Current	Apparent	Max.	Nominal	Max.
				At 380 Vac	At 480 Vac	Power	Inrush Current (2)	current (1)	transient current (1) (3)
		kW	HP	Α	Α	kVA	Α	Α	Α
ATV650U07N4•	[A]	0.37	1/2	0.9	0.8	0.7	8.0	1.5	2.3
ATV650U15N4•	[A]	0.75	1	1.7	1.5	1.2	8.3	2.2	3.3
ATV650U22N4•	[A]	1.5	2	3.1	2.9	2.4	8.4	4	6
ATV650U30N4•	[A]	2.2	3	4.5	4.0	3.3	31.5	5.6	8.4
ATV650U40N4•	[A]	3	-	6	5.4	4.5	32.2	7.2	10.8
ATV650U55N4•	[A]	4	5	8	7.2	6.0	33.2	9.3	14
ATV650U75N4•	[A]	5.5	7 1/2	10.5	9.2	7.6	39.9	12.7	19.1
ATV650D11N4•	[A]	7.5	10	14.1	12.5	10.4	40.4	16.5	24.8
ATV650D15N4•	[A]	11	15	20.6	18.1	15	74.5	23.5	35.3
ATV650D18N4•	[A]	15	20	27.7	24.4	20.3	75.5	31.7	47.6
ATV650D22N4•	[A]	18.5	25	34.1	29.9	24.9	76	39.2	58.8
ATV650D30N4•	[B]	22	30	40.5	35.8	29.8	83	46.3	69.5
ATV650D37N4•	[B]	30	40	54.8	48.3	40.2	92	61.5	92.3
ATV650D45N4•	[B]	37	50	67.1	59	49.1	109.7	74.5	111.8
ATV650D55N4•	[C]	45	60	81.4	71.8	59.7	176	88	132
ATV650D75N4•	[C]	55	75	98.9	86.9	72.2	187	106	159
ATV650D90N4•	[C]	75	100	134.3	118.1	98.2	236	145	217.5

- (1) The switching frequency is adjustable:
 - O From 2...12 kHz for drive frame sizes A and B, rated value: 4 kHz
 - O From 1...8 kHz for drive frame size C, rated value: 2.5 kHz

For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current *(see page 107)*. In this case, switching frequency can be reduced if an excessive temperature rise occurs.

- (2) Peak current when power is switched On, for the maximum supply mains voltage.
- (3) The drive is designed to run up to 60 s at 150% of nominal current.

IP54 Products 3-Phase Power Part Supply 380...440 Vac 50/60 Hz - Floor standing

Power And Current Ratings

Catalog Number	Nominal	Power Pa	art Supply	Drive (output)			
	Power (1)	Max. Input Current		Apparent	Max.	Nominal	Max.
	kW	At 380 Vac	At 440 Vac	Power	Inrush Current (2)	Current (1)	Transient current (1) (3)
		Α	Α	kVA	Α	Α	Α
ATV650C11N4F	90	174	151	115	187	173	260
ATV650C13N4F	110	207	179	136	187	211	317
ATV650C16N4F	132	244	210	160	187	250	375
ATV650C20N4F	160	302	262	200	345	302	453
ATV650C25N4F	200	369	319	243	345	370	555
ATV650C31N4F	250	453	391	298	345	477	716

- (1) The switching frequency is adjustable from 2...8 kHz with a rated value of 2.5 kHz For operation at switching frequencies higher than the rated value. Derating must be applied to the drive (output) current (see page 107). In this case, switching frequency can be reduced if an excessive temperature rise occurs.
- (2) Peak current when power is switched On, for the maximum supply mains voltage.
- (3) The drive is designed to run up to 60 s at 150% of nominal current.

Floor Standing Drives - Fuse and Circuit-breaker Ratings

Catalog Number	Nominal	Upstream Cables	Internal Circuits	
	Power	gG Class Pre-fuse	Circuit-breaker I _{therm}	aR fuse
	kW	Α	Α	Α
ATV6•0C11N4F	110	250	200	250
ATV6•0C13N4F	132	300	240	315
ATV6•0C16N4F	160	300	280	350
ATV6•0C20N4F	200	355	330	2 x 250
ATV6•0C25N4F	250	400	400	2 x 315
ATV6•0C31N4F	315	500	500	2 x 400


Section 2.4

Electrical Data - Upstream Protective Device

What Is in This Section?

This section contains the following topics:

Торіс	Page
Introduction	85
Prospective Short-Circuit Current	87
IEC Type Circuit-Breaker as SCPD	90
IEC Fuses	91
UL Circuit-Breakers and Fuses	93



84

Introduction

Overview

🛕 🛕 DANGER

INSUFFICIENT PROTECTION AGAINST OVERCURRENTS CAN CAUSE FIRE OR EXPLOSION

- Use properly rated overcurrent protection devices.
- Use the fuses/circuit breakers specified.
- Do not connect the product to a supply mains whose prospective short circuit current rating (current that flows during a short circuit) exceeds the specified maximum permissible value.
- When rating the upstream mains fuses and the cross sections as well as the lengths of the mains cables, take into account the minimum required prospective short-circuit current (Isc). Refer to the Upstream Protection Device section.
- If the minimum required prospective short-circuit current (lsc) is not available, apply the instructions given in the section below.

Failure to follow these instructions will result in death or serious injury.

The specified maximum permissible values and products for IEC compliance are specified in the catalog. The specified maximum permissible values and products for UL/CSA compliance are specified in the annex provided with the drive.

General

- The Short Circuit Protective Device (SCPD) rated to the drive will help protect the upstream installation in case of a short-circuit internal to the drive and mitigate the damage to the drive and its surrounding
- The SCPD rated to the drive is mandatory to help ensuring the safety of the Power Drive System. It comes in addition to the upstream branch circuit protection which is in compliance with the local regulation for electrical installation.
- The SCPD shall mitigate the damage in case of detected error condition such as an internal short-circuit of the drive.
- The SCPD must take into account both following characteristics...
 - a maximum prospective short-circuit current
 - o a minimum required prospective short-circuit current (Isc).


If the minimum required prospective short-circuit current (Isc) is not available, increase the power of the transformer or decrease the length of the cables

In other cases, contact your Schneider Electric Customer Care Center (CCC) www.se.com/CCC for specific selection of Short Circuit Protective Device (SCPD).



Wiring Diagram

This diagram shows an example of installation with both SCPD types, Circuit-breaker (see page 90) and Fuse link (see page 91) rated to the drive.



(1) Drive

Prospective Short-Circuit Current

Calculation

The prospective short-circuit current shall be computed at the drive connection points.

We recommend using the Schneider Electric tool Ecodial Advance Calculation www.se.com/en/product-range-presentation/61013-ecodial-advance-calculation/ available on

The following equations allow to estimate the value of the symmetrical three-phase prospective shortcircuit current (Isc) at the drive connection points.

$$Xt = \frac{U^2}{Sn} \cdot usc$$

$$Zcc = \sqrt{\left(\rho \cdot \frac{l}{S} + Rf\right)^{2} + \left(Xt + XcJ + Xf\right)^{2}}$$

$$Isc = \frac{U}{\sqrt{3}} \cdot \frac{1}{Zcc}$$

lsc Symmetrical three-phase prospective short-circuit current (kA)

Xt Transformer reactance

No-load phase to phase voltage of the transformer (V)

Sn Apparent transformer power (kVA)

Short-circuit voltage, according to the transformer data sheet (%) usc

Zcc Total short-circuit impedance ($m\Omega$)

Conductor resistivity e.g. Cu: $0.01851 \text{ m}\Omega.\text{mm}$ O

Conductor length (mm)

S Conductor cross section (mm²)

Хc Conductor lineic reactance (0.0001 mΩ/mm)

Rf, Xf Resistance and reactance of the line filter (m Ω) (see page 88)

Example of Calculation with Copper Cable (without line filter)

Transformer	U	Cable Cross	Isc dep	Isc depending on cable length in m(ft)							
50 Hz	400 Vac Usc	Section	10 (33)	20 (66)	40 (131)	80 (262)	100 (328)	160 (525)	200 (656)	320 (1,050)	
kVA	%	mm ² (AWG)	kA	kA	kA	kA	kA	kA	kA	kA	
100	4	2.5 (14)	2.3	1.4	0.8	0.4	0.3	0.2	0.2	0.1	
		4 (12)	2.9	2.0	1.2	0.6	0.5	0.3	0.2	0.2	
		6 (10)	3.2	2.6	1.6	0.9	0.7	0.5	0.4	0.2	
		10 (8)	3.4	3.1	2.3	1.4	1.2	0.8	0.6	0.4	
		25 (4)	3.5	3.4	3.1	2.5	2.2	1.6	1.4	0.9	
		50 (0)	3.5	3.5	3.3	3.0	2.8	2.3	2.1	1.5	
		70 (00)	3.5	3.5	3.4	3.1	2.9	2.6	2.3	1.8	
		120 (250 MCM)	3.6	3.5	3.4	3.2	3.1	2.8	2.6	2.1	
250	4	6 (10)	5.7	3.4	1.8	0.9	0.7	0.5	0.4	0.2	
		10 (8)	7.1	5.0	2.9	1.5	1.2	0.8	0.6	0.4	
		25 (4)	8.4	7.4	5.5	3.4	2.8	1.8	1.5	0.9	
		50 (0)	8.6	8.1	7.0	5.2	4.5	3.2	2.7	1.8	
		70 (00)	8.6	8.2	7.3	5.8	5.2	3.9	3.3	2.3	
		120 (250 MCM)	8.7	8.3	7.6	6.5	6.0	4.8	4.2	3.0	
400	4	6 (10)	6.6	3.6	1.8	0.9	0.7	0.5	0.4	0.2	
		10 (8)	9.2	5.6	3.0	1.5	1.2	0.8	0.6	0.4	
		25 (4)	12	9.9	6.5	3.6	2.9	1.9	1.5	1.0	
		50 (0)	13	12	9.3	6.1	5.1	3.4	2.8	1.8	
		70 (00)	13	12	10	7.2	6.2	4.4	3.6	2.4	
		120 (250 MCM)	13	13	11	8.6	7.6	5.7	4.9	3.4	
800	6	6 (10)	6.9	3.7	1.9	0.9	0.7	0.5	0.4	0.2	
i		10 (8)	10	5.8	3.0	1.5	1.2	0.8	0.6	0.4	
		25 (4)	15	11	6.9	3.7	3.0	1.9	1.5	1.0	
		50 (0)	17	15	11	6.5	5.4	3.5	2.9	1.8	
		70 (00)	17	15	12	7.9	6.7	4.6	3.7	2.4	
		120 (250 MCM)	17	16	13	9.8	8.6	6.2	5.2	3.5	
1,000	6	6 (10)	7.1	3.7	1.9	0.9	0.7	0.5	0.4	0.2	
	10 (8)	11	6.0	3.1	1.5	1.2	0.8	0.6	0.4		
		25 (4)	18	12	7.1	3.7	3.0	1.9	1.5	1.0	
		50 (0)	21	17	12	6.7	5.5	3.6	2.9	1.8	
İ		70 (00)	21	18	13	8.4	7.0	4.7	3.8	2.4	
		120 (250 MCM)	22	19	16	11	9.3	6.5	5.4	3.6	

Additional Line Filter Option

If a line input filter option is required for the installation such as a line reactor or a passive harmonic filter, the minimum prospective short-circuit current capability of the source is reduced at the drive connection point and shall be estimated (see page 87) with the impedance values given in the table below.

Then, the SCPD type shall be selected according to the drive. If no selection is available, Schneider Electric Customer Care Center (CCC) <u>www.se.com/CCC</u> should be contacted.

EMC filter series have no significant effect on the minimum prospective short-circuit current capability of the main source.

Through the line option, the lsc will be limited to a maximum value independent of the transformer and cable. Therefore the below equations can be used to estimate the minimum prospective short-circuit current capability.

 $10 m\Omega \le Xf \le 400 m\Omega \implies Isc_{maxi}(kA) = 4.7 - 0.7 \cdot Log(Xf)$

 $400 \, m\Omega \le Xf \le 2000 \, m\Omega \quad \Rightarrow \quad Isc_{\text{maxi}} \, (kA) = 2.05 - 0.26 \cdot \text{Log}(Xf)$

Log: Natural logarithm

Line Choke Filters Impedance Values

Line Choke Filter	Xf in mΩ
<u>VZ1L004M010</u> , <u>VW3A4551</u>	700
<u>VZ1L007UM50</u> , <u>VW3A4552</u>	300
<u>VZ1L018UM20,</u> <u>VW3A4553</u>	100
<u>VW3A4554</u>	70
<u>VW3A4555</u>	30
<u>VW3A4556</u>	20

Harmonic Passive Filters Resistance and Reactance Values

Catalog Number			(Rf)	(Rf) Xf	Catalog Number		Xf
Drive	Harmonic passiv	e filter			Harmonic passive		
380480 Vac	THDi < 10%		mΩ	mΩ	THDi < 5%		mΩ
ATV630U07N4, ATV650U07N4 ATV630U15N4, ATV650U15N4 ATV630U22N4, ATV650U22N4 ATV630U30N4, ATV650U30N4	VW3A46101	VW3A46139	_	700	VW3A46120	VW3A46158	1,800
ATV630U40N4, ATV650U40N4 ATV630U55N4, ATV650U55N4	VW3A46102	VW3A46140	_	420	VW3A46121	VW3A46159	1,000
ATV630U75N4, ATV650U75N4	VW3A46103	VW3A46141	-	300	VW3A46122	VW3A46160	540
ATV630D11N4, ATV650D11N4	VW3A46104	VW3A46142	-	230	VW3A46123	VW3A46161	530
ATV630D15N4, ATV650D15N4	VW3A46105	VW3A46143	-	160	VW3A46124	VW3A46162	390
ATV630D18N4, ATV650D18N4	VW3A46106	VW3A46144	-	140	VW3A46125	VW3A46163	320
ATV630D22N4, ATV650D22N4	VW3A46107	VW3A46145	-	110	VW3A46126	VW3A46164	270
ATV630D30N4, ATV650D30N4	VW3A46108	VW3A46146	-	80	VW3A46127	VW3A46165	180
ATV630D37N4, ATV650D37N4	VW3A46109	VW3A46147	-	60	VW3A46128	VW3A46166	170
ATV630D45N4, ATV650D45N4	VW3A46110	VW3A46148	-	50	VW3A46129	VW3A46167	130
ATV630D55N4, ATV650D55N4	VW3A46111	VW3A46149	-	40	VW3A46130	VW3A46168	100
ATV630D75N4, ATV650D75N4	VW3A46112	VW3A46150	-	30	VW3A46131	VW3A46169	70
ATV630D90N4, ATV650D90N4	VW3A46113	VW3A46151	30	30	VW3A46132	VW3A46170	50
ATV630C11N4	VW3A46114	VW3A46152	20_	20	VW3A46133	VW3A46171	40
ATV630C13N4	VW3A46115	VW3A46153	20	20	VW3A46134	VW3A46172	30
ATV630C16N4	VW3A46116	VW3A46154	20	20	VW3A46135	VW3A46173	30
ATV630C22N4	VW3A46118	VW3A46155	10	10	VW3A46137	VW3A46174	20
ATV630C25N4	VW3A46119	VW3A46157	10	10	VW3A46138	VW3A46176	20
ATV630C31N4	VW3A46116x2	VW3A46153x2	10	10	VW3A46135x2	VW3A46172x2	15

IEC Type Circuit-Breaker as SCPD

Function

The circuit-breaker offers enhanced features versus fuse-link since it cumulates 3 functionalities:

- insulation with lock,
- switch (full load interruption),
- downstream short-circuit protection without replacement.

Selection Table

Schneider Electric circuit-breaker, setting and limits shall be selected according to the following table:

Catalog Number			Circuit Breaker	Ir m	Minimum Isc
200240 Vac	380480 Vac	500690 Vac	to IEC 60947-2	(A)	(A)
-	ATV630U07N4, ATV650U07N4	-	GV2L07	33.5	100
ATV630U07M3	ATV630U15N4, ATV650U15N4	-	GV2L08	51	100
ATV630U15M3	ATV630U22N4, ATV650U22N4	ATV630U22Y6 ATV630U30Y6	GV2L10	78	200
ATV630U22M3	ATV630U30N4, ATV650U30N4 ATV630U40N4, ATV650U40N4	ATV630U40Y6 ATV630U55Y6	GV2L14	138	300
ATV630U30M3	ATV630U55N4, ATV650U55N4	ATV630U75Y6	GV2L16	170	300
ATV630U40M3	ATV630U75N4, ATV650U75N4	ATV630D11Y6	GV2L20	223	400
ATV630U55M3	ATV630D11N4, ATV650D11N4	ATV630D15Y6	GV2L22	327	600
_	_	ATV630D18Y6	GV3L25	350	600
ATV630U75M3	ATV630D15N4, ATV650D15N4	ATV630D22Y6	GV3L32	448	700
ATV630D11M3	ATV630D18N4, ATV650D18N4	ATV630D30Y6	GV3L40	560	900
_	ATV630D22N4, ATV650D22N4	ATV630D37Y6	GV3L50	700	1,100
ATV630D15M3	ATV630D30N4, ATV650D30N4	ATV630D45Y6	GV3L65	910	1,800
ATV630D18M3 ATV630D22M3	ATV630D37N4, ATV650D37N4	_	GV4L80	480	1,800
ATV630D30M3	ATV630D45N4, ATV650D45N4 ATV630D55N4, ATV650D55N4	-	GV4L115	690	2,500
		ATV630D55Y6 ATV630D75Y6	NSX100-MA100	600	2,900
ATV630D37M3 ATV630D45M3	ATV630D55N4, ATV650D55N4 ATV630D75N4, ATV650D75N4	ATV630D90Y6	NSX160-MA150	1,350	3,200
ATV630D55M3	ATV630D90N4, ATV650D90N4 ATV6•0C11N4	-	NSX250-MA220	1,980	4,700
ATV630D75M3	ATV630C13N4 ATV630C16N4	-	NSX400-1.3M320	1,600	6,300
_	ATV6•0C22N4 ATV6•0C25N4	-	NSX630-1.3M500	3,000	9,000
_	ATV6•0C31N4	_	NS800L-2or5 800	1,600	20,000

NOTE: Floor Standing Drives ATV6•0C••N4F have built-in protection *(see page 92)* therefore only upstream branch circuit protection which follows the local rules for electrical installation is necessary.

NOTE: Verify that the minimum required prospective short-circuit current (Isc) value from the table above is lower than the value estimated in the Calculation section (see page 87).

IEC Fuses

gG Category Fuses Selection Table

Current limiting fuses can be chosen as SCPD according to the following table:

Catalog Number			Fuse gG to IEC 60269-1		
			Rating	Minimum Isc	
200240 Vac	380480 Vac	500690 Vac	(A)	(A)	
-	ATV630U07N4, ATV650U07N4	-	4	200	
ATV630U07M3	ATV630U15N4, ATV650U15N4	ATV630U22Y6 ATV630U30Y6	8	200	
ATV630U15M3	ATV630U22N4, ATV650U22N4	ATV630U40Y6	10	300	
-	ATV630U30N4, ATV650U30N4	-	12	300	
ATV630U22M3	ATV630U40N4, ATV650U40N4	ATV630U55Y6	16	400	
ATV630U30M3	ATV630U55N4, ATV650U55N4	ATV630U75Y6	20	1,000	
ATV630U40M3	ATV630U75N4, ATV650U75N4	ATV630D11Y6	25	1,000	
_	_	ATV630D15Y6	32	2,000	
ATV630U55M3	ATV630D11N4, ATV650D11N4	ATV630D18Y6	40	2,000	
ATV630U75M3	ATV630D15N4, ATV650D15N4	ATV630D22Y6	50	2,500	
ATV630D11M3	ATV630D18N4, ATV650D18N4	ATV630D30Y6	63	3,000	
-	ATV630D22N4, ATV650D22N4	ATV630D37Y6	80	4,000	
ATV630D15M3	ATV630D30N4, ATV650D30N4	ATV630D45Y6 ATV630D55Y6	100	5,500	
ATV630D18M3 ATV630D22M3	ATV630D37N4, ATV650D37N4	ATV630D75Y6	125	6,500	
ATV630D30M3	ATV630D45N4, ATV650D45N4 ATV630D55N4, ATV650D55N4	ATV630D90Y6	160	9,000	
ATV630D37M3	_	_	200	12,000	
ATV630D45M3	ATV630D75N4, ATV650D75N4 ATV630D90N4, ATV650D90N4	_	250	15,000	
ATV630D55M3	ATV6•0C11N4	_	not applica	ble	
ATV630D75M3	ATV630C13N4	_	not applica	ble	
_	ATV630C16N4	_	not applica	ble	
_	ATV630C22N4	_	not applica	ble	
_	ATV630C25N4	-	not applica	ble	
_	ATV630C31N4	_	not applica	ble	

NOTE: Floor Standing Drives ATV6•0C••N4F have built-in protection (see page 92) therefore only upstream branch circuit protection which follows the local rules for electrical installation is necessary.

NOTE: Verify that the minimum lsc value above is lower than the value estimated in the Calculation section (see page 87).

gR-aR Category Fuses Selection Table

Catalog Number	talog Number			Fuse gR-aR to IEC 60269-4		
-			Rating	Minimum Isc		
200240 Vac	380480 Vac	500690 Vac	(A)	(A)		
-	ATV630U07N4, ATV650U07N4	-	4	100		
ATV630U07M3	ATV630U15N4, ATV650U15N4	ATV630U22Y6 ATV630U30Y6	8	100		
ATV630U15M3	ATV630U22N4, ATV650U22N4	ATV630U40Y6	10	100		
-	ATV630U30N4, ATV650U30N4	-	12.5	200		
ATV630U22M3	ATV630U40N4, ATV650U40N4	ATV630U55Y6	16	200		
ATV630U30M3	ATV630U55N4, ATV650U55N4	ATV630U75Y6	20	200		
ATV630U40M3	ATV630U75N4, ATV650U75N4	ATV630D11Y6	25	300		
_	_	ATV630D15Y6	32	500		
ATV630U55M3	ATV630D11N4, ATV650D11N4	ATV630D18Y6	40	500		
ATV630U75M3	ATV630D15N4, ATV650D15N4	ATV630D22Y6	50	800		
ATV630D11M3	ATV630D18N4, ATV650D18N4	ATV630D30Y6	63	1,000		
-	ATV630D22N4, ATV650D22N4	ATV630D37Y6	80	1,500		
ATV630D15M3	ATV630D30N4, ATV650D30N4	ATV630D45Y6 ATV630D55Y6	100	1,500		
ATV630D18M3 ATV630D22M3	ATV630D37N4, ATV650D37N4	ATV630D75Y6	125	2,000		
ATV630D30M3	ATV630D45N4, ATV650D45N4 ATV630D55N4, ATV650D55N4	ATV630D90Y6	160	2,500		
ATV630D37M3	_	_	200	4,000		
ATV630D45M3	ATV630D75N4, ATV650D75N4 ATV630D90N4, ATV650D90N4	-	250	5,000		
ATV630D55M3	ATV6•0C11N4	_	315	6,000		
ATV630D75M3	ATV630C13N4	_	350	7,000		
_	ATV630C16N4	_	400	9,000		
_	ATV630C22N4	_	630	10,000		
_	ATV630C25N4	_	700	10,000		
_	ATV630C31N4	_	800	10,000		

Catalog Number	Built-in aR Fuse to IEC 60269-4					
	Rating	Minimum Isc				
380440 Vac	(A) A	(A)				
ATV6•0C11N4F	250	5,000				
ATV6•0C13N4F	315	6,000				
ATV6•0C16N4F	350	7,000				
ATV6•0C20N4F	2 x 250	10,000				
ATV6•0C25N4F	2 x 315	12,000				
ATV6•0C31N4F	2 x 400	18,000				

NOTE: Verify that the minimum Isc value above is lower than the value estimated in the Calculation section (see page 87).

UL Circuit-Breakers and Fuses

Reference Document

UL Fuse and circuit-breaker information is provided in the Annex for ATV600 Getting Started (EAV64300).

Complementary Information

The following table shows the minimum required prospective short-circuit current (Isc) depending on the drive and **associated circuit-breaker**.

Catalog Number			Circuit Breakers				
			PowerPact	Min. Isc	GV•P	Min. Isc	
200240 Vac	380480 Vac	600 Vac		(A)		(A)	
-	ATV630U07N4(Z), ATV650U07N4(E)	-	H•L36015	1,500	GV2P07	100	
ATV630U07M3	ATV630U15N4(Z), ATV650U15N4(E) ATV630U22N4(Z), ATV650U22N4(E)	_	H•L36015	1,500	GV2P08	100	
ATV630U15M3	ATV630U30N4(Z), ATV650U30N4(E) ATV630U40N4(Z), ATV650U40N4(E)	_	H•L36015	1,500	GV2P10	200	
ATV630U22M3	ATV630U55N4(Z), ATV650U55N4(E)	-	H•L36025	1,500	GV2P14	300	
ATV630U30M3	_	_	H•L36030	1,500	GV2P14	300	
ATV630U40M3	_	_	H•L36030	1,500	GV2P20	400	
ATV630U55M3	_	_	H•L36050	1,700	GV2P21	600	
-	-	ATV630U22S6X ATV630U40S6X ATV630U22Y6 ATV630U30Y6	H•L36015	1,500	GV3P13	300	
-	_	ATV630U55S6X ATV630U40Y6 ATV630U55Y6	H•L36020	1,500	GV3P13	300	
-	_	ATV630U75S6X ATV630U75Y6	H•L36025	1,500	GV3P13	300	
-	ATV630U75N4(Z), ATV650U75N4(E)		H•L36030	1,500	GV3P13	300	
_	_	ATV630D11Y6	H•L36040	1,700	GV3P13	300	
_	_	ATV630D11S6X	H•L36040	1,700	GV3P18	400	
-	ATV630D11N4(Z), ATV650D11N4(E)	ATV630D15Y6	H•L36050	1,700	GV3P18	400	
ATV630U75M3	_	_	H•L36060	3,000	GV2P32	700	
_	_	ATV630D15S6X	H•L36050	1,700	GV3P25	700	
-	ATV630D15N4(Z), ATV650D15N4(E)	ATV630D18Y6	H•L36060	3,000	GV3P25	700	
-	_	ATV630D18S6 ATV630D22Y6	H•L36080	3,000	GV3P25	700	
_	ATV630D18N4(Z), ATV650D18N4(E)		H•L36070	3,000	GV3P32	700	
_	_	ATV630D22S6 ATV630D30Y6	H•L36100	3,500	GV3P32	700	
ATV630D11M3	_	_	H•L36070	3,000	GV3P40	900	
-	ATV630D22N4(Z), ATV650D22N4(E)	-	H•L36080	3,000	GV3P40	900	

⁽¹⁾ Standard fixed trip unit; see PowerPact catalog (0611CT1001 R02/16), Table18, x 2 for trip within 1 cycle

⁽²⁾ Electronic trip unit magnetic only, ref M37x (Micrologic 1.3M); see PowerPact catalog (0611CT1001 R02/16) Table 53, x 1.5)

Catalog Number			Circuit Breakers					
			PowerPact	Min. Isc	GV•P	Min. Isc		
200240 Vac	380480 Vac	600 Vac		(A)		(A)		
ATV630D15M3		-	H•L36090	3,000	GV3P50	1,100		
-	ATV630D30N4(Z), ATV650D30N4(E)	_	H•L36100	3,500	GV3P50	1,100		
-	-	ATV630D30S6 ATV630D37Y6	H•L36125	3,500	GV3P50	1,100		
-	-	ATV630D37S6 ATV630D45Y6	H•L36150	3,500	GV3P50	1,100		
ATV630D18M3	_	_	H•L36110	3,500	GV3P65	1,800		
-	ATV630D37N4(Z), ATV650D37N4(E)	_	H•L36125	3,500	GV3P65	1,800		
-	-	ATV630D45S6 ATV630D55Y6	H•L36150	3,500	GV3P65	1,800		
ATV630D22M3	_	_	H•L36125	3,500	GV4PB80S	6,000		
-	ATV630D45N4(Z), ATV650D45N4(E)	_	H•L36150	3,500	GV4PB80S	6,000		
-	-	ATV630D55S6 ATV630D75Y6	J•L36200	4,000	GV4PB80S	6,000		
ATV630D30M3	ATV630D55N4(Z), ATV650D55N4(E)	-	J•L36175	3,500	GV4PB115S	6,000		
ATV630D37M3	_	_	J•L36200	4,000	_	_		
ATV630D45M3	_	_	J•L36225	4,500	-	_		
-	ATV630D75N4(Z), ATV650D75N4(E)	_	J•L36200	4,000	GV4PB115S	6,000		
-	-	ATV630D75S6 ATV630D90Y6	J•L36250	5,000	GV4PB115S	6,000		
-	ATV630D90N4(Z), ATV650D90N4(E)	-	J•L36250	5,000	GV5P150H	8,500		
ATV630D55M3	_	_	L•L36400	7,500	-	_		
	ATV630C11N4	_	L•L36400	7,500	GV5P220H	9,500		
ATV630D75M3		_	L•L36600	10,000	_	_		
	ATV630C13N4	_	L•L36600	10,000	GV5P220H	9,500		
_	ATV630C16N4	-	L•L36600	10,000	GV6P320H	18,000		

⁽¹⁾ Standard fixed trip unit; see PowerPact catalog (0611CT1001 R02/16), Table18, x 2 for trip within 1 cycle

⁽²⁾ Electronic trip unit magnetic only, ref M37x (Micrologic 1.3M); see PowerPact catalog (0611CT1001 R02/16) Table 53, x 1.5)

The following table shows the minimum required prospective short-circuit current (Isc) depending on the drive and associated class J fuse, according to UL248-8.


Catalog Number			Class J Fuse to UL248-8	Minimum Isc
200240 Vac	380480 Vac	600 Vac	(A)	(A)
-	ATV630U07N4(Z), ATV650U07N4(E)	-	3	100
ATV630U07M3	ATV630U15N4(Z), ATV650U15N4(E)	ATV630U22Y6 ATV630U22S6X	6	300
ATV630U15M3	ATV630U22N4(Z), ATV650U22N4(E) ATV630U30N4(Z), ATV650U30N4(E)	ATV630U30Y6 ATV630U40S6X	10	500
ATV630U22M3	ATV630U40N4(Z), ATV650U40N4(E) ATV630U55N4(Z), ATV650U55N4(E)	ATV630U40Y6 ATV630U55Y6 ATV630U75Y6 ATV630U55S6X ATV630U75S6X	15	500
ATV630U30M3	ATV630U75N4(Z), ATV650U75N4(E)	ATV630D11Y6	20	500
ATV630U40M3	-	ATV630D11S6X ATV630D15Y6	25	1,000
-	ATV630D11N4(Z), ATV650D11N4(E)		30	1,000
-	_	ATV630D15S6X ATV630D18Y6	30	1,000
ATV630U55M3	-	ATV630D18S6 ATV630D22Y6	35	1,500
_	ATV630D15N4(Z), ATV650D15N4(E)	ATV630D22S6 ATV630D30Y6	40	1,500
ATV630U75M3	_	_	45	2,000
_	ATV630D18N4(Z), ATV650D18N4(E)	-	50	2,000
ATV630D11M3	ATV630D22N4(Z), ATV650D22N4(E)	ATV630D30S6 ATV630D37Y6	60	2,000
-	-	ATV630D37S6 ATV630D45Y6	70	2,000
ATV630D15M3	ATV630D30N4(Z), ATV650D30N4(E)	ATV630D45S6 ATV630D55Y6	80	2,000
-	ATV630D37N4(Z), ATV650D37N4(E)		90	2,500
ATV630D18M3 ATV630D22M3	ATV630D45N4(Z), ATV650D45N4(E)	_	100	2,500
-	-	ATV630D55S6 ATV630D75Y6	110	2,500
_	ATV630D55N4(Z), ATV650D55N4(E)	ATV630D75S6 ATV630D90Y6	150	3,500
ATV630D30M3	_	-	175	5,000
ATV630D37M3 ATV630D45M3	ATV630D75N4(Z), ATV650D75N4(E) ATV630D90N4(Z), ATV650D90N4(E)	-	200	5,000
_	ATV630C11N4	_	250	6,500
ATV630D55M3	ATV630C13N4	- • (315	8,000
ATV630D75M3	ATV630C16N4	-	350	9,000
_	ATV630C22N4(MN)	-	500	12,000
_	ATV630C25N4(MN) ATV630C31N4(MN)	~ O	600	15,000

Chapter 3Drive Mounting

What Is in This Chapter?

This chapter contains the following topics:

Topic	Page
Mounting Conditions	98
Derating Curves	107
Mounting Procedures	116



Mounting Conditions

Before You Begin

Conductive foreign objects, dust or liquids or damaged parts may cause parasitic voltage.

A A DANGER

ELECTRIC SHOCK CAUSED BY FOREIGN OBJECTS OR DAMAGE

- Do not use damaged products.
- Keep foreign objects such as chips, screws or wire clippings from getting into the product.
- Verify correct seat of seals and cable entries in order to avoid deposits and humidity.

Failure to follow these instructions will result in death or serious injury.

The temperature of the products described in this manual may exceed 80 °C (176 °F) during operation.

WARNING

HOT SURFACES

- Ensure that any contact with hot surfaces is avoided.
- Do not allow flammable or heat-sensitive parts in the immediate vicinity of hot surfaces.
- · Verify that the product has sufficiently cooled down before handling it.
- Verify that the heat dissipation is sufficient by performing a test run under maximum load conditions.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Power Drive Systems (PDS) can generate strong local electrical and magnetic fields. This can cause interference in electromagnetically sensitive devices.

A WARNING

ELECTROMAGNETIC FIELDS

- Keep persons with electronic medical implants, such as pacemakers, away from the equipment.
- Do not place electromagnetically sensitive devices in the vicinity of the equipment.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Attaching A Label With Safety Instructions

A label kit is provided with the drive.

Step	Action						
1	Observe the safety regulations in the target country						
2	Select the label suitable for the target country						
3	Attach the label to the front of the device so that it is clearly visible. Below is the English version. The lal can vary depending on the frame size of the product.						
	DANGER ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH.						
	To service, remove all power. - Wait 15 minutes - Verify no voltage is present.						
	Failure to comply will result in death or serious injury						
	NOTE: Products used in Canada according to CSA C22.2 no.274 must comply with the requirement defined by the Canadian Advisory council of Electrical Safety (CACES). It defines that dual language (French and English) safety labeling is required on all products for use in Canada. To fulfill this requirement, add the French language safety label on the front panel of the product.						

Mounting Types


This table shows the possible mounting types and the resulting IP degree of protection.

Mountin	Mounting Figure						
Туре	Description						
-	Enclosed with flange-mounting kit	This mounting is used to reduce the power dissipated in the enclosure by locating the power section outside the enclosure.					
A	Individual IP21 and IP55	This mounting type requires the dedicated flange-mounting kit (not available for ATV•30•••S6• and ATV•30•••Y6). Refer to www.schneider-electric.com NOTE: Use ProClima software available on www.schneider-electric.com to support you to integrate Altivar Process in an enclosure.					
		Frame sizes 1, 2, 3, 3S and 5S: a ≥ 100 mm (3.9 in.) Frame sizes 4, 5 and 6: a ≥ 110 mm (4.33 in.) Frame size 7, 3Y, 5Y, FS1, FS2, A, B, C, FSA and FSB: no restriction of clearance					

Mounting		Figure
Туре	Description	
В	Side by side IP20	Frame sizes 1, 2, 3, 3S, 3Y, 5S, 5Y and 7: possible, regardless of the number of drives installed side by side Frame sizes 4 and 5: possible, 2 drives only Frame size 6: only at ambient temperature lower than 40 °C (104 °F)
С	Individual IP20	Frame sizes 1, 2, 3, 3S, 3Y, 5S, 5Y and 7: no restriction of clearance
		Frame sizes 4, 5 and 6: $a \ge 110$ mm (4.33 in.)

coin coin

Clearances and Mounting Position - Wall Mounting



Minimum clearance regarding the drive frame size

Frame Size	X1	X2	Х3
15, 3S, 3Y, 5S, 5Y	≥ 100 mm (3.94 in.)	≥ 100 mm (3.94 in.)	≥ 10 mm (0.39 in.)
AC	≥ 100 mm (3.94 in.)	≥ 100 mm (3.94 in.)	≥ 10 mm (0.39 in.)
6	≥ 250 mm (10 in.)	≥ 250 mm (10 in.)	≥ 100 mm (3.94 in.)
7	≥ 200 mm (7.87 in.)	≥ 150 mm (5.90 in.)	≥ 10 mm (0.39 in.)

X1: free space in top of the drive

X2: free space in lower part of the drive

X3: free space in front of the drive.

Frame Size 7 Drive - IP23 Mounting in Enclosure

Install the drive as described below:

Step	Action	Drawing and Comments
1	Install the drive on an enclosure baseplate	
2	Install the DC choke in accordance with the mounting instructions (see page 122).	
3	Install the UL Type 1, IP21 kit ④ for attaching the power cables, in accordance with the mounting instructions supplied with the kit	
4	Extend the IP54 duct ① between the upper outlet of the DC choke and the top of the enclosure ②. Fixing points are provided for this purpose on the top of the DC choke.	ATV A ATV A
5	Add a plate ③ approximately 150 mm (6 in.) from the top of the enclosure over the air outlet opening to prevent foreign bodies falling into the drive cooling duct.	The air inlet can be via a grille on the lower part of front panel of the enclosure door, in accordance with the required flow rates given in the above table.

NOTE:

- If the air in the power circuit is totally evacuated to the outside, very few power is dissipated inside the enclosure.
- Connect all the additional metal parts to ground using the strips.
- The design of the UL Type 1, IP21 kit 4 (to be ordered as an option) is based on the same principle as the DC choke, and has an IP54 duct to help guide the incoming air.

Frame Size 7 Drive - IP54 Mounting in Enclosure

Install the drive as described in the IP23 mounting section with the following additional points to obtain an IP54 enclosure:

Step	Action	Drawing and Comments
1	Do not make an air outlet hole for the control section. Do not make an air inlet hole in the enclosure door. In the power section, the air will enter through the lower part of the enclosure via a plinth added for this purpose.	
2	Install the IP21 UL Type 1 kit ①, if required in accordance with the mounting instructions supplied with the kit	
3	Add an enclosure baseplate ② designed to provide IP54 protection around the power cables.	ATV ATV
4	Add an air evacuation duct ③ between the baseplate and the duct of the UL type 1 conformity kit. The conformity kit enables an extension duct to be mounted. Drill a hole in the base of the enclosure to allow air to enter. Place seals around the duct that has been added to maintain IP54 protection.	
5	Add a 200 mm plinth ④ at the lower part of the enclosure with grilles to allow air to enter.	
6	Use the dissipated power table below to calculate the enclosure dimensions.	<u> </u>

NOTE:

• Connect all the additional metal parts to ground using the strips.


Power dissipated by the control section inside the enclosure

These levels of power dissipation are given for operation at nominal load and for the factory-set switching frequency.

Catalog Number	Dissipated Power in W (1)	
ATV630C22N4	451	
ATV630C25N4	606	
ATV630C31N4	769	
(1) Add 7W to this va	alue for each option card added	
		• • • • • • • • • • • • • • • • • • • •
		A~'O'
		EAV64301 04/2020

102

Clearances and Mounting Position - Floor Standing



General Mounting Instructions

- Mount the device in a vertical position. This is required for cooling the device.
- · Attach it on the mounting surface in compliance with standards, using 4 screws with captive washer according to the table given in Mounting Procedures (see page 116).
- The use of washers is required with all mounting screws.
- Tighten the fixation screws.
- Do not mount the device close to heat sources.
- • Avoid environmental effects like high temperatures and high humidity as well as dust, dirt and conductive gases.
- Adhere to the minimum installation distances for required cooling.
- Do not mount the device on flammable materials.
- Install the Altivar Process floor standing drive on a solid, vibration-free ground.

Power Dissipated For Enclosed Drives and Required Air Flow - Wall Mounting

Catalog Number (1)	Frame Size		ssipated at ormal Duty			sipated at eavy Duty		Minimum air flow rate required	
		Forced Cooled Area	Natural Cooled Area	Total	Forced Cooled Area	Natural Cooled Area	Total		
		(W)	(W)	(W)	(W)	(W)	(W)	(m ³ /ho ur)	(ft ³ /min
ATV630U07M3	1	33	26	59	15	26	41	38	22
ATV630U15M3	1	61	29	90	28	27	55	38	22
ATV630U22M3	1	85	31	116	54	29	83	38	22
ATV630U30M3	1	118	33	151	83	32	115	38	22
ATV630U40M3	1	163	37	200	111	33	144	38	22
ATV630U07N4	1	24	26	50	14	25	39	38	22
ATV630U15N4	1	47	27	74	21	26	47	38	22
ATV630U22N4	1	69	29	98	40	27	67	38	22
ATV630U30N4	1	89	30	119	59	28	87	38	22
ATV630U40N4	1	111	31	142	79	29	108	38	22
ATV630U55N4	1	166	34	200	106	31	137	38	22
ATV630U55M3	2	203	52	255	139	47	186	103	61
ATV630U75N4	2	213	46	259	150	43	193	103	61
ATV630D11N4	2	297	52	349	186	47	233	103	61
ATV630U22S6X	2	57	52	109	38	51	89	103	61
ATV630U40S6X	2	78	54	132	43	53	96	103	61
ATV630U55S6X	2	111	56	167	79	54	133	103	61
ATV630U75S6X	2	144	59	203	99	56	155	103	61
ATV630D11S6X	2	188	63	251	136	59	195	103	61
ATV630D15S6X	2	243	65	308	194	62	256	103	61
ATV630U75M3	3	353	75	428	247	70	317	215	127
ATV630D11M3	3	532	86	618	298	76	374	215	127
ATV630D15N4	3	424	76	500	260	70	330	215	127
ATV630D18N4	3	534	82	616	369	76	445	215	127
ATV630D22N4	3	583	87	670	451	82	533	215	127
ATV630D18S6	3S	386	82	468	314	78	392	330	194
ATV630D22S6	3S	507	86	593	394	81	475	330	194
ATV630U22Y6	3Y	44	67	111	34	67	101	330	194
ATV630U30Y6	3Y	59	69	128	44	67	111	330	194
ATV630U40Y6	3Y	77	69	146	59	69	128	330	194
ATV630U55Y6	3Y	104	70	174	77	69	146	330	194
ATV630U75Y6	3Y	139	72	211	104	70	174	330	194
ATV630D11Y6	3Y	202	75	277	139	72	211	330	194
ATV630D15Y6	3Y	278	78	356	202	75	277	330	194
ATV630D18Y6	3Y	385	82	467	278	78	356	330	194
ATV630D22Y6	3Y	474	86	560	385	82	467	330	194
ATV630D30Y6	3Y	557	90	647	474	86	560	330	194
ATV630D15M3	4	589	112	701	412	100	512	240	141
ATV630D18M3	4	737	123	860	527	112	639	240	141
	1	1	1	_		l		L	l

⁽¹⁾ Size 1...5 drives: Including catalog numbers ATV630•••N4Z.

⁽²⁾ First value is the power dissipated at nominal current in the forced cooled area of the drive. The second value is the power dissipated at nominal current in the natural cooled area, value used in case of installation using the flange-mounting kit (not available for ATV630•••S6• and ATV630•••Y6), separate hot and control part in a cabinet. If the drive is installed in a standard cabinet, the sum of both values is to be taken into account.

Catalog Number (1)	Frame Size		issipated at			issipated at leavy Duty		Minimun	n air flow uired
		Forced Cooled Area	Natural Cooled Area	Total	Forced Cooled Area	Natural Cooled Area	Total		
		(W)	(W)	(W)	(W)	(W)	(W)	(m ³ /ho ur)	(ft ³ /min
ATV630D22M3	4	873	134	1,007	641	123	764	240	141
ATV630D30N4	4	730	113	843	485	101	586	240	141
ATV630D37N4	4	908	122	1,030	661	113	774	240	141
ATV630D45N4	4	1,078	132	1,210	780	123	903	240	141
ATV630D30M3	5	1,077	169	1,246	747	147	894	295	174
ATV630D37M3	5	1,407	189	1,596	1,013	169	1,182	295	174
ATV630D45M3	5	1,694	208	1,902	1,226	188	1,414	295	174
ATV630D55N4	5	1,073	155	1,228	776	143	919	295	174
ATV630D75N4	5	1,601	184	1,785	987	156	1,143	295	174
ATV630D90N4	5	1,899	205	2,104	1,364	185	1,549	295	174
ATV630D30S6	5S	471	105	576	385	100	485	406	239
ATV630D37S6	5S	608	114	722	480	106	586	406	239
ATV630D45S6	5S	747	121	868	616	113	729	406	239
ATV630D55S6	5S	991	136	1127	727	120	847	406	239
ATV630D75S6	5S	1,240	148	1,388	996	136	1,132	406	239
ATV630D37Y6	5Y	572	116	688	417	108	525	406	239
ATV630D45Y6	5Y	719	123	842	572	116	688	406	239
ATV630D55Y6	5Y	881	131	1012	719	123	842	406	239
ATV630D75Y6	5Y	1,106	144	1250	848	132	980	406	239
ATV630D90Y6	5Y	1,472	162	1,634	1,106	144	1,250	406	239
ATV630D55M3	6	1,898	310	2,208	1,485	284	1,769	600	353
ATV630D75M3	6	2,865	362	3,227	1,903	310	2,213	600	353
ATV630C11N4	6	2,318	320	2,638	1,795	292	2,087	600	353
ATV630C13N4	6	2,638	349	2,987	2,116	320	2,436	600	353
ATV630C16N4	6	3,424	388	3,812	2,651	350	3,001	600	353
ATV630C22N4	7A	4,508	706	5,214	3,120	615	3,735	860	506
ATV630C22N4MN	7A	4,532	707	5,239	3,173	615	3,788	860	506
ATV630C25N4	7B	5,063	920	5,983	3,643	850	4,493	1,260	742
ATV630C31N4	7B	6,313	1,019	7,332	4,517	920	5,437	1,260	742
ATV630C25N4MN	7B	5,124	920	6,044	3,692	850	4,542	1,260	742
ATV630C31N4MN	7B	6,287	1,019	7,306	4,522	919	5,441	1,260	742

⁽¹⁾ Size 1...5 drives: Including catalog numbers ATV630•••N4Z.


⁽²⁾ First value is the power dissipated at nominal current in the forced cooled area of the drive. The second value is the power dissipated at nominal current in the natural cooled area, value used in case of installation using the flange-mounting kit (not available for ATV630•••S6• and ATV630•••Y6), separate hot and control part in a cabinet. If the drive is installed in a standard cabinet, the sum of both values is to be taken into account.

Power Dissipated For Enclosed Drives and Required Air Flow - Floor Standing

Catalog Number ATV630 and ATV650	Power Dissipated in Normal Duty			Power Dissipated in Normal Duty			Minimum Air Flow Rate	
	Forced Cooled Area	Natural Cooled Area	Total	Forced Cooled Area	Natural Cooled Area	Total	Required	
	(W)	(W)	(W)	(W)	(W)	(W)	(m ³ /hour)	(ft ³ /min)
C11N4F	2,032	380	2,412	1,621	300	1,921	720	2,032
C13N4F	2,542	450	2,992	2,030	360	2,390	720	2,542
C16N4F	3,258	560	3,818	2,540	420	2,960	720	3,258
C20N4F	3,591	580	4,171	2,796	430	3,226	1,300	3,591
C25N4F	4,713	730	5,443	3,604	520	4,124	1,300	4,713
C31N4F	6,405	990	7,395	4,705	680	5,385	1,300	6,405

Air flow Cooling Diagrams - Floor Standing

These diagrams show the cooling air flow.




Derating Curves


Description

Derating curves for the nominal drive current (In) as a function of temperature and switching frequency. Refer to the Mounting Conditions chapter *(see page 99)* for the mounting types description.


Frame Size 1 - 200...240 V




Frame Size 1 - 380...480 V




Frame Size 2 - 200...240 V




Frame Size 2 - 380...480 V




Frame Size 2 - 600 V




Frame Size 3 - 200...240 V




Frame Size 3 - 380...480 V




Frame Size 3S and 3Y - 600 V and 500...690 V




Frame Size 4 - 200...240 V




Frame Size 4 - 380...480 V




Frame Size 5 - 200...240 V




Frame Size 5 - 380...480 V -




Frame Size 5S and 5Y - 600 V and 500...690 V




Frame Size 6 - 200...240 V and 380...480 V




Frame Size 7A - 380...480 V - 220 kW



Frame Size 7B - 380...480 V - 250 kW




Frame Size 7B - 380...480 V - 315 kW




112

Frame Size A up to ATV650D11N4




Frame Size A, ATV650D15N4 to D22N4




Frame Size B



Frame Size C




Floor Standing Drives - All Frame Sizes - 380...440 V - Normal Duty



114

Floor Standing Drives - All Frame Sizes - 380...440 V - Heavy Duty




Mounting Procedures

Mounting Screws


Frame Size	Screw diameter	Hole diameter
1	5 mm (0.2 in)	6 mm (0.24 in)
2	5 mm (0.2 in)	6 mm (0.24 in)
3	5 mm (0.2 in)	6 mm (0.24 in)
3S	5 mm (0.2 in)	6 mm (0.24 in)
3Y	5 mm (0.2 in)	6 mm (0.24 in)
4	6 mm (0.24 in)	7 mm (0.28 in)
5	8 mm (0.31 in)	9 mm (0.35 in)
5S	8 mm (0.31 in)	9 mm (0.35 in)
5Y	8 mm (0.31 in)	9 mm (0.35 in)
6	10 mm (0.4 in)	11.5 mm (0.45 in)
7	10 mm (0.4 in)	11.5 mm (0.45 in)
Α	5 mm (0.2 in)	6 mm (0.24 in)
В	8 mm (0.31 in)	9 mm (0.35 in)
С	10 mm (0.4 in)	11.6 mm (0.45 in)
FS1	12 mm (0.47 in)	13 mm (0.51 in)
FS2	12 mm (0.47 in)	13 mm (0.51 in)
FSA	10 mm (0.4 in)	12.5 mm (0.49 in)
FSB	10 mm (0.4 in)	12.5 mm (0.49 in)

Mounting Procedure For Frame Sizes 1 to 3, 200...240 V and 380...480 V, IP21 Drives, WITHOUT Marking on The Upper Side of The Top Cover



Perform the following instructions


Step	Action	
1	Unscrew the 4 screws attaching the front cover	
2	Slide down the front cover	
3	Pull the front cover and remove it	• • • • • • • • • • • • • • • • • • • •



Perform the following instructions


Step	Action
4	Pull the top cover from back to front.
5	Remove the top cover (see the video).
6	Attach the drive on the mounting surface using the screws with captive washer, according to the table above (see page 116).
7	Refit the top cover to help prevent extra parts to fall into the drive during wiring operation or if IP21 degre of protection is requested.

Mounting Procedure For Frame Sizes 1 to 3, 200...240 V and 380...480 V, IP21 Drives, WITH Marking size, on The Upper Side of The Top Cover



Perform the following instructions


Step	Action
1	Unscrew the 4 screws attaching the front cover
2	Slide down the front cover
3	Pull the front cover and remove it



Perform the following instructions

Perform	a the following instructions	
Step	Action	
4	Push the top cover from front to back	
5	Remove the top cover	
6	Attach the drive on the mounting surface using the screws with captive washer, according to the table above (see page 116).	
7	Refit the top cover to help prevent extra parts to fall into the drive during wiring operation or if IP21 degree of protection is requested.	


Mounting Procedure For Frame Sizes 3S and 5S, for 600 V Supply Mains



Perform the following instructions


Step	Action
1	Unscrew the 4 screws attaching the lower front cover.
2	Remove the lower front cover to access the lower fixing holes.

Mounting Procedure For Frame Sizes 4 and 5, for 200...240 V and 380...480 V Supply Mains, IP21 Drives



Perform the following instructions

Step	Action
1	Unscrew the 6 screws (frame size 4) or the 8 screws (frame size 5) attaching the front and bottom covers
2	Remove the covers



Perform the following instructions

Step	Action
1	For Size 5 products, unscrew the 2 screws underneath the top cover
2	Slide the top cover from back to front
3	Remove the top cover
4	Screw the drive on the mounting surface using 4 screws with captive washer, according to the table above (see page 116).
5	Refit the top cover on the drive.

Mounting Procedure For Frame Sizes 3Y and 5Y, Frame Sizes 1...5 for cabinet integration (ATV630•••N4Z), and Frame Sizes 6 and 7


NOTE: Due to accessible live parts on their lower part, these drives must be installed in enclosures or located behind enclosures or barriers, which comply at least with the requirements of IP2•, as per IEC61800-5-1.

o its Mounting the drive does not require preliminary dismantling operation. Simply mount the drive to its support using the 4 screws with captive washer, according to the table above (see page 116).

120


Installing the EMC on Frame Sizes 3Y

Install the EMC plate supplied as described below. Tighten the 3 x M5 screws to 2.6 N·m (23 lbf.in)



Installing the EMC on Frame Sizes 5Y


Install the EMC plate supplied as described below. Tighten the 2 x M8 screws to 7.3 N·m (65 lbf.in)



Installing the DC choke on Frame Sizes 7 Drives

This must be performed after mounting the drive and before wiring it. During installation, ensure that no liquid, dust or conductive objects fall into the drive.

Perform the following instructions to install the DC chokes:



Step	Action
Step 5	Action Mount the cover ④ on the housing and secure it with the nuts ⑤ provided.
	Mount panels © and ⑦ using the screws provided. Tighton the M6 put to 5.5 Nm (49.7 lb in)
-	Tighten the M6 nuts to 5.5 N·m (48.7 lb.in).
6	Refit all the drive covers. Tighten the M5 nuts to 3.5 N·m (30.9 lb.in).

NOTE:

- Once the choke has been installed, the degree of protection of the top of the drive is IP31.
- For ATV630 ••••• MN products, no DC choke housing is provided. Please order separately your Line choke.

Mounting Procedure For Frame Sizes A, B and C

Mounting the drive does not require preliminary dismantling operation. Simply mount the drive to its support using the 4 screws with captive washer, according to the table above (see page 116).

Mounting Procedure for Floor Standing Drives

Installation and mounting procedures of the floor standing drives are described in the dedicated instruction sheet NVE57369 delivered with these drives and available on schneider-electric.com.



Chapter 4 **Drive wiring**

What Is in This Chapter?

This chapter contains the following topics:

Topic	Page
Wiring Instructions	126
Specific Wiring Instructions For Wall Mounting Drives	131
Specific Wiring Instructions For Floor Standing Drives	132
Dimensioning Of Power Part Cables For Floor Standing Drives	133
Cable Length Instructions	134
General Wiring Diagrams	136
Output Relay with Inductive AC Loads	139
Output Relay with Inductive DC loads	139
Digital Inputs Wiring Depending on Sink / Source Switch Configuration	141
Characteristics of the Power Part Terminals	143
Wiring The Power Part	149
Electromagnetic Compatibility	169
Operation on an IT or Corner Grounded System	171
Disconnecting The Built-in EMC Filter	172
Arrangement and Characteristics of Control Block Terminals and Communication and I/O Ports	177
Control Terminals Electrical Data	179
Wiring The Control Part	182



Wiring Instructions

General Instructions

The entire installation procedure must be performed without voltage present.

A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

Read and understand the instructions in **Safety Information** chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.

Drive systems may perform unexpected movements because of incorrect wiring, incorrect settings, incorrect data or other errors.

WARNING

UNANTICIPATED EQUIPMENT OPERATION

- Carefully install the wiring in accordance with the EMC requirements.
- Do not operate the product with unknown or unsuitable settings or data.
- Perform a comprehensive commissioning test.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Unsuitable settings or unsuitable data or unsuitable wiring may trigger unintended movements, trigger signals, damage parts and disable monitoring functions.

WARNING

UNANTICIPATED EQUIPMENT OPERATION

- Only start the system if there are no persons or obstructions in the zone of operation.
- Verify that a functioning emergency stop push-button is within reach of all persons involved in the operation.
- Do not operate the drive system with unknown settings or data.
- Verify that the wiring is appropriate for the settings.
- Never modify a parameter unless you fully understand the parameter and all effects of the modification.
- When commissioning, carefully run tests for all operating states, operating conditions and potential error situations.
- Anticipate movements in unintended directions or oscillation of the motor.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

A A DANGER

HAZARD OF FIRE OR ELECTRIC SHOCK

- Wire cross sections and tightening torques must comply with the specifications provided in this
 document
- If you use flexible multi-wire cables for a connection with a voltage higher than 25 Vac, you must use ring type cable lugs or wire ferrules, depending on the connection.

Failure to follow these instructions will result in death or serious injury.

The product has a leakage current greater than 3.5 mA. If the protective ground connection is interrupted, a hazardous touch current may flow if the product is touched.

A A DANGER

ELECTRIC SHOCK CAUSED BY HIGH LEAKAGE CURRENT

• Verify compliance with all local and national electrical code requirements as well as all other applicable regulations with respect to grounding of the entire drive system.

Failure to follow these instructions will result in death or serious injury.

A A DANGER

INSUFFICIENT PROTECTION AGAINST OVERCURRENTS CAN CAUSE FIRE OR EXPLOSION

- Use properly rated overcurrent protection devices.
- Use the fuses/circuit breakers specified.
- Do not connect the product to a supply mains whose prospective short circuit current rating (current that flows during a short circuit) exceeds the specified maximum permissible value.
- When rating the upstream mains fuses and the cross sections as well as the lengths of the mains cables, take into account the minimum required prospective short-circuit current (Isc). Refer to the Upstream Protection Device section.
- If the minimum required prospective short-circuit current (Isc) is not available, apply the instructions given in the section below.

Failure to follow these instructions will result in death or serious injury.

The specified maximum permissible values and products for IEC compliance are specified in the catalog. The specified maximum permissible values and products for UL/CSA compliance are specified in the annex provided with the drive.

Cable Characteristics

Only use cables with insulator heat resistance of 75°C (167°F) min.

If you are using cables longer than 150 m (492 ft) between the drive and the motor, add output filters (for more details refer to the catalog).

Use a shielded cable to meet the requirements of Category C2 or C3 according to the standard IEC 61800-3, except when using a sinus filter. In this case, the use of a non-shielded motor cable is possible.

To limit the currents in common mode, use common mode output filters (ferrite) in order to reduce the circulating currents in the motor windings.

Standard linear capacity cables can be used with Altivar Process. Use of cables with lower linear capacity could increase cable length performances.

The overvoltage limitation function [Motor surge limit.] 5 V L enables you to increase the cable length while decreasing the torque performances (refer to Programming manual). (see page 9)

Power Part Cables Stripping lengths



Catalog Number and Frame Size [•] (1)		Cable Stripping Length	
		Input (Supply Mains)	Output (Motor)
		mm (in.)	mm (in.)
ATV630U07M3U40M3	[1]	11 ± 1 (0.43 ± 0.04)	11 ± 1 (0.43 ± 0.04)
ATV630U07N4U55N4	[1]	11 ± 1 (0.43 ± 0.04)	11 ± 1 (0.43 ± 0.04)
ATV630U55M3	[2]	11 ± 1 (0.43 ± 0.04)	11 ± 1 (0.43 ± 0.04)
ATV630U75N4D11N4	[2]	11 ± 1 (0.43 ± 0.04)	11 ± 1 (0.43 ± 0.04)
ATV630U22S6XU75S6X, D11S6XD15S6X	[2]	11 ± 1 (0.43 ± 0.04)	11 ± 1 (0.43 ± 0.04)
ATV630U22Y6U75Y6, D11Y6D15Y6	[3Y]	20 ± 2 (0.79 ± 0.08)	20 ± 2 (0.79 ± 0.08)
ATV630U75M3D11M3	[3]	20 ± 2 (0.79 ± 0.08)	20 ± 2 (0.79 ± 0.08)
ATV630D15N4D22N4	[3]	20 ± 2 (0.79 ± 0.08)	20 ± 2 (0.79 ± 0.08)
ATV630D18S6, D22S6	[3S]	20 ± 2 (0.79 ± 0.08)	20 ± 2 (0.79 ± 0.08)
ATV630D18Y6D30Y6	[3Y]	32 ± 3 (1.26 ± 0.12)	32 ± 3 (1.26 ± 0.12)
ATV630D15M3D22M3	[4]	26 ± 2 (1.02 ± 0.08)	26 ± 2 (1.02 ± 0.08)
ATV630D30N4D45N4	[4]	26 ± 2 (1.02 ± 0.08)	26 ± 2 (1.02 ± 0.08)
ATV630D30M3D45M3	[5]	32 ± 3 (1.26 ± 0.12)	32 ± 3 (1.26 ± 0.12)
ATV630D55N4D90N4	[5]	32 ± 3 (1.26 ± 0.12)	32 ± 3 (1.26 ± 0.12)
ATV630D30S6D75S6	[5S]	32 ± 3 (1.26 ± 0.12)	32 ± 3 (1.26 ± 0.12)
ATV630D37Y6D90Y6	[5Y]	32 ± 3 (1.26 ± 0.12)	32 ± 3 (1.26 ± 0.12)
ATV650U07N4D11N4	[A]	11 ± 1 (0.43 ± 0.04)	11 ± 1 (0.43 ± 0.04)
ATV650U07N4ED11N4E	[A]	11 ± 1 (0.43 ± 0.04)	11 ± 1 (0.43 ± 0.04)
ATV650D15N4, D18N4, D22N4	[A]	20 ± 2 (0.79 ± 0.08)	20 ± 2 (0.79 ± 0.08)
ATV650D15N4ED22N4E	[A]	17 ± 2 (0.67 ± 0.08)	20 ± 2 (0.79 ± 0.08)
ATV650D30N4, D37N4, D45N4	[B]	26.2 ± 2 (1.03 ± 0.08)	26.2 ± 2 (1.03 ± 0.08)
ATV650D30N4E, D37N4E, D45N4E	[B]	21.5 ± 2.5 (0.85 ± 0.1)	21.5 ± 2.5 (0.85 ± 0.1)
ATV650D55N4, D75N4, D90N4	[C]	32 ± 3 (1.27 ± 0.12)	32 ± 3 (1.27 ± 0.12)
ATV650D55N4E, D75N4E, D90N4E	[C]	32 ± 3 (1.27 ± 0.12)	32 ± 3 (1.27 ± 0.12)
(1) Size 15 drives: Including catalog numbers ATV630•••N4Z.			

Control Part

A WARNING

UNANTICIPATED EQUIPMENT OPERATION

Verify that the digital and analog inputs and outputs are wired with the shielded, twisted-pair cables specified in the present manual.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

- Keep the control circuits away from the power cables. For digital and analog inputs/outputs, use shielded twisted cables with a pitch of 25...50 mm (1 in. and 2 in.)
- It is advisable to use cable ends, available on <u>www.schneider-electric.com.</u>

NOTE:

- Analog inputs and outputs Alx, AQx, COM use shielded cable and each analog input and output has its own COM line.
- Each PTC input has its own COM line, not shared with other Inputs/Outputs.
- All digital inputs DIx use one common 24V line in source mode or one common COM line in sink mode.
 This 24V or COM line is used only for DIx.
- Safe torque off inputs STOA / STOB use shielded cables and one common 24V line. This 24V line is used only for STOA / STOB.

Residual Current Device

Direct current can be introduced in the protective ground conductor of this drive. If a residual current device (RCD / GFCI) or a residual current monitor (RCM) is used for additional protection against direct or indirect contact, the following specific types must be used:

A WARNING

DIRECT CURRENT CAN BE INTRODUCED INTO THE PROTECTIVE GROUND CONDUCTOR

- Use a Type A or Type F Residual Current Device (RCD / GFCI) or a Residual Current Monitor (RCM) for single-phase drives connected to a phase and to the neutral conductor.
- Use a Type B Residual Current Device (RCD / GFCI) or a Residual Current Monitor (RCM) that has approval for use with frequency inverters and is sensitive to all types of current for three-phase devices and for single-phase devices not connected to a phase and the neutral conductor.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Further conditions for use of a residual current device:

- The drive has an increased leakage current at the moment power is applied. Use a residual current device (RCD / GFCI) or a residual current monitor (RCM) with a response delay.
- High-frequency currents must be filtered.

Due to high leakage current in standard operation, it is advisable to choose at least a 300 mA device.

If the installation requires a residual current device less than 300 mA, it can be possible to use a device lower than 300 mA by changing the IT switch position (drive sizes 5S and 5Y) or by removing the screws (drive sizes 1...7) according to the instructions given in the Operation on an IT System section (see page 171).

If the installation includes several drives, provide one residual current device per drive.

Equipment Grounding

NOTICE

DESTRUCTION DUE TO INCORRECT WIRING

• Before switching on and configuring the product, verify that it is properly wired.

Failure to follow these instructions can result in equipment damage.

♠ ♠ DANGER

ELECTRIC SHOCK CAUSED BY INSUFFICIENT GROUNDING

- Verify compliance with all local and national electrical code requirements as well as all other applicable regulations with respect to grounding of the entire drive system.
- Ground the drive system before applying voltage.
- The cross section of the protective ground conductor must comply with the applicable standards.
- Do not use conduits as protective ground conductors; use a protective ground conductor inside the conduit.
- Do not consider cable shields to be protective ground conductors.

Failure to follow these instructions will result in death or serious injury.

Tighten the grounding screws according to the instructions given in the Ground Cables section (see page 143).

Connection Instructions

The product has a leakage current greater than 3.5 mA. If the protective ground connection is interrupted, a hazardous touch current may flow if the product is touched.

A DANGER

ELECTRIC SHOCK CAUSED BY HIGH LEAKAGE CURRENT

• Verify compliance with all local and national electrical code requirements as well as all other applicable regulations with respect to grounding of the entire drive system.

Failure to follow these instructions will result in death or serious injury.

DANGER


INSUFFICIENT PROTECTION AGAINST OVERCURRENTS CAN CAUSE FIRE OR EXPLOSION

- Use properly rated overcurrent protection devices.
- Use the fuses/circuit breakers specified.
- Do not connect the product to a supply mains whose prospective short circuit current rating (current that flows during a short circuit) exceeds the specified maximum permissible value.
- When rating the upstream mains fuses and the cross sections as well as the lengths of the mains cables, take into account the minimum required prospective short-circuit current (Isc). Refer to the Upstream Protection Device section.
- If the minimum required prospective short-circuit current (Isc) is not available, apply the instructions given in the section below.

Failure to follow these instructions will result in death or serious injury.

The specified maximum permissible values and products for IEC compliance are specified in the catalog. The specified maximum permissible values and products for UL/CSA compliance are specified in the annex provided with the drive.

- Ensure that the resistance to Ground is 1 Ohm or less.
- When grounding several drives, you must connect each one directly, as shown in the above figure.
- Do not loop Ground cables or connect them in series.





130

Specific Wiring Instructions For Wall Mounting Drives

Connection Instructions

The product has a leakage current greater than 3.5 mA. If the protective ground connection is interrupted, a hazardous touch current may flow if the product is touched.

A A DANGER

ELECTRIC SHOCK CAUSED BY HIGH LEAKAGE CURRENT

• Verify compliance with all local and national electrical code requirements as well as all other applicable regulations with respect to grounding of the entire drive system.

Failure to follow these instructions will result in death or serious injury.


🕰 🕰 DANGER

INSUFFICIENT PROTECTION AGAINST OVERCURRENTS CAN CAUSE FIRE OR EXPLOSION

- Use properly rated overcurrent protection devices.
- Use the fuses/circuit breakers specified.
- Do not connect the product to a supply mains whose prospective short circuit current rating (current that flows during a short circuit) exceeds the specified maximum permissible value.
- When rating the upstream mains fuses and the cross sections as well as the lengths of the mains cables, take into account the minimum required prospective short-circuit current (Isc). Refer to the Upstream Protection Device section.
- If the minimum required prospective short-circuit current (Isc) is not available, apply the instructions given in the section below.

Failure to follow these instructions will result in death or serious injury.

- Ensure that the resistance to Ground is 1 Ohm or less.
- When grounding several drives, you must connect each one directly, as shown in the above figure.
- Do not loop Ground cables or connect them in series.



Specific Wiring Instructions For Floor Standing Drives

Protective Grounding

There is a marked terminal (bar) inside the enclosure to connect the protective conductor. Furthermore there is a marked terminal (bar) to connect the protective grounding of the motor.

The product has a leakage current greater than 3.5 mA. If the protective ground connection is interrupted, a hazardous touch current may flow if the product is touched.


A A DANGER

ELECTRIC SHOCK CAUSED BY HIGH LEAKAGE CURRENT

• Verify compliance with all local and national electrical code requirements as well as all other applicable regulations with respect to grounding of the entire drive system.

Failure to follow these instructions will result in death or serious injury.

Connection Instructions



- Check whether the resistance of the protective grounding is 0.1 Ω or less.
- When several inverters need to be connected to the protective ground, each one must be connected directly to this protective ground as illustrated above.

Upstream Protective Device Information

A A DANGER

INSUFFICIENT PROTECTION AGAINST OVERCURRENTS CAN CAUSE FIRE OR EXPLOSION

- Use properly rated overcurrent protection devices.
- Use the fuses/circuit breakers specified.
- Do not connect the product to a supply mains whose prospective short circuit current rating (current that flows during a short circuit) exceeds the specified maximum permissible value.
- When rating the upstream mains fuses and the cross sections as well as the lengths of the mains cables, take into account the minimum required prospective short-circuit current (Isc). Refer to the Upstream Protection Device section.
- If the minimum required prospective short-circuit current (lsc) is not available, apply the instructions
 given in the section below.

Failure to follow these instructions will result in death or serious injury.

NOTE: The Floor standing drives include semiconductor fuses as standard (see page 83).

Dimensioning Of Power Part Cables For Floor Standing Drives

Cable Cross Sections

The recommended values for dimensioning the cable cross sections given in chapter Characteristics of the Power Part Terminals are reference values for multi-core copper power cables laid in air at a maximum ambient temperature of 40°C (104°F). Observe different ambient conditions and local regulations.

Types of Supply Mains Cables

Cable Type	Description
	Three-phase cable with sector-shaped conductors and reduced protective conductor.
	NOTE: Verify that the PE conductor complies with the requirements according to IEC 61439-1.
	Three-phase cable with round conductors and reduced protective conductor.
	NOTE: Verify that the PE conductor complies with the requirements according to IEC 61439-1.

Dimensioning of the Motor Cables

A A DANGER


ELECTRIC SHOCK DUE TO OVERLOAD ON MOTOR CABLES

- Verify that the protective ground conductor complies with the requirements specified in IEC 61439-1.
- Verify compliance of the motor cables with the specification of IEC 60034-25.

Failure to follow these instructions will result in death or serious injury.

The motor cables are dimensioned for the maximum continuous current. They apply to 0...100 Hz (up to 300 Hz the cable losses increase about 25 % because of the Skin-effect).

The IGBT modules cause high-frequent interferences which drain off more and more stronger to the ground potential with increasing motor cable length. As a result the line-conducted interferences to the mains increase. In case of too long motor cables the attenuation of the mains filters is not longer sufficient and the permitted interference limits are exceeded.



Types of Motor Cables

Cable Type	Description
	Symmetrically shielded cable with 3 phase conductors, symmetrically arranged PE conductor and a shield. NOTE: Verify that the PE conductor complies with the requirements according to IEC 61439-1. Example: 2YSLCY-JB
8	Symmetrically shielded cable with 3 phase conductors and a concentric PE conductor •••• as shield. NOTE: Verify that the PE conductor complies with the requirements according to IEC 61439-1. Example: NYCY / NYCWY
	Three-phase cable with round conductors and reduced protective conductor. NOTE: A separate PE conductor is required if the shield does not fulfill the requirements according to IEC 61439-1.

Cable Length Instructions

Long Cable Lengths Consequences

When drives are used with motors, a combination of fast switching transistors and long motor cables can even cause peak voltages up to twice the DC link voltage. This high peak voltage can cause premature aging of motor winding insulation which leads to motor breakdown.

The overvoltage limitation function will enable to increase the cable length while decreasing the torque performances.

Length Of Motor Cables

Because of the permitted mains disturbances, the allowed overvoltages at the motor, the occurring bearing currents and the permitted heat losses the distance between inverter and motor(s) is limited.


The maximum distance heavily depends on the used motors (insulation material), the type of motor cable used (shielded/unshielded), the cable laying (cable channel, underground installation...) as well as from the used options.

Dynamic Voltage Load Of The Motor

Overvoltages at the motor terminals result from reflection in the motor cable. Basically the motors are stressed with measurable higher voltage peaks from a motor cable length of 10 m. With the length of the motor cable also the value of overvoltage increases.

The steep edges of the switching impulses at the output side of the frequency inverter lead to a further load of the motors. The slew rate of the voltage is typically over 5 kV/µs but it decreases with the length of the motor cable

Load of the motor with overvoltage and slew rate when using conventional drive



L Length of motor cables in meters (feet)

Corrective Actions Overview

A number of simple measures can be taken to help enhance the motor life time:

- Specification of a motor designed for speed drive applications (IEC60034-25 B or NEMA MG1 Part 31 should be prescribed).
- Specification of drives that integrate voltage reflection superimposition software suppression. Refer to [Volt surge limit. opt] 5 a P parameter in the Programming manual (see page 9).
- Reduce to a minimum the distance between motor and drive.
- Use unshielded cables.
- Reduce the drive switching frequency (a reduction to 2.5 kHz is advisable.)

Preventive Measures Suitable for Wall Mounting Drives According to IEC60034-25

The preventive measures will depend on motor characteristics and cable length.

Motor cable length (unshielded cable)	Motor conforming to IEC60034-25	Motor NOT-conforming to IEC60034-25
1 m (3 ft) < L < 50 m (164 ft)	Filter not required	dV/dt filter
50 m (164 ft) < L < 100 m (328 ft)	Filter not required	Sinus filter
100 m (328 ft) < L < 300 m (984 ft)	Filter not required	Sinus filter
300 m (984 ft) < L < 500 m (1640 ft)	dV/dt filter	Sinus filter
500 m (1640 ft) < L < 1000 m (3281 ft)	Sinus filter	Sinus filter

NOTE: When calculating cable lengths for the purpose of guarding against these overvoltage situations, a shielded cable should count as twice the length of an unshielded cable. For example, if a shielded cable is 100 m (328 ft) in actual length, it should be considered to be equal to a 200 m (656 ft) length standard cable in the calculation.

NOTE: The FS drive is delivered with standard output filters. For motor cable lengths beyond 300 m (984 ft), refer to the ATV660 drive range (see page 9).


Additional Information

Further detailed technical information is available in the following white paper An Improved Approach for Connecting VSD and Electric Motors (998-2095-10-17-13AR0 EN) available on www.schneiderelectric.com.




General Wiring Diagrams

Control Block Wiring Diagram



(1) STO Safe Torque Off, (2) Analog Output, (3) Digital Input, (4) reference potentiometer (ex. SZ1RV1002), (5) Analog Input

Three-phase Power Supply - Diagram With Line Contactor Without Safety Function STO



(1) Line choke, if used.

(2) Use relay output R1 set to operating state Fault to switch Off the product once an error is detected.

all.colfi

Three-phase Power Supply - Diagram With Downstream Contactor

If a Run command is executed while the downstream contactor between the drive and the motor is still open, there may be residual voltage at the output of the drive. This can cause an incorrect estimation of the motor speed when the contacts of the downstream contactor are closed. This incorrect estimation of the motor speed can lead to unanticipated equipment operation or to equipment damage.

In addition, there may be overvoltage at the output of the drive if the power stage is still enabled when the downstream contactor between the drive and the motor opens.


A WARNING

UNANTICIPATED EQUIPMENT OPERATION OR EQUIPMENT DAMAGE

If a downstream contactor is used between the drive and the motor, verify the following:

- The contacts between the motor and the drive must be closed before a Run command is executed.
- The power stage must not be enabled when the contacts between the motor and the drive open.

Failure to follow these instructions can result in death, serious injury, or equipment damage.




- (1) Line choke, if used.
- (2) Use relay output R1 set to operating state Fault to switch Off the product once an error is detected.

Safety Function STO

All details related to the STO safety function activation are given in the ATV600 Embedded Safety Function Manual *EAV64334*.


Sensor Connection

It is possible to connect either 1 or 3 sensors on terminals Al2 or Al3.



Floor Standing Drive Circuit Diagram

The following diagram shows the typical wiring of the drive.



ATV •• 0 •• • N4F Altivar Process Floor standing drive

FUSE/CB External pre-fuse or circuit breaker to protect the mains cable

MS Built-in main switch, lockable in open position (only availble on IP54 drives)

T01 Control transformer 400 / 230 V AC

MF aR fuses for short-circuit shut-down if the electronic protective devices do not work properly

RFI Built-in RFI filter, considering category C3 according to EN 61800-3 Use in industrial environments

LC Line reactor to reduce the current harmonics on the mains caused by the DC link

REC Rectifier module(s)

INV Inverter module(s)

FC dv/dt filter choke to reduce the voltage load of the motor

CTRL Control panel with control block and further control components

M11 Fan in enclosure door

If the internal circuit breaker is open, the internal fans will not be supplied. If the door is not completely closed, the cooling system will not operate properly. This may cause the drive to trigger an overtemperature error.

NOTICE

OVERHEATING AND DAMAGE TO THE DRIVE SYSTEM

- Verify that the circuit breaker accessible inside the cabinet is always closed during operation.
- Verify that the door of the cabinet is always closed during operation.

Failure to follow these instructions can result in equipment damage.

NOTE: For a detailed wiring diagram of the Floor standing drive, contact Schneider Electric Services.

138


Output Relay with Inductive AC Loads

General

The AC voltage source must be of overvoltage category II (OVC II) according to IEC61800-5-1. If it is not the case an insulation transformer must be used.

Contactors with AC Coil

If controlled by relay, a resistor-capacitor (RC) circuit must be connected in parallel to the coil of the contactor, as shown on the drawing below.



(1) AC 250 Vac maxi.

Schneider Electric AC contactors have a dedicated area on the housing to plug easily the RC device. Refer to the Motor control and protection components catalog <u>MKTED210011EN</u> available on <u>se.com</u> to find the RC device to be associated with the contactor used.

Example: With a 48 Vac source, contactors <u>LC1D09E7</u> or <u>LC1DT20E7</u> have to be used with <u>LAD4RCE</u> voltage suppression device.

Other Inductive AC Loads


For other inductive AC loads...

- Use an auxiliary contactor connected on drive to control the load.
 Example: with a 48 Vac source, auxiliary contactors <u>CAD32E7</u> or <u>CAD50E7</u> with <u>LAD4RCE</u> voltage suppression device.
- When using a third party inductive AC load, request the supplier to provide information on the voltage suppression device, in order to avoid overvoltage above 375 V during relay opening.

Output Relay with Inductive DC loads

Contactors with DC Coil

If controlled by relay, a bidirectional transient voltage suppression (TVS) diode, also called transil, must be connected in parallel to the coil of the contactor, as shown on the drawing below.



- (1) DC 30 Vdc maxi.
- (2) TVS diode


Schneider Electric contactors with DC coil include the TVS diode. No additional device is required.

Refer to the Motor control and protection components catalogue <u>MKTED210011EN</u> available on <u>se.com</u> for more information.

Other Inductive DC Loads

Other inductive DC loads without embedded TVS diode must use one of the following voltage suppression device:

- A bidirectional TVS device as shown on the drawing above, defined by...
 - O TVS break-down voltage greater than 35 Vdc,
 - TVS clamping voltage V(TVS) less than 50 Vdc
 - TVS peak power dissipation greater than load rated current, I(load) x V(TVS).
 Example: with I(load) = 0.9 A and V(TVS) = 50 Vdc, TVS peak power must be greater than 45 W
 - TVS average power dissipation greater than the value calculated by the following 0.5 x I(load) x V(TVS) x load time constant x number of operation per second.
 Example: with I(load) = 0.9 A and V(TVS) = 50 Vdc, load time constant = 40 ms (load inductance divided by load resistance) and 1 operation every 3 s, the TVS average power dissipation must be greater than 0.5 x 0.9 x 50 x 0.04 x 0.33 = 0.3 W.
- A fly-back diode as shown in the drawing below.



- (1) DC 30 Vdc maxi.
- (2) Flyback diode

The diode is a polarized device. The fly-back diode must be defined by...

- a reverse voltage greater than 100 Vdc,
- a rated current greater than two times the load rated current,
- a thermal resistance: junction to ambient temperature (in K/W) less than 90 / (1.1 x I(load)) to operate at maximum 60°C (140°F) ambient temperature.

Example: with I(load) = 1.5 A, select a 100 V, 3 A rated current diode with a thermal resistance from junction to ambient less than $90 / (1.1 \times 1.5) = 54.5 \text{ K/W}$.

Using a flyback diode, the relay opening time will be longer than with a TVS diode.

NOTE: Use diodes with leads for easy wiring and keep at least 1 cm (0.39 in.) of leads at each side of the case of the diode for a correct cooling.

Digital Inputs Wiring Depending on Sink / Source Switch Configuration

About the Switch

WARNING

UNANTICIPATED EQUIPMENT OPERATION

- If the drive is set to SK or EXT, do not connect the 0 V terminal to ground or to protective ground.
- · Verify that accidental grounding of digital inputs configured for sink logic, caused, for example, by damage to the signal cables, cannot occur.
- Follow all applicable standards and directives such as NFPA 79 and EN 60204 for proper control circuit grounding practices.

Failure to follow these instructions can result in death, serious injury, or equipment damage.


The switch is used to adapt the operation of the logic inputs to the technology of the programmable controller outputs. To access the switch, follow the Access to control Terminals procedure (see page 182). The switch is located below the control terminals (see page 177).

- Set the switch to Source (factory setting) if using PLC outputs with PNP transistors.
- Set the switch to Ext if using PLC outputs with NPN transistors.

Wiring With Use of the Output Power Supply for the Digital Inputs


Switch set to SRC (Source) position





Switch set to SK (Sink) position





Wiring With Use of an External Power Supply for the Digital Inputs

DANGER


ELECTRIC SHOCK CAUSED BY INCORRECT POWER SUPPLY UNIT

The +24 Vdc supply voltage is connected with many exposed signal connections in the drive system.


• Use a power supply unit that meets the PELV (Protective Extra Low Voltage) requirements.

Failure to follow these instructions will result in death or serious injury.

Switch set to EXT (Sink External) position without functional isolation on digital inputs




Switch set to EXT (Sink External) position with functional isolation on digital inputs. This configuration requires the use of 2 external supply units.



NOTE:

- STO inputs are also connected by default on a 24 Vdc terminal. If the external power supply is switched off, the function STO will be triggered.
- • To avoid to trigger the STO function when switching-on the product, the external power supply must be previously switched on.

Switch set to SRC (Source) position



142

Characteristics of the Power Part Terminals

Description of the Power Terminals


Terminal	Function
PE or 🖶	Ground connection terminal
R/L1 S/L2 T/L3	AC supply mains
U/T1 V/T2 W/T3	Outputs to the motor

Ground Cables

Ground cable cross sections of input and output ground cables are the same as those given for the input and output cables. Minimum cross section of protective ground cable is 10 mm² (AWG 8) and 16 mm² (AWG 6) for AL cable.

Tightening torques according to frame size

- Frame sizes 1...3: 2.5 N·m (22.1 lb.in)
- Frame size 3S: 12 N·m (106.2 lb.in)
- Frame size 3Y:
 - O ATV•30U22Y6...U75Y6, ATV•30D11Y6: 3 N·m (26.5 lb.in)
 - O ATV•30D15Y6, D18Y6: 5.4 N·m (47.8 lb.in)
 - O ATV•30D22Y6, D30Y6: 12 N·m (106.2 lb.in)
- Frame size 4: 5 N·m (44.2 lb.in)
- Frame size 5: 25 N·m (221.3 lb.in)
- Frame sizes 5S and 5Y: 41 N·m (362.89 lb.in)
- Frame size 6:
 - o ①: 27 N·m (239 lb.in)
 - ②:13.5 N·m (119.5 lb.in)



• Frame size 7: 37.5...50.8 N·m (332...449 lb.in)

Frame Size 1

ATV630 (**)	Supply Terminals (L1, L2, L3)			Output Terminals (U, V, W)		
	Wire Cross Section		Tightening Torque	Wire Cross Section		Tightening Torque
	Minimum	Maximum (*)	Rated	Minimum	Maximum (*)	Rated
	mm² (AWG)	mm² (AWG)	N·m (lb.in)	mm² (AWG)	mm² (AWG)	N·m (lb.in)
U07••, U15••, U22••, U30N4, U40N4	2.5 (14)	6 (10)	1.3 (11.5)	2.5 (14)	6 (10)	1.3 (11.5)
U55N4, U30M3	2.5 (14)	6 (10)	1.3 (11.5)	4 (12)	6 (10)	1.3 (11.5)
U40M3	4 (12)	6 (10)	1.3 (11.5)	6 (10)	6 (10)	1.3 (11.5)

Only use cables with solid wires or rigid stranded wires.

Frame Size 2

ATV630 (**)	Supply Terminals (L1, L2, L3)			Output Terminals (U, V, W)		
	Wire Cross Section		Tightening Torque	Wire Cross Section		Tightening Torque
	Minimum	Maximum (*)	Rated	Minimum	Maximum (*)	Rated
	mm² (AWG)	mm² (AWG)	N·m (lb.in)	mm² (AWG)	mm² (AWG)	N·m (lb.in)
U22S6XU75S6X D11S6XD15S6X D11N4	6 (10)	6 (10)	1.8 (15.6)	6 (10)	10 (8)	1.8 (15.6)
U75N4	4 (12)	6 (10)	1.8 (15.6)	6 (10)	10 (8)	1.8 (15.6)
U55M3	6 (10)	6 (10)	1.8 (15.6)	10 (8)	10 (8)	1.8 (15.6)

Only use cables with solid wires or rigid stranded wires.

Frame Size 3

ATV630 (**)	Supply Terminals (L1, L2, L3)			Output Terminals (U, V, W)		
	Wire Cross Sec	tion	Tightening Torque	Wire Cross Section		Tightening Torque
	Minimum	Maximum (*)	Rated	Minimum	Maximum (*)	Rated
	mm² (AWG)	mm² (AWG)	N·m (lb.in)	mm² (AWG)	mm² (AWG)	N·m (lb.in)
D15N4, D18N4, U75M3	10 (8)	16 (6)	3.5 (30.4)	10 (8)	16 (6)	3.5 (30.4)
D22N4, D11M3	10 (8)	16 (6)	3.5 (30.4)	16 (6)	16 (6)	3.5 (30.4)

Only use cables with solid wires or rigid stranded wires.

^(*) Maximum cross section of the terminals

^(**) The 2 dots may stand for M3 or N4. The values for ATV -----N4 catalog numbers also apply to ATV -----N4Z.

^(*) Maximum cross section of the terminals

^(**) The values for ATV•••••N4 catalog numbers also apply to ATV•••••N4Z.

^(*) Maximum cross section of the terminals

^(**) The values for ATV630•••N4 catalog numbers also apply to ATV630•••N4Z.

Frame Size 3S

ATV630	Supply Termina	Supply Terminals (L1, L2, L3)			als (U, V, W)		
	Wire Cross Section		Tightening Torque	Wire Cross Section		Tightening Torque	
	Minimum	Maximum (*)	Rated	Minimum Maximum (*)		Rated	
	mm² (AWG)	mm² (AWG)	N·m (lb.in)	mm² (AWG)	mm² (AWG)	N·m (lb.in)	
D18S6, D22S6	10 (8)	10 (8)	12 (106.2)	10 (8)	10 (8)	12 (106.2)	
Only use cables y	Only use cables with solid wires or rigid stranded wires						

Frame Size 3Y

Supply Terminals (L1, L2, L3)			Output Termin	als (U, V, W)		
Wire Cross Section		Tightening Torque	Wire Cross Section		Tightening Torque	
Minimum	Maximum (*)	Rated	Minimum	Maximum (*)	Rated	
mm² (AWG)	mm² (AWG)	N·m (lb.in)	mm² (AWG)	mm² (AWG)	N·m (lb.in)	
4 (12)	10 (8)	3 (26.5)	4 (12)	10 (8)	3 (26.5)	
6 (10)	10 (8)	5.4 (47.7)	6 (10)	10 (8)	5.4 (47.7)	
10 (8)	10 (8)	12 (106.2)	10 (8)	10 (8)	12 (106.2)	
	Wire Cross Se Minimum mm² (AWG) 4 (12) 6 (10)	Minimum Maximum (*) mm² (AWG) mm² (AWG) 4 (12) 10 (8) 6 (10) 10 (8)	Wire Cross Section Tightening Torque Minimum Maximum (*) Rated mm² (AWG) mm² (AWG) N·m (lb.in) 4 (12) 10 (8) 3 (26.5) 6 (10) 10 (8) 5.4 (47.7)	Wire Cross Section Tightening Torque Wire Cross Section Minimum Maximum (*) Rated Minimum mm² (AWG) N·m (Ib.in) mm² (AWG) 4 (12) 10 (8) 3 (26.5) 4 (12) 6 (10) 10 (8) 5.4 (47.7) 6 (10)	Wire Cross Section Tightening Torque Wire Cross Section Minimum Maximum (*) Rated Minimum Maximum (*) mm² (AWG) mm² (AWG) N·m (lb.in) mm² (AWG) mm² (AWG) 4 (12) 10 (8) 3 (26.5) 4 (12) 10 (8) 6 (10) 10 (8) 5.4 (47.7) 6 (10) 10 (8)	

Only use cables with solid wires or rigid stranded wires.

Frame Size 4

ATV630 (**)	Supply Termina	als (L1, L2, L3)		Output Termina	out Terminals (U, V, W)		
	Wire Cross Section		Tightening Torque	Wire Cross Sec	Vire Cross Section		
	Minimum	Maximum (*)	Rated	Minimum	Maximum (*)	Rated	
	mm² (AWG)	mm² (AWG)	N·m (lb.in)	mm² (AWG)	mm² (AWG)	N·m (lb.in)	
D30N4, D15M3	25 (4)	50 (1)	12 (106.2)	25 (4)	50 (1)	12 (106.2)	
D37N4, D18M3	35 (3)	50 (1)	12 (106.2)	35 (3)	50 (1)	12 (106.2)	
D45N4, D22M3	35 (2)	50 (1)	12 (106.2)	50 (1)	50 (1)	12 (106.2)	

Only use cables with rigid stranded wires.

Frame Size 5

Supply Termina	ls (L1, L2, L3)		Output Termina		
Wire Cross Section		Tightening Torque	Wire Cross Section		Tightening Torque
Minimum	Maximum (*)	Min. to Maximum	Minimum	Maximum (*)	Rated
mm² (AWG)	mm² (AWG)	N·m (lb.in)	mm² (AWG)	mm² (AWG)	N·m (lb.in)
70 (1/0)	120 (250MCM)	25 (221.3)	70 (1/0)	120 (250MCM)	25 (221.3)
70 (1/0)	120 (250MCM)	25 (221.3)	70 (2/0)	120 (250MCM)	25 (221.3)
95 (3/0)	120 (250MCM)	25 (221.3)	95 (3/0)	120 (250MCM)	25 (221.3)
70 (2/0)	120 (250MCM)	25 (221.3)	95 (3/0)	120 (250MCM)	25 (221.3)
120 (4/0)	120 (250MCM)	25 (221.3)	120 (250MCM)	120 (250MCM)	25 (221.3)
	Minimum mm² (AWG) 70 (1/0) 70 (1/0) 95 (3/0) 70 (2/0)	Minimum Maximum (*) mm² (AWG) mm² (AWG) 70 (1/0) 120 (250MCM) 70 (1/0) 120 (250MCM) 95 (3/0) 120 (250MCM) 70 (2/0) 120 (250MCM)	Wire Cross Section Tightening Torque Minimum Maximum (*) Min. to Maximum mm² (AWG) N·m (lb.in) 70 (1/0) 120 (250MCM) 25 (221.3) 70 (1/0) 120 (250MCM) 25 (221.3) 95 (3/0) 120 (250MCM) 25 (221.3) 70 (2/0) 120 (250MCM) 25 (221.3)	Wire Cross Section Tightening Torque Wire Cross Section Minimum Maximum (*) Min. to Maximum Minimum mm² (AWG) N·m (lb.in) mm² (AWG) 70 (1/0) 120 (250MCM) 25 (221.3) 70 (1/0) 70 (1/0) 120 (250MCM) 25 (221.3) 70 (2/0) 95 (3/0) 120 (250MCM) 25 (221.3) 95 (3/0) 70 (2/0) 120 (250MCM) 25 (221.3) 95 (3/0)	Wire Cross Section Tightening Torque Wire Cross Section Minimum Maximum (*) Min. to Maximum Minimum Maximum (*) mm² (AWG) mm² (AWG) N·m (lb.in) mm² (AWG) mm² (AWG) 70 (1/0) 120 (250MCM) 25 (221.3) 70 (1/0) 120 (250MCM) 70 (1/0) 120 (250MCM) 25 (221.3) 70 (2/0) 120 (250MCM) 95 (3/0) 120 (250MCM) 25 (221.3) 95 (3/0) 120 (250MCM) 70 (2/0) 120 (250MCM) 25 (221.3) 95 (3/0) 120 (250MCM)

Only use cables with rigid stranded wires.

^(*) Maximum cross section of the terminals

^(*) Maximum cross section of the terminals

^(*) Maximum cross section of the terminals (**) The values for ATV630•••N4 catalog numbers also apply to ATV630•••N4Z.

^(*) Maximum cross section of the terminals (**) The values for ATV630•••N4 catalog numbers also apply to ATV630•••N4Z.

Frame Size 5S

ATV630	Supply Termin	als (L1, L2, L3)		Output Termin	Output Terminals (U, V, W)		
	Wire Cross Section		Tightening Torque	Wire Cross Se	Wire Cross Section		
	Minimum	Maximum (*)	Min. to Maximum	Minimum	Maximum (*)	Rated	
	mm² (AWG)	mm² (AWG)	N·m (lb.in)	mm² (AWG)	mm² (AWG)	N·m (lb.in)	
D30S6	16 (6)	50 (1/0)	11.3 (100)	16 (6)	50 (1/0)	41 (360)	
D37S6, D45S6	25 (4)	50 (1/0)	11.3 (100)	25 (4)	50 (1/0)	41 (360)	
D55S6	35 (2)	50 (1/0)	11.3 (100)	35 (2)	50 (1/0)	41 (360)	
D75S6	50 (1/0)	50 (1/0)	11.3 (100)	50 (1/0)	50 (1/0)	41 (360)	
Only use cables v	•						

Frame Size 5Y

ATV630	Supply Termin	als (L1, L2, L3)		Output Termin	Output Terminals (U, V, W)			
	Wire Cross Section		Tightening Torque	Wire Cross Se	/ire Cross Section			
	Minimum	Maximum (*)	Min. to Maximum	Minimum	Maximum (*)	Rated		
	mm² (AWG)	mm² (AWG)	N·m (lb.in)	mm² (AWG)	mm² (AWG)	N·m (lb.in)		
D37Y6	25 (4)	50 (1/0)	11.3 (100)	25 (4)	50 (1/0)	41 (360)		
D45Y6, D55Y6	25 (4)	50 (1/0)	11.3 (100)	25 (4)	50 (1/0)	41 (360)		
D75Y6	35 (2)	50 (1/0)	11.3 (100)	35 (2)	50 (1/0)	41 (360)		
D90Y6	50 (1/0)	50 (1/0)	11.3 (100)	50 (1/0)	50 (1/0)	41 (360)		
•	Only use cables with rigid stranded wires. (*) Maximum cross section of the terminals							

Frame Size 6

NOTE:

- If used with ring tongue: selection criteria are compatible with screw M10, width 24 mm (0.94 in.), following DIN 46234.
- If used with lugs: selection criteria are compatible with standard cable lug according to DIN 46234. You may also use lug kit DZ2FH6 and DZ2FH1 available on <u>schneider-electric.com</u>

ATV630	Supply Termina	ls (L1, L2, L3)		Output Termina	Output Terminals (U, V, W)		
	Wire Cross Section		Tightening Torque	Wire Cross Sec	Wire Cross Section		
	Minimum	Maximum (*)	Rated	Minimum	Maximum (*)	Rated	
	mm² (AWG)	mm² (AWG)	N·m (lb.in)	mm² (AWG)	mm² (AWG)	N·m (lb.in)	
C11N4	2 x 50 (2 x 1/0)	3 x 120 (2 x 300MCM)	27 (239)	2 x 50 (2 x 1/0)	3 x 120 (2 x 300MCM)	27 (239)	
C13N4, D55M3	2 x 70 (2 x 2/0)	3 x 120 (2 x 300MCM)	27 (239)	2 x 70 (2 x 2/0)	3 x 120 (2 x 300MCM)	27 (239)	
C16N4, D75M3	2 x 95 (2 x 3/0)	3 x 120 (2 x 300MCM)	27 (239)	2 x 95 (2 x 3/0)	3 x 120 (2 x 300MCM)	27 (239)	
(*) Maximum cros	(*) Maximum cross section of the terminals						

Frame Size 7A and 7B

ATV630	Supply Termina	Supply Terminals (L1, L2, L3)			ninals (U, V, W)		
	Wire Cross Sec	tion	Tightening Wire Cross Section Torque		Tightening Torque		
	Minimum	Maximum (*)	Rated	Minimum	Maximum (*)	Rated	
	mm² (AWG)	mm² (AWG)	N·m (lb.in)	mm² (AWG)	mm² (AWG)	N·m (lb.in)	
C22N4	2 x 150 (2 x 350MCM)	2 x 150 (2 x 350MCM)	41 (360)	2 x 150 (2 x 350MCM)	2 x 150 (2 x 350MCM)	41 (360)	
C25N4, C31N4	4 x 185 (3 x 350MCM)	4 x 185 (3 x 350MCM)	41 (360)	4 x 185 (3 x 350MCM)	4 x 185 (3 x 350MCM)	41 (360)	
(*) Maximum cros	(*) Maximum cross section of the terminals						

Frame Size A

ATV650	Supply Terminals (L1, L2, L3)			Output Termin	Output Terminals (U, V, W)		
	Wire Cross Section		Tightening Torque	Wire Cross Se	Wire Cross Section		
	Minimum	Maximum (*)	Rated	Minimum	Maximum (*)	Rated	
	mm² (AWG)	mm² (AWG)	N·m (lb.in)	mm² (AWG)	mm² (AWG)	N·m (lb.in)	
U07N4U55N4	4 (12)	6 (10)	1.3 (11.5)	4 (12)	6 (10)	1.3 (11.5)	
U07N4EU55N4E	4	6	2.1 (18.3)	4	6	1.3 (11.5)	
U75N4	4 (12)	6 (10)	1.8 (15.6)	6 (10)	10 (8)	1.8 (15.6)	
U75N4E	4	6	2.1 (18.3)	6	10	1.8 (15.6)	
D11N4	6 (10)	6 (10)	1.8 (15.6)	6 (10)	10 (8)	1.8 (15.6)	
D11N4E	6	6	2.1 (18.3)	6	10	1.8 (15.6)	
D15N4, D18N4	10 (8)	16 (6)	3.5 (30.4)	10 (8)	16 (6)	3.5 (30.4)	
D15N4E, D18N4E	10	16	4.5 (40)	10	16	3.5 (30.4)	
D22N4	10 (8)	16 (6)	3.5 (30.4)	16 (6)	16 (6)	3.5 (30.4)	
D22N4E	10	16	4.5 (40)	16	16	3.5 (30.4)	

Only use cables with solid wires or rigid stra (*) Maximum cross section of the terminals

Frame Size B

ATV650	Supply Termin	nals (L1, L2, L3)		Output Power	Output Power Terminals (U, V, W)			
	Wire Cross Section		Tightening Torque	Wire Cross Se	Wire Cross Section			
	Minimum	Maximum (*)	Rated	Minimum	Maximum (*)	Rated		
	mm² (AWG)	mm² (AWG)	N·m (lb.in)	mm² (AWG)	mm² (AWG)	N⋅m (lb.in)		
D30N4	25 (4)	50 (1)	12 (106.2)	25 (4)	50 (1)	12 (106.2)		
D30N4E	25	50	12 (106.2)	25	50	12 (106.2)		
D37N4	25 (4)	50 (1)	12 (106.2)	35 (3)	50 (1)	12 (106.2)		
D37N4E	25	50	12 (106.2)	35	50	12 (106.2)		
D45N4	35 (3)	50 (1)	12 (106.2)	35 (2)	50 (1)	12 (106.2)		
D45N4E	35	50	12 (106.2)	35	50	12 (106.2)		
Only use cal	Only use cables with rigid stranded wires.							

(*) Maximum cross section of the terminals

Frame Size C

ATV650	Supply Termin	nals (L1, L2, L3)		Output Termin	Output Terminals (U, V, W)		
	Wire Cross Se	ection	Tightening Torque	Wire Cross Section		Tightening Torque	
	Minimum	Maximum (*)	Rated	Minimum	Maximum (*)	Rated	
	mm² (AWG)	mm² (AWG)	N·m (lb.in)	mm² (AWG)	mm² (AWG)	N·m (lb.in)	
D55N4	50 (1)	120 (250MCM)	25 (221.3)	70 (1/0)	120 (250MCM)	25 (221.3)	
D55N4E	70	95	22.6 (200)	70	120	25 (221.3)	
D75N4	70 (2/0)	120 (250MCM)	25 (221.3)	95 (3/0)	120 (250MCM)	25 (221.3)	
D75N4E	95	95	22.6 (200)	95	120	25 (221.3)	
D90N4	95 (3/0)	120 (250MCM)	25 (221.3)	120 (4/0)	120 (250MCM)	25 (221.3)	
D90N4E	95	95	22.6 (200)	120	120	25 (221.3)	

Only use cables with rigid stranded wires. (*) Maximum cross section of the terminals

Floor Standing Drives - Normal Duty

ATV•30 and	Supply Terminals (L1,	L2, L3)	Output Terminals (U, V	/, W)
ATV•50	Wire Cross Section in r	nm²	Wire Cross Section in	mm²
	Recommended	Maximum (*)	Recommended	Maximum (*)
C11N4F	1 x (3 x 150 mm²) or	1 x (3 x 185 mm²) or	1 x (3 x 120 mm²) or	1 x (3 x 185 mm²) or
	2 x (3 x 70 mm²)	2 x (3 x 120 mm²)	2 x (3 x 70 mm²)	2 x (3 x 120 mm²)
C13N4F	1 x (3 x 185 mm²) or	1 x (3 x 185 mm²) or	1 x (3 x 150 mm²) or	1 x (3 x 185 mm²) or
	2 x (3 x 70 mm²)	2 x (3 x 120 mm²)	2 x (3 x 70 mm²)	2 x (3 x 120 mm²)
C16N4F	1 x (3 x 185 mm²) or	1 x (3 x 185 mm²) or	1 x (3 x 185 mm²) or	1 x (3 x 185 mm²) or
	2 x (3 x 95 mm²)	2 x (3 x 120 mm²)	2 x (3 x 95 mm²)	2 x (3 x 120 mm²)
C20N4F	2 x (3 x 120 mm²) or	3 x (3 x 185 mm²) or	2 x (3 x 120 mm²) or	3 x (3 x 185 mm²) or
	3 x (3 x 70 mm²)	4 x (3 x 120 mm²)	3 x (3 x 70 mm²)	4 x (3 x 120 mm²)
C25N4F	2 x (3 x 185 mm²) or	3 x (3 x 185 mm²) or	2 x (3 x 150 mm²) or	3 x (3 x 185 mm²) or
	3 x (3 x 95 mm²)	4 x (3 x 120 mm²)	3 x (3 x 95 mm²)	4 x (3 x 120 mm²)
C31N4F	3 x (3 x 150 mm²) or	3 x (3 x 185 mm²) or	2 x (3 x 185 mm²) or	3 x (3 x 185 mm²) or
	4 x (3 x 95 mm²)	4 x (3 x 120 mm²)	4 x (3 x 120 mm²)	4 x (3 x 120 mm²)
(*) Maximum o	ross section of the termin	als	<u>. </u>	

Floor Standing Drives - Heavy Duty

ATV•30 and	Supply Terminals (L1, L2, L3)		Output Terminals (U, V, W)	
ATV•50	Wire Cross Section in mm²		Wire Cross Section in mm²	
	Recommended	Maximum (*)	Recommended	Maximum (*)
C11N4F	1 x (3 x 150 mm²) or	1 x (3 x 185 mm²) or	1 x (3 x 150 mm ²) or	1 x (3 x 185 mm²) or
	2 x (3 x 70 mm²)	2 x (3 x 120 mm²)	2 x (3 x 70 mm ²)	2 x (3 x 120 mm²)
C13N4F	1 x (3 x 185 mm²) or	1 x (3 x 185 mm²) or	1 x (3 x 150 mm²) or	1 x (3 x 185 mm²) or
	2 x (3 x 70 mm²)	2 x (3 x 120 mm²)	2 x (3 x 70 mm²)	2 x (3 x 120 mm²)
C16N4F	1 x (3 x 185 mm²) or	1 x (3 x 185 mm²) or	1 x (3 x 150 mm²) or	1 x (3 x 185 mm²) or
	2 x (3 x 70 mm²)	2 x (3 x 120 mm²)	2 x (3 x 70 mm²)	2 x (3 x 120 mm²)
C20N4F	2 x (3 x 95 mm²)	3 x (3 x 185 mm²) or 4 x (3 x 120 mm²)	1 x (3 x 185 mm ²) or 2 x (3 x 95 mm ²)	3 x (3 x 185 mm²) or 4 x (3 x 120 mm²)
C25N4F	2 x (3 x 120 mm²) or	3 x (3 x 185 mm²) or	2 x (3 x 120 mm ²) or	3 x (3 x 185 mm²) or
	3 x (3 x 70 mm²)	4 x (3 x 120 mm²)	3 x (3 x 70 mm ²)	4 x (3 x 120 mm²)
C31N4F	3 x (3 x 150 mm²) or	3 x (3 x 185 mm²) or	2 x (3 x 185 mm²) or	3 x (3 x 185 mm²) or
	4 x (3 x 95 mm²)	4 x (3 x 120 mm²)	4 x (3 x 120 mm²)	4 x (3 x 120 mm²)
(*) Maximum cross section of the terminals				

Wiring The Power Part


Access To The Terminals For Frame Sizes 1 to 3, IP21 Drives for 200...240 V, 380...480 V and 600 V Supply Mains

A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

Read and understand the instructions in Safety Information chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.



Apply the following instructions to access the terminals on frame sizes 1 to 3 drives

Step	Action
1	Unscrew the 4 screws attaching the housing
2	Slide down the front cover
3	Remove the front cover
4	Refit the front cover on completion of wiring. Tighten the screws to 1.5 N•m / 13.3 lb-in.


Access To The Terminals For Frame Sizes 1 to 3, IP20 Drives for cabinet integration, 380...480 V Supply Mains

A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

Read and understand the instructions in **Safety Information** chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.



Apply the following instructions to access the terminals on frame sizes 1 to 3 IP20 drives

Step	Action
1	Unscrew the 2 screws attaching the housing
2	Slide down the front cover
3	Remove the front cover
4	Refit the front cover on completion of wiring. Tighten the screws to 1.5 N•m / 13.3 lb-in.


Access To The Terminals For Frame Sizes 3S and 5S, for 600 V Supply Mains

A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

Read and understand the instructions in **Safety Information** chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.



Apply the following instructions to access the terminals on frame sizes 3S and 5S drives

Step	Action
1	Unscrew the 10 screws attaching the housing
2	Remove the front covers
3	Refit the front cover on completion of wiring. Tighten the screws to 1.5 N•m / 13.3 lb-in.


Access To The Terminals For Frame Sizes 3Y and 5Y, for 500...690 V Supply Mains

DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

Read and understand the instructions in Safety Information chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.



Apply the following instructions to access the terminals on frame sizes 3Y and 5Y drives

Step	Action
1	Unscrew the 6 screws attaching the housing
2	Remove the front cover
3	Refit the front cover on completion of wiring. Tighten the screws to 1.5 N•m / 13.3 lb-in.


Access To The Terminals For Frame Sizes 4 and 5, IP21 Drives

A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

Read and understand the instructions in **Safety Information** chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.



Apply the following instructions to access the terminals on frame sizes 4 and 5 drives

Step	Action
1	Unscrew the 6 screws (frame size 4) ot the 8 screws (frame size 5) attaching the front and bottom covers
2	Remove the covers
3	On completion of wiring Refit the power terminal cover Refit the front cover
	Tighten the front cover screws to 1.1 N•m / 9.7 lb-in for frame size 4 2.6 N•m / 23 lb-in for frame size 5


Access To The Terminals For Frame Sizes 4 and 5, Drives for cabinet integration, 380...480 V Supply Mains

A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

Read and understand the instructions in Safety Information chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.



Apply the following instructions to access the terminals on frame sizes 4 and 5 drives

Step	Action
1	Unscrew the 4 screws attaching the front cover
2	Remove the cover
3	On completion of wiring refit the front cover. Tighten the front cover screws to 1.1 N*m / 9.7 lb-in for frame size 4 2.6 N*m / 23 lb-in for frame size 5


Access To The Terminals - Frame Size 6

A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

Read and understand the instructions in **Safety Information** chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.



Apply the following instructions to access the terminals on frame size 6 drives


Step	Action
1	Unscrew the 6 screws attaching the bottom front cover and remove it
2	Remove the terminal cover
3	Refit the front cover on completion of wiring. Tighten the screws to 3.3 N•m / 29.3 lb-in.

A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

Read and understand the instructions in **Safety Information** chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.



Apply the following instructions to access the terminals on frame size 7 drives

Step	Action
1	Unscrew the 4 screws attaching the bottom front cover and remove it
2	Remove the terminal cover
3	Refit the front cover on completion of wiring. Tighten the screws to 4.2 N•m / 37.17 lb-in.

Access To The Terminals For Frame Size A

A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH


Read and understand the instructions in **Safety Information** chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.

Apply the following instructions to access the terminals on frame size A drives

Step	Action
1	Unscrew the 4 captive screws attaching the housing
2	Remove the front cover
3	Attach it on the left or right side of the housing
4	Refit the front cover on completion of wiring. Tighten the screws to 1.5 N•m / 13.3 lb-in.

EAV64301 04/2020 155



Access To The Terminals For Frame Sizes B and C

A A DANGER


HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

Read and understand the instructions in **Safety Information** chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.

Apply the following instructions to access the terminals on frame sizes B and C drives

Step	Action
1	Unscrew the screw attaching the housing
2	Open the front cover
3	Refit the front cover on completion of wiring. Tighten the screws to 1.5 N•m / 13.3 lb-in.




Access To The Terminals - Floor Standing Drives


A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

Read and understand the instructions in **Safety Information** chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.





Apply the following instructions to access the terminals on Floor Standing drives

Step	Action
1	Open the enclosure. Unscrew the 9 front screws of both upper and lower covers
2	Unscrew the 3 side screws of both upper and lower covers
3	Remove the internal switch handle
4	Remove both upper and lower covers to access the power terminals.
5	On completion of wiring Refit both upper and lower covers Tighten the screws to 5.5 N•m / 48.6 lb-in Refit the internal switch handle


EAV64301 04/2020 157

Frame Size 1 and Frame Size A Cable Path

Correspondence Table Between Frame Size A and Frame Size 1

Power Rating		Frame Size A Drives	Frame Size 1 Drives
kW	HP	Catalog Number	Catalog Number
0.75	1	ATV650U07N4•	ATV630U07N4
1.5	2	ATV650U15N4•	ATV630U15N4
2.2	3	ATV650U22N4•	ATV630U22N4
3	-	ATV650U30N4•	ATV630U30N4
4	5	ATV650U40N4•	ATV630U40N4
5.5	7 ^{1/2}	ATV650U55N4•	ATV630U55N4

Wire the power cables as shown below (example for wall mounting drives).




NOTE: PA/+ and PC/- terminals are used only to measure the DC Bus voltage and are not intended to be wired for an external use.

Frame Size 2 and Frame Size A Cable Path

Correspondence Table Between Frame Size A and Frame Size 2

Power Rating		Frame Size A Drives	Frame Size 2 Drives
kW	HP	Catalog Number	Catalog Number
7.5	10	ATV650U75N4•	ATV630U75N4
11	15	ATV650D11N4•	ATV630D11N4

Wire the power cables as shown below (example for wall mounting drives).




NOTE: PA/+ and PC/- terminals are used only to measure the DC Bus voltage and are not intended to be wired for an external use.

Frame Size 3 and Frame Size A Cable Path

Correspondence Table Between Frame Size A and Frame Size 3

Power Rating		Frame Size A Drives	Frame Size 3 Drives
kW	HP	Catalog Number	Catalog Number
15	20	ATV650D15N4•	ATV630D15N4
18.5	25	ATV650D18N4•	ATV630D18N4
22	30	ATV650D22N4•	ATV630D22N4


Wire the power cables as shown below (example for wall mounting drives).



NOTE: PA/+ and PC/- terminals are used only to measure the DC Bus voltage and are not intended to be wired for an external use.

Frame Size 3S Cable Path

Wire the power cables as shown below.




NOTE: PA/+ and PC/- terminals are used only to measure the DC Bus voltage and are not intended to be wired for an external use.

EAV64301 04/2020 159

Frame Size 3Y Cable Path

NOTE: Due to accessible live parts on their lower part, these drives should be installed in enclosures or located behind enclosures or barriers, which comply at least with the requirements of IP2•, as per IEC61800-5-1.

Wire the power cables as shown below.




NOTE: PA/+ and PC/- terminals are used only to measure the DC Bus voltage and are not intended to be wired for an external use.

Frame Size 4 and Frame Size B Cable Path

Correspondence Table Between Frame Size B and Frame Size 4

Power Rating		Frame Size B Drives	Frame Size 4 Drives
kW	HP	Catalog Number	Catalog Number
30	40	ATV650D30N4•	ATV630D30N4
37	50	ATV650D37N4•	ATV630D37N4
45	60	ATV650D45N4•	ATV630D45N4

Wire the power cables as shown below (example for wall mounting drives).




NOTE: PA/+ and PC/- terminals are used only to measure the DC Bus voltage and are not intended to be wired for an external use.

Frame Size 5 and Frame Size C Cable Path

Correspondence Table Between Frame Size C and Frame Size 5

Power Rating		Frame Size C Drives	Frame Size 5 Drives
kW	HP	Catalog Number	Catalog Number
55	75	ATV650D55N4•	ATV630D55N4
75	100	ATV650D75N4•	ATV630D75N4
90	125	ATV650D90N4•	ATV630D90N4

Wire the power cables as shown below (example for wall mounting drives).




NOTE: PA/+ and PC/- terminals are used only to measure the DC Bus voltage and are not intended to be wired for an external use.



EAV64301 04/2020 16

Frame Size 5S Cable Path

Wire the power cables as shown below.




NOTE: PA/+ and PC/- terminals are used only to measure the DC Bus voltage and are not intended to be wired for an external use.

Frame Size 5Y Cable Path

NOTE: Due to accessible live parts on their lower part, these drives should be installed in enclosures or located behind enclosures or barriers, which comply at least with the requirements of IP2•, as per IEC61800-5-1.

Wire the power cables as shown below.



NOTE: PA/+ and PC/- terminals are used only to measure the DC Bus voltage and are not intended to be wired for an external use.



Frame Size 6 Cable Path


NOTE: Due to accessible live parts on their lower part, these drives should be installed in enclosures or located behind enclosures or barriers, which comply at least with the requirements of IP2•, as per IEC61800-5-1.

Use 1 or 2 connection cables per terminal, depending on the cable characteristics. Refer to standard IEC 60364-5-52 for cable selection. Permissible cable cross sections are given in the Power Terminals section (see page 143).

For 2 connection cable wiring:


Step	Action	
1	Connect the first cable on the lower terminal	
2	Connect the other cable on the upper terminal	


For 2 cable connection, wire the power cables as shown below.



NOTE: PA/+ and PC/- terminals are used only to measure the DC Bus voltage and are not intended to be wired for an external use.

NOTE: A conduit box is available as an option. It enables an IP21 degree of protection at the bottom side of the drive. See www.schneider-electric.com






Frame Size 7A Cable Path

NOTE: Due to accessible live parts on their lower part, these drives should be installed in enclosures or located behind enclosures or barriers, which comply at least with the requirements of IP2•, as per IEC61800-5-1.

Refer to standard IEC 60364-5-52 for cable selection. Permissible cable cross sections are given in the Power Terminals section (see page 143).

Wire the power cables as shown below.



Cable wiring:

5	Step Action	
	1	Connect the first cable on the lower terminal
	2	Connect the other cable on the upper terminal

NOTE: Wiring of the DC chokes is described in the Installing the DC Choke section (see page 122).




Frame Size 7B Cable Path

NOTE: Due to accessible live parts on their lower part, these drives should be installed in enclosures or located behind enclosures or barriers, which comply at least with the requirements of IP2•, as per IEC61800-5-1.

Refer to standard IEC 60364-5-52 for cable selection. Permissible cable cross sections are given in the Power Terminals section *(see page 143)*.

Wire the power cables as shown below.




Cable wiring:

Step	Action
1	Connect the first cable on the lower terminal
2	Connect the other cable on the upper terminal

NOTE: Wiring of the DC chokes is described in the Installing the DC Choke section (see page 122).

Frame Size 7A and 7B DC Bus terminals


The figure below shows where to find DC Bus terminals (PA/+, PC/-).



NOTE: PA/+ and PC/- terminals are used only to measure the DC Bus voltage and are not intended to be wired for an external use.

Connecting Fans For a Separate Power Supply on Frame Sizes 7A and 7B

In order to remove the link between the fans and power supply terminals R/L1, S/L2, T/L3 and relocate it at terminals R0, S0, T0. Cross the connectors X1 and X4 as indicated on the diagram below.



- 1 Factory wiring: Fans powered internally by R/L1, S/L2, T/L3.
- 2 Modification for fans powered externally by R0, S0, T0.


Floor Standing Drives - Wiring Procedure

Permissible cable cross sections and tightening torques are given in the Power Terminals section (see page 143).

NOTE: The cable length from the bottom of the drive to the terminals is between 350 mm (13.8 in.) and 420 mm (16.6 in.), depending on the rank of the terminal.

Perform the following instructions to connect the power part:

Step	Action
1	Verify the input mains supply voltage. The drive transformer is factory set to suit a 380/400 Vac mains supply input voltage. If the supply mains voltage is between 415 and 440 Vac, disconnect P1 transformer terminal and connect the wire to the P2 terminal.
2	Connect the supply mains cable lugs to the power input terminals L1, L2, L3. Attach the PE cable lug to the Ground bar.
3	Connect the motor cable lugs to the power output terminals U, V, W. Attach the PE cable lug to the Ground bar.
4	Position the lower cable clamp on the insulated part of the supply mains cable and attach it to the lower rail. Position the upper cable clamp on the cable shielding of the motor cable and attach it to the upper rail. Position the lower cable clamp on the insulated part of the motor cable and attach it to the lower rail.



- flat washer
- b nut
- spring washer
- flat washer
- M12 screw

168

Electromagnetic Compatibility

Limit Values

This product meets the EMC requirements according to the standard IEC 61800-3 if the measures described in this manual are implemented during installation.

This product meets the EMC requirements according to the standard IEC 61800-3. If the selected composition (product itself, mains filter, other accessories and measures) does not meet the requirements of category C1, the following information applies as it appears in IEC 61800-3:

A WARNING

RADIO INTERFERENCE

In a domestic environment this product may cause radio interference in which case supplementary mitigation measures may be required.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

EMC requirements for the control cabinet

EMC measures	Objective
Use mounting plates with good electrical conductivity, connect large surface areas of metal parts, remove paint from contact areas.	Good conductivity due to large surface contact.
Ground the control cabinet, the control cabinet door and the mounting plate with ground straps or ground wires. The conductor cross section must be at least 10 mm ² (AWG 8).	Reduces emissions.
Fit switching devices such as power contactors, relays or solenoid valves with interference suppression units or arc suppressors (for example, diodes, varistors, RC circuits).	Reduces mutual interference.
Install power components and control components separately.	
Install frame size 1 and 2 drives on grounded metal back plane.	Reduces emissions.

Shielded cables

EMC measures	Objective
Connect large surface areas of cable shields, use cable clamps and ground straps.	Reduces emissions.
Use cable clamps to connect a large surface area of the shields of all shielded cables to the mounting plate at the control cabinet entry.	
Ground shields of digital signal wires at both ends by connecting them to a large surface area or via conductive connector housings	Reduces interference affecting the signal wires, reduces emissions
Ground the shields of analog signal wires directly at the device (signal input); insulate the shield at the other cable end or ground it via a capacitor (for example, 10 nF, 100 V or higher.	Reduces ground loops due to low-frequency interference.
Use only shielded motor cables with copper braid and a coverage of at least 85%, ground a large surface area of the shield at both ends.	Diverts interference currents in a controlled way, reduces emissions.
Codiletin	

EAV64301 04/2020 169

Cable Installation

EMC measures	Objective
Do not route fieldbus cables and signal wires in a single cable duct together with lines with DC and AC voltages of more than 60 V. (Fieldbus cables, signal lines and analog lines may be in the same cable duct) Recommendation: Use separate cable ducts at least 20 cm (8 in.) apart.	Reduces mutual interference.
Keep cables as short as possible. Do not install unnecessary cable loops, use short cables from the central grounding point in the control cabinet to the external ground connection.	Reduces capacitive and inductive interference.
Use equipotential bonding conductors in the following cases: wide-area installations, different voltage supplies and installation across several buildings.	Reduces current in the cable shield, reduces emissions.
Use fine stranded equipotential bonding conductors.	Diverts high-frequency interference currents
If motor and machine are not conductively connected, for example by an insulated flange or a connection without surface contact, you must ground the motor with a ground strap or a ground wire. The conductor cross section must be at least 10 mm ² (AWG 8).	Reduces emissions, increases immunity.
Use twisted pair for the DC supply. For digital and analog inputs use shielded twisted cables with a pitch of between 2550 mm (12 in).	Reduces interference affecting the signal cables, reduces emissions.

Power Supply

EMC measures	Objective
Operate product on mains with grounded neutral point.	Enables effectiveness of mains filter.
Surge arrester if there is a risk of overvoltage.	Reduces the risk of damage caused by overvoltage.



170

Operation on an IT or Corner Grounded System

Definition

IT system: Isolated or impedance grounded neutral. Use a permanent insulation monitoring device compatible with nonlinear loads, such as an XM200 type or equivalent.

Corner grounded system: System with one phase grounded.

Operation

NOTICE

OVERVOLTAGE OR OVERHEATING

If the drive is operated via an IT or corner grounded system, the integrated EMC filter must be disconnected as described in the present manual.

Failure to follow these instructions can result in equipment damage.



Disconnecting The Built-in EMC Filter

Filter Disconnection

A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

Read and understand the instructions in Safety Information chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.

The drives have a built-in EMC filter. As a result they exhibit leakage current to ground. If the leakage current creates compatibility problems with your installation (residual current device or other), then you can reduce the leakage current by disconnecting the built-in filter as shown below. In this configuration the product does not meet the EMC requirements according to the standard IEC 61800-3.

Setting


Apply the following instructions to disconnect the built-in EMC filter.

Step	Action
1	Remove the front cover(s) (see page 149)
2	The screw(s) or switch is/are factory set to the position, as shown on detail ①
3	For operation without the built-in EMC filter, remove the screw(s) from its/ their location or move the switch from its position and set it/them to the position, as shown on detail ②
4	Refit the front cover(s)


NOTE:

- Use only the screw(s) supplied.
- Do not operate the drive with setting screw(s) removed.


Setting For Frame Size 1 Products




Setting For Frame Size 2 Products




Setting For Frame Size 3 and IP55 Frame Size A Products




Setting For Frame Size 3S, Frame Size 3Y and Frame Size 4 Products, 200...240 $\rm V$




Setting For IP55 Frame Size B Products and Frame Size 4 Products, 380...480 V




Setting For Frame Size 5 Products and IP55 Frame Size C Products




Setting For Frame Size 5S and Frame Size 5Y Products Setting For Frame Size 6 Products




Setting For Frame Size 7A Products



Setting For Frame Size 7B Products




Setting For Floor Standing Products



Arrangement and Characteristics of Control Block Terminals and Communication and I/O Ports

Terminal Arrangement

The control block terminals are the same for all drive frame sizes.



1 Ethernet Modbus TCP, 2 Serial Modbus

NOTE: Modbus VP12S: This is the standard Modbus serial link marking. VP•S means connector with power supply, where 12 stands for the 12 Vdc supply voltage.

Wiring Characteristics


NOTE: Control terminals can accept 1 or 2 wires.

Wire cross sections and tightening torques


Control	Relay Output Wire Cross Section		Other Wire Cross Section		Tightening	
Terminals	Minimum (1)	Maximum	Minimum (1)	Maximum	Torque	
	mm² (AWG)	mm² (AWG)	mm² (AWG)	mm² (AWG)	N•m (lb.in)	
All terminals	0.75 (18)	1.5 (16)	0.5 (20)	1.5 (16)	0.5 (4.4)	

(1) The value corresponds to the minimum permissible cross section of the terminal.

NOTE: Also refer to Control Terminal Electrical data (see page 179).



Control Block Ports



Legend

Marking	Description			
1	RJ45 port for Graphic display terminal			
2	RJ45 port for Ethernet embedded			
3	Sink-Ext-Source switch (see page 141)			
4	RJ45 port for Modbus embedded			
5	Slot B, for I/O modules			
6	Slot A, for fieldbus and I/O modules			

RJ45 Communication ports

The control block includes 3 RJ45 ports.

They allow to connect:

- A PC
 - O Using a commissioning software (SoMove, SoMachine...), to configure and monitor the drive
 - O To access the drive webserver
- A SCADA system
- A PLC system
- A Graphic Display terminal, using Modbus protocol
- A Modbus fieldbus

NOTE: Verify that RJ45 cable is not damaged prior to connect it to the product otherwise the power supply of the control could be lost.

NOTE: Do not plug Ethernet cable in Modbus plug or vice versa.

Control Terminals Electrical Data

Characteristics of Terminals

NOTE

- For a description of the terminal arrangement, refer to Arrangement and Characteristics of Control Terminals and Communication And I/O Ports (see page 177)
- For factory setting I/O assignment, refer to the Programming manual (see page 9).
- For cable lengths, refer to the table given in the Wiring The control Part section (see page 183).

Terminal	Description	I/O Type	Electrical characteristics
R1A	NO contact of relay R1	О	Output Relay 1
R1B	-		Minimum switching capacity: 5 mA for 24 Vdc
	NC contact of relay R1	0	Maximum switching current on resistive load:
R1C	Common point contact of relay R1	0	3 A for 250 Vac (OVC II) and 30 Vdc
	Of felay KT		Maximum switching current on inductive load:
			 2 A for 250 Vac (OVC II) and 30 Vdc. Inductive load must be equipped with a voltage surge suppression device according to ac or dc operation with total energy dissipation greater than the inductive energy stored in the load. Refer to sections Output Relay with Inductive AC Loads (see page 139) and Output Relay with Inductive DC Loads (see page 139). Refresh time: 5 ms ± 0.5 ms
			Service life: 100,000 operations at maximum switching current
R2A	NO contact of relay R2	0	Output Relay 2
R2C	Common point contact	0	Minimum switching capacity: 5 mA for 24 Vdc
	of relay R2		Maximum switching current on resistive load: A for 250 Vac (OVCII) and 30 Vdc
			Maximum switching current on inductive load:
			2 A for 250 Vac (OVCII) and 30 Vdc. Inductive load must be
			equipped with a voltage surge suppression device according to ac or
			dc operation with total energy dissipation greater than the inductive
			energy stored in the load. Refer to sections Output Relay with Inductive AC Loads (see page 139) and Output Relay with Inductive
			DC Loads (see page 139)
			Refresh time: 5 ms ± 0.5 ms
			Service life: 100 000
			 100,000 operations at maximum switching current 1,000,000 operations at 0.5 A
R3A	NO contact of relay R3	0	Output Relay 3 Minimum switching capacity: 5 mA for 24 Vdc
R3C	Common point contact of relay R3	0	Maximum switching current on resistive load:
	Of felay No		5 A for 250 Vac (OVCII) and 30 Vdc
			Maximum switching current on inductive load:
			2 A for 250 Vac (OVCII) and 30 Vdc. Inductive load must be
			equipped with a voltage surge suppression device according to ac or dc operation with total energy dissipation greater than the inductive
			energy stored in the load. Refer to sections Output Relay with
			Inductive AC Loads (see page 139) and Output Relay with Inductive
			DC Loads (see page 139) • Refresh time: 5 ms ± 0.5 ms
			Service life:
			100,000 operations at maximum switching current
			O 1,000,000 operations at 0.5 A
STOA,	STO inputs	I	Safety Function STO Inputs
STOB			Refer to the Embedded Safety Function Manual (<u>EAV64334</u>) available
			on www.schneider-electric.com
24V	Output power supply for	0	Use only PELV standard power supply unit.
	digital inputs and safety		• +24 Vdc
	function STO inputs		Tolerance: minimum 20.4 Vdc, maximum 27 Vdc Current: maximum 200 mA for both 24 Vdc terminals
			Terminal protected against overload and short-circuit
			In Sink Ext position, this supply is powered by external PLC supply
СОМ	Analog I/O common	I/O	0 V for Analog outputs
	-	1	

EAV64301 04/2020 179

Terminal	Description	I/O Type	Electrical characteristics	
AQ1 AQ2	Analog output Analog output	0	 AQ: Analog output software-configurable for voltage or current Voltage analog output 010 Vdc, minimum. Minimum load impedance 470 Ω, Current analog output X-Y mA by programming X and Y from 020 mA, maximum load impedance 500 Ω Sampling time: 10 ms + 1 ms maximum Resolution 10 bits Accuracy: ±1 % for a temperature variation of 60 °C (108 °F) Linearity ±0.2 % 	
P24	External input supply	I	 External input supply +24 Vdc Tolerance: minimum 19 Vdc, maximum 30 Vdc Current: maximum 0.8 A 	
0V	0 V	I/O	0 V for P24	
DI1-DI6	Digital inputs	I	6 programmable logic inputs 24 Vdc, comply with IEC/EN 61131-2 logic type 1 • Positive logic (Source): State 0 if ≤ 5 Vdc or logic input not wired, state 1 if ≥ 11 Vdc • Negative logic (Sink):State 0 if ≥ 16 Vdc or logic input not wired, state 1 if ≤ 10 Vdc • Impedance 3.5 kΩ • Maximum voltage: 30 Vdc • Sampling time: 2 ms + 0.5 ms maximum	
			Multiple assignment makes it possible to configure several functions on one input (example: DI1 assigned to forward and preset speed 2, DI3 assigned to reverse and preset speed 3).	
DI5-DI6	Pulse inputs	I	Programmable Pulse input Comply with level 1 PLC, IEC 65A-68 standard State 0 if < 0.6 Vdc, state 1 if > 2.5 Vdc Pulse counter 030 kHz Frequency range: 030 kHz Cyclic ratio: 50 % ±10 % Maximum input voltage 30 Vdc, < 10 mA Sampling time: 5 ms + 1 ms maximum	
10V	Output supply for Analog input	0	Internal supply for the analog inputs 10.5 Vdc Tolerance ±5 % Current: maximum 10 mA Short circuit protected	
Al1-Al2- Al3	Analog inputs	I	Software-configurable V/A: voltage or current analog input Voltage analog input 010 Vdc, impedance 30 kΩ, Current analog input X-Y mA by programming X and Y from 020 mA, with impedance 250 Ω Sampling time: 5 ms + 1 ms maximum Resolution 12 bits Accuracy: ±0.6 % for a temperature variation of 60 °C (108 °F) Linearity ±0.15 % of maximum value	
СОМ	Analog I/O common	I/O	0 V for Analog inputs	

Terminal	Description	I/O Type	Electrical characteristics
AI2-AI3	Sensor inputs	I	Software-configurable PT100/PT1000 or KTY84 or PTC or Water level sensor PT100 1 or 3 thermal sensors mounted in series (configurable by software) Sensor current: 5 mA Range -20200 °C (-4392 °F) Accuracy ±4 °C (7.2 °F) for a temperature variation of 60 °C (108 °F)
			 ▶ PT1000 ○ 1 or 3 thermal sensors mounted in series (configurable by software) ○ Thermal sensor current: 1 mA ○ Range -20200 °C (-4392 °F) ○ Accuracy ±4 °C (7.2 °F) for a temperature variation of 60 °C (108 °F)
			 PTC 6 sensors maximum mounted in series Sensor current: 1 mA Nominal value: < 1.5 kΩ Overheat trigger threshold: 2.9 kΩ ± 0.2 kΩ Overheat reset threshold: 1.575 kΩ ± 0.75 kΩ Low impedance detection threshold: 50 Ω –10 Ω/+20 Ω
			 KTYp84 1 thermal sensor Thermal sensor current: 1 mA Range -20200 °C (-4392 °F) Accuracy ±4 °C (7.2 °F) for a temperature variation of 60 °C (108 °F)
			 Water Level Sensor Sensitivity: 01 MΩ, adjustable by software Water level sensor current: 0.3 mA1 mA maximum Adjustable delay: 010 s



Wiring The Control Part

Preliminary Instructions

A A DANGER

ELECTRIC SHOCK CAUSED BY INCORRECT POWER SUPPLY UNIT

The +24 Vdc supply voltage is connected with many exposed signal connections in the drive system.

• Use a power supply unit that meets the PELV (Protective Extra Low Voltage) requirements.

Failure to follow these instructions will result in death or serious injury.

A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

Read and understand the instructions in **Safety Information** chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.

Unsuitable settings or unsuitable data or unsuitable wiring may trigger unintended movements, trigger signals, damage parts and disable monitoring functions.

A WARNING

UNANTICIPATED EQUIPMENT OPERATION

- Only start the system if there are no persons or obstructions in the zone of operation.
- Verify that a functioning emergency stop push-button is within reach of all persons involved in the operation.
- Do not operate the drive system with unknown settings or data.
- Verify that the wiring is appropriate for the settings.
- Never modify a parameter unless you fully understand the parameter and all effects of the modification.
- When commissioning, carefully run tests for all operating states, operating conditions and potential error situations.
- Anticipate movements in unintended directions or oscillation of the motor.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

A WARNING

INCORRECT WIRING

Only PELV circuits are allowed to be connected on the control part (except relays R1, R2 and R3).

Failure to follow these instructions can result in death, serious injury, or equipment damage.

NOTICE

INCORRECT VOLTAGE

Only supply the digital inputs with 24 Vdc.

Failure to follow these instructions can result in equipment damage.

Control Cable Lengths

Control terminal Input/Output Cables		Maximum wires length depending on cable cross section (*)	
		1.5 mm ² / AWG16	0.5 mm ² / AWG20
Analog inputs Al1, Al2, Al3	voltage: 0 - 10 V	30 m / 98 in	30 m / 98 in
	current: 0 - 20 mA	3000 m / 9840 ft	1000 m / 3280 ft
Analog inputs Al2, Al3	PT100	30 m / 98 in	10 m / 32 ft
	PT1000	300 m / 984 ft	100 m / 328 ft
	KTY84	300 m / 984 ft	100 m / 328 ft
	PTC	300 m / 984 ft	100 m / 328 ft
	Water level	3000 m / 9840 ft	1000 m / 3280 ft
Output supply 10V		30 m / 98 in	30 m / 98 in
Analog outputs AQ1, AQ2	voltage: 0 - 10 V	30 m / 98 in	10 m / 32 ft
	current: 0 - 20 mA	3000 m / 9840 ft	1000 m / 3280 ft
Output power supply 24V	200 mA max.	300 m / 984 ft	100 m / 328 ft
Digital inputs DI1DI6		3000 m / 9840 ft	1000 m / 3280 ft
Safe Torque Off inputs STOA, STOB		3000 m / 9840 ft	1000 m / 3280 ft
Control power supply input P24	24 V input	120 m / 390 ft	40 m / 130 ft

^(*) Shorter cable lengths or smaller cable cross sections can be adjusted using linear interpolation with the values listed in the table. For example: maximum 10 m / 32 ft with 0.5 mm² / AWG20 and maximum 30 m with 1.5 mm² / AWG16 listed in the table, is equivalent to maximum 20 m / 65 ft with 1 mm² / AWG17.



Optional Module Installation and Wiring


NOTE:

- For possible fieldbus module list, refer to the catalog (see page 9)
- For fieldbus modules information, refer to the instruction sheet <u>\$1A45591\$</u> available on <u>www.schneider-</u>

To help ensure correct wiring of the control part, apply the following instructions to install and connect a module to be wired.

Step	Action
1	Insert the module in the slot A or B (see page 178).
2	Insert the cable in the cabling plate, according to the outlined locations. The breakable cut out is used for fieldbus cables.
3	Connect the cable to the module

(Procedure applicable for wall mounting product)



NOTE: Cabling plate shown is for frame size 2. Other cabling plates look slightly differs from this one.

NOTE: For Floor standing products route the option cables into the integrated control cable conduit.




184

I/O Relay Module Installation and Wiring


To help ensure correct wiring of the control part, apply the following instructions to install and connect an I/O relay module.

Step	Action		
1	Insert the I/O relay module in an option slot.		
2	Push the module into its location and keep access to the module terminal screws.		
3	Insert the I/O cable in the cabling plate, according to the outlined location.		
4	Wire the I/O relay module.		
5	Push again the module to its final position.		

(Procedure applicable for wall mounting product)



Special Case of PROFIBUS Fieldbus Module Installation and Wiring on Frame Size 1 Drives




To help ensure correct wiring of the control part, apply the following instructions to install the PROFIBUS fieldbus module on Frame size 1 drives

Step	Action
1	Insert the module in its slot
2	Insert the SUB-D connector in the cut out of the cabling plate
3	Plug the SUB-D connector to the module

Control Cables Path - Drives With Conduit Box

To help ensure correct wiring of the control part, apply the following instructions to wire the control block terminals


Step	Action
1	Wire the P24, 0V, the digital inputs (DI1DI6), and the 24V terminal
2	Wire the safety outputs STOA, STOB, the 24V, the COM and the analog outputs (AQ1, AQ2) terminals, wire the 10V, the analog inputs (AI1AI3) and COM terminals
3	Wire the Relay outputs



NOTE: Cabling plate shown is for frame size 2. Other cabling plates look slightly differs from this one. NOTE: For Floor standing products route the control wires into the integrated control cable conduit.

Ethernet Cable Path


(Wiring applicable for wall mounting product)




plates Ir NOTE: Cabling plate shown is for frame size 2. Other cabling plates look slightly differs from this one. NOTE: For Floor standing products route the control wires into the integrated control cable conduit.

Control Cables Path - Drives Without Conduit Box

Example: cable path for frame size 3Y for 500-690 V mains voltage



Example: cable path for frame size 5Y for 500-690 V mains voltage



Chapter 5 Checking Installation

Check List Before Switching On

The safety function STO (Safe Torque Off) does not remove power from the DC bus. The safety function STO only removes power to the motor. The DC bus voltage and the mains voltage to the drive are still present.

🛕 🛕 DANGER

HAZARD OF ELECTRIC SHOCK

- Do not use the safety function STO for any other purposes than its intended function.
- Use an appropriate switch, that is not part of the circuit of the safety function STO, to disconnect the drive from the mains power.

Failure to follow these instructions will result in death or serious injury.

Unsuitable settings or unsuitable data or unsuitable wiring may trigger unintended movements, trigger signals, damage parts and disable monitoring functions.

A WARNING

UNANTICIPATED EQUIPMENT OPERATION

- Only start the system if there are no persons or obstructions in the zone of operation.
- Verify that a functioning emergency stop push-button is within reach of all persons involved in the operation.
- Do not operate the drive system with unknown settings or data.
- Verify that the wiring is appropriate for the settings.
- Never modify a parameter unless you fully understand the parameter and all effects of the modification.
- When commissioning, carefully run tests for all operating states, operating conditions and potential error situations.
- Anticipate movements in unintended directions or oscillation of the motor.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

If the power stage is disabled unintentionally, for example as a result of power outage, errors or functions, there is a possibility that the motor is no longer decelerated in a controlled way.

▲ WARNING

UNANTICIPATED EQUIPMENT OPERATION

Verify that movements without braking effect cannot cause injuries or equipment damage.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Mechanical Installation

Verify the mechanical installation of the entire drive system:

Step	Action	1
1	Does the installation meet the specified distance requirements?	
2	Did you tighten all fastening screws to the specified tightening torque?	

Electrical installation

Verify the electrical connections and the cabling:

Step	Action	1
1	Did you connect all protective ground conductors?	
2	The correct tightening of the screws may be altered during assembly and wiring phases of the drive. Verify and adjust the tightening of all terminal screws to the specified nominal torque.	
3	Do all fuses and circuit breaker have the correct rating; are the fuses of the specified type? (refer to the information provided in the Altivar Process ATV600 Getting Started Annex (SCCR), catalog number: <u>EAV64300</u> for UL/CSA compliance and also in the catalog (see page 9) for IEC compliance.	
4	Did you connect or insulate all wires at the cable ends?	
5	Did you properly separate and insulate the control and power wiring?	
6	Did you properly connect and install all cables and connectors?	
7	Do all plug-in terminals colors and markings correspond to the colors and marking of the control block?	
8	Did you properly connect the signal wires?	
9	Are the required shield connections EMC-compliant?	
10	Did you take all measures for EMC compliance?	
11	On floor standing products, verify that internal circuit breaker is closed	

Covers And Seals

Verify that all devices, doors and covers of cabinet are properly installed to meet the required degree of protection.



190

Chapter 6 Maintenance

What Is in This Chapter?

This chapter contains the following topics:

Topic	Page
Scheduled Servicing	191
Long-term Storage	193
Decommissioning	193
Additional Support	193

Scheduled Servicing

Servicing

A A DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

Read and understand the instructions in **Safety Information** chapter before performing any procedure in this chapter.

Failure to follow these instructions will result in death or serious injury.

The temperature of the products described in this manual may exceed 80 °C (176 °F) during operation.

A WARNING

HOT SURFACES

- Ensure that any contact with hot surfaces is avoided.
- Do not allow flammable or heat-sensitive parts in the immediate vicinity of hot surfaces.
- Verify that the product has sufficiently cooled down before handling it.
- Verify that the heat dissipation is sufficient by performing a test run under maximum load conditions.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

A WARNING

INSUFFICIENT MAINTENANCE

Verify that the maintenance activities described below are performed at the specified intervals.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Adherence to the environmental conditions must be ensured during operation of the drive. In addition, during maintenance, verify and, if appropriate, correct all factors that may have an impact on the environmental conditions.

	Part concerned	Activity	Interval (1)
Overall condition	All parts such as housing, HMI, control block, connections, etc.	Perform a visual inspection	At least every year
Corrosion	Terminals, connectors, screws, EMC plate	Inspect and clean if required	
Dust	Terminals, fans, cabinet air inlets and air outlets, air filters of cabinet	Inspect and clean if required	
	Drives filter mats Floor standing	Inspect	At least every year
		Change	At least every 4 years
Cooling	Wall mounting drives fan	Verify the fan operation	At least every year
		Replace the fan, see catalog and the instructions sheets on www.schneider-electric.com .	After 3 to 5 years, depending on the operating conditions
	Floor standing drives fan for power part and enclosure door fan	Replace the fans, see catalog and the instructions sheets on www.schneider-electric.com.	Every 35000 operating hours or every 6 years
Fastening	All screws for electrical and mechanical connections	Verify tightening torques	At least every year

⁽¹⁾ Maximum maintenance intervals from the date of commissioning. Reduce the intervals between maintenance to adapt maintenance to the environmental conditions, the operating conditions of the drive, and to any other factor that may influence the operation and/ or maintenance requirements of the drive.

NOTE: The fan operation depends on the drive thermal state. The drive may be running and the fan not. Fans may continue to run for a certain period of time even after power to the product has been disconnected.

CAUTION

RUNNING FANS

Verify that fans have come to a complete standstill before handling them.

Failure to follow these instructions can result in injury or equipment damage.

Diagnostic And Troubleshooting

Refer to the ATV600 Programming Manual (see page 9) available on www.schneider-electric.com

Spares and repairs

Serviceable product. Please refer to your Customer Care Center on:

www.schneider-electric.com/CCC.

192

Long-term Storage

Capacitor Reforming

If the drive was not connected to mains for an extended period of time, the capacitors must be restored to their full performance before the motor is started.

NOTICE

REDUCED CAPACITOR PERFORMANCE

- Apply mains voltage to the drive for one hour before starting the motor if the drive has not been connected to mains for the following periods of time:
 - O 12 months at a maximum storage temperature of +50°C (+122°F)
 - O 24 months at a maximum storage temperature of +45°C (+113°F)
 - o 36 months at a maximum storage temperature of +40°C (+104°F)
- Verify that no Run command can be applied before the period of one hour has elapsed.
- Verify the date of manufacture if the drive is commissioned for the first time and run the specified procedure if the date of manufacture is more than 12 months in the past.

Failure to follow these instructions can result in equipment damage.

If the specified procedure cannot be performed without a Run command because of internal mains contactor control, perform this procedure with the power stage enabled, but the motor being at standstill so that there is no appreciable mains current in the capacitors.

Decommissioning

Uninstall the Product

Observe the following procedure when uninstalling the product.

- Switch off all supply voltage. Verify that no voltages are present refer to Safety Information chapter (see page 5).
- Remove all connection cables.
- Uninstall the product.

End of Life

The components of the product consist of different materials which can be recycled and which must be disposed of separately.

- Dispose of the packaging in compliance with all applicable regulations.
- Dispose of the product in compliance with all applicable regulations.

Refer to Green Premium section (see page 29) for information and documents on environmental protection such as EoLI (End of Life instruction).

Additional Support

Customer Care Center

For additional support, you can contact our Customer Care Center on:

www.schneider-electric.com/CCC.

Glossary



AC

Alternating Current

D

DC

Direct Current

E

ELV

Extra-Low Voltage. For more information: IEC 60449

Error

Discrepancy between a detected (computed, measured, or signaled) value or condition and the specified or theoretically correct value or condition.

F

Factory setting

Factory settings when the product is shipped

Fault

Fault is an operating state. If the monitoring functions detect an error, a transition to this operating state is triggered, depending on the error class. A "Fault reset" is required to exit this operating state after the cause of the detected error has been removed. Further information can be found in the pertinent standards such as IEC 61800-7, ODVA Common Industrial Protocol (CIP).

Fault reset

A function used to restore the drive to an operational state after a detected error is cleared by removing the cause of the error so that the error is no longer active.

G

GP

General-Purpose

L

L/R

Time constant equal to the quotient of inductance value (L) over the resistance value (R).

N

NC contact

Normally Closed contact

NO contact

Normally Open contact

0

OEM

Original Equipment Manufacturer

OVCII

Overvoltage Category II, according IEC 61800-5-1

P

PA/+

DC bus terminal

PC/-

DC bus terminal

PELV

Protective Extra Low Voltage, low voltage with isolation. For more information: IEC 60364-4-41

PLC

Programmable logic controller

Power stage

The power stage controls the motor. The power stage generates current for controlling the motor.

PTC

Positive Temperature Coefficient. PTC thermistor probes integrated in the motor to measure its

temperature

R

REACh

Registration, Evaluation, Authorisation and restriction of Chemicals regulation

RoHS

Restriction of Hazardous Substances

S

SCPD

Short-Circuit Protective Device

STO

Safe Torque Off: No power that could cause torque or force is supplied to the motor

Т

TVS Diode

Transient Voltage Suppression Diode

VHP

Very High Horse Power (> 800 kW)

W

Warning

If the term is used outside the context of safety instructions, a warning alerts to a potential problem that was detected by a monitoring function. A warning does not cause a transition of the operating state.

Odien

all.com

colinatati.com



